

DETAILED ENERGY STUDY

Report

University City Municipal Buildings
University City, MO



August 2011

Prepared by

Allen&Hoshall
engineering since 1915



Table of Contents

LIST OF TABLES4

LIST OF FIGURES5

EXECUTIVE SUMMARY7

INCENTIVES SUMMARY8

SAVINGS SUMMARY9

MEASUREMENT AND VERIFICATION SUMMARY9

ENVIRONMENTAL IMPACT.....10

FACILITY DESCRIPTIONS11

 ANNEX 11

 TRINITY BUILDING 18

 HEMAN PARK COMMUNITY CENTER..... 21

 HEMAN PARK POOL 27

 CENTRAL GARAGE 31

 HEMAN PARK TENNIS COURT, RESTROOM, AND PAVILION 37

 TRANSFER STATION AND MRF 40

 PUBLIC WORKS SIGN SHOP 45

 PARK MAINTENANCE FACILITY 48

 GOLF COURSE 54

 FIRE STATION #2 60

 CITY HALL 66

 CENTENNIAL COMMONS RECREATION CENTER..... 71

1.0 LIGHTING IMPROVEMENTS 78

 ECM-1.1: LIGHTING RETROFIT (ANNEX) 78

 ECM-1.2: LIGHTING RETROFIT (CITY HALL) 95

 ECM-1.3: LIGHTING RETROFIT (COMMUNITY CENTER) 108

 ECM-1.4: LIGHTING RETROFIT (FIRE STATION #2) 114

 ECM-1.5: LIGHTING RETROFIT (GOLF COURSE) 122

 ECM-1.6: LIGHTING RETROFIT (PUBLIC WORKS) 127

 ECM-1.7: LIGHTING RETROFIT (RECREATION CENTER) 137

 ECM-1.8: LIGHTING RETROFIT (TRINITY BUILDING) 142

2.0 ENERGY MANAGEMENT SYSTEM / CONTROL IMPROVEMENTS 147

 ECM-2.1: INSTALL PROGRAMMABLE TSTATS & LOCKING COVERS - CENTRAL GARAGE (ASSUMES ECM-4.3 IMPLEMENTED)..... 147

 ECM-2.2: INSTALL PLUG LOAD OCCUPANCY SENSORS - CITY HALL 149

 ECM-2.3: INSTALL PLUG LOAD OCCUPANCY SENSORS - ANNEX 150

4.0 HEATING, VENTILATING, & AIR CONDITIONING IMPROVEMENTS..... 152

 ECM-4.1: UNIT REPLACEMENT – ANNEX 152

 ECM-4.2: PUMP MOTOR REPLACEMENT – HEMAN PARK POOL 154

 ECM-4.3: UNIT REPLACEMENT – CENTRAL GARAGE (ASSUMES ECM-2.1 IMPLEMENTED) 155

APPENDIX A LIGHTING IMPROVEMENTS CALCULATIONS (ANNEX) – ECM-1.1 157

APPENDIX B LIGHTING IMPROVEMENTS CALCULATIONS (CITY HALL) – ECM-1.2 174

APPENDIX C LIGHTING IMPROVEMENTS CALCULATIONS (COMMUNITY CENTER)– ECM-1.3 187

APPENDIX D LIGHTING IMPROVEMENTS CALCULATIONS (FIRE STATION #2)– ECM-1.4 192

APPENDIX E LIGHTING IMPROVEMENTS CALCULATIONS (GOLF COURSE)– ECM-1.5 199



Detailed Energy Study University City Municipal Buildings

| | |
|--|-----|
| APPENDIX F LIGHTING IMPROVEMENTS CALCULATIONS (PUBLIC WORKS)– ECM-1.6 | 205 |
| APPENDIX G LIGHTING IMPROVEMENTS CALCULATIONS (RECREATION CENTER)– ECM-1.7 | 220 |
| APPENDIX H LIGHTING IMPROVEMENTS CALCULATIONS (TRINITY BUILDING)– ECM-1.8..... | 227 |
| APPENDIX I ENERGY MANAGEMENT / CONTROL IMPROVEMENTS– ECM-2..... | 231 |
| APPENDIX J HEATING, VENTILATION, & AIR CONDITIONING IMPROVEMENTS – ECM-4..... | 235 |
| APPENDIX K MECHANICAL INVENTORY | 241 |
| APPENDIX L COST ESTIMATE | 244 |



List of Tables

Table 1 Recommended Space Temperature Setpoints..... 8
Table 2 Savings Summary..... 9
Table 3 Greenhouse Gases and Other Pollutants..... 10
Table 4 Utility Bill Analysis - Annex..... 13
Table 5 Utility Bill Analysis - Trinity Building..... 19
Table 6 Utility Bill Analysis - Heman Park Community Center..... 23
Table 7 Utility Bill Analysis - Heman Park Pool..... 29
Table 8 Utility Bill Analysis - Central Garage..... 33
Table 9 Utility Bill Analysis - Heman Park Tennis Court, Restroom and Pavilion..... 38
Table 10 Utility Bill Analysis - Transfer Station and MRF..... 42
Table 11 Utility Bill Analysis - Public Works Sign Shop..... 46
Table 12 Utility Bill Analysis - Park Maintenance Facility..... 50
Table 13 Utility Bill Analysis - Golf Course..... 56
Table 14 Utility Bill Analysis - Fire Station #2..... 62
Table 15 Utility Bill Analysis - City Hall..... 68
Table 16 Utility Bill Analysis - Centennial Commons Recreation Center..... 73
Table 17 Savings Summary - ECM-1.1 Lighting Retrofit (Annex)..... 78
Table 18 Savings Summary - ECM-1.2 Lighting Retrofit (City Hall)..... 95
Table 19 Savings Summary - ECM 1.3 Lighting Retrofit (Community Center)..... 108
Table 20 Savings Summary - ECM-1.4 Lighting Retrofit (Fire Station #2)..... 114
Table 21 Savings Summary - ECM-1.5 Lighting Retrofit (Golf Course)..... 122
Table 22 Savings Summary - ECM-1.6 Lighting Retrofit (Public Works)..... 127
Table 23 Savings Summary - ECM-1.7 Lighting Retrofit (Recreation Center)..... 137
Table 24 Savings Summary - ECM-1.8 Lighting Retrofit (Trinity Building)..... 142
Table 25 Office Set Point Schedule - Central Garage..... 147
Table 26 Savings Summary - ECM-2.1 Office Setpoint Schedule (Central Garage)..... 147
Table 27 Savings Summary - ECM-2.2 Install Plug Load Occupancy Sensors (City Hall)
..... 149
Table 28 Savings Summary - ECM-2.3 Install Plug Load Occupancy Sensors (Annex). 150
Table 29 Existing HVAC Recommended Replacement Schedule - Annex..... 152
Table 30 Savings Summary - ECM-4.1 Unit Replacement Annex..... 152
Table 31 Savings Summary - ECM-4.2 Pump Motor Replacement (Heman Park Pool). 154
Table 32 Existing HVAC Recommended Replacement Schedule - Central Garage..... 155
Table 33 Savings Summary - ECM-4.3 Existing HVAC Replacement - Central Garage. 155



List of Figures

Figure 1 Electrical Usage Breakdown - Annex 12

Figure 2 Natural Gas Usage Breakdown - Annex 13

Figure 3 Monthly Electrical Consumption - Annex..... 14

Figure 4 Monthly Electrical Demand - Annex 15

Figure 5 Monthly Natural Gas Consumption - Annex 16

Figure 6 Monthly Water Consumption - Annex..... 17

Figure 7 Monthly Water Consumption - Trinity Building 20

Figure 8 Electrical Usage Breakdown - Heman Park Community Center 22

Figure 9 Natural Gas Usage Breakdown - Heman Park Community Center 22

Figure 10 Monthly Electrical Consumption - Heman Park Community Center..... 24

Figure 11 Monthly Natural Gas Consumption - Heman Park Community Center 25

Figure 12 Monthly Water Consumption - Heman Park Community Center..... 26

Figure 13 Natural Gas Usage Breakdown - Heman Park Pool..... 28

Figure 14 Monthly Natural Gas Consumption - Heman Park Pool..... 30

Figure 15 Electrical Usage Breakdown - Central Garage 32

Figure 16 Natural Gas Usage Breakdown - Central Garage 32

Figure 17 Monthly Electrical Consumption - Central Garage..... 34

Figure 18 Monthly Natural Gas Consumption - Central Garage 35

Figure 19 Monthly Water Consumption - Central Garage 36

Figure 20 Electricity Usage Breakdown - Heman Park Tennis Court, Restroom and Pavilion..... 38

Figure 21 Monthly Electrical Consumption - Heman Park Tennis Court, Restroom and Pavilion..... 39

Figure 22 Electricity Usage Breakdown - Transfer Station and MRF..... 41

Figure 23 Natural Gas Usage Breakdown - Transfer Station and MRF 41

Figure 24 Monthly Electrical Consumption - Transfer Station and MRF 43

Figure 25 Monthly Gas Consumption - Transfer Station and MRF 44

Figure 26 Electricity Usage Breakdown - Public Works Sign Shop 46

Figure 27 Monthly Electrical Consumption - Public Works Sign Shop..... 47

Figure 28 Electricity Usage Breakdown - Park Maintenance Facility..... 49

Figure 29 Natural Gas Usage Breakdown - Park Maintenance Facility 49

Figure 30 Monthly Electricity Consumption - Park Maintenance Facility 51

Figure 31 Monthly Natural Gas Consumption - Park Maintenance Facility 52

Figure 32 Monthly Water Consumption - Park Maintenance Facility 53

Figure 33 Electricity Usage Breakdown - Golf Course 55

Figure 34 Natural Gas Consumption - Golf Course..... 56

Figure 35 Monthly Electrical Consumption - Golf Course 57

Figure 36 Monthly Natural Gas Consumption - Golf Course 58

Figure 37 Monthly Water Consumption - Golf Course..... 59

Figure 38 Electricity Usage Breakdown - Fire Station #2 61

Figure 39 Natural Gas Usage Breakdown - Fire Station #2 61

Figure 40 Monthly Electrical Consumption - Fire Station #2..... 63

Figure 41 Monthly Natural Gas Consumption - Fire Station #2 64

Figure 42 Monthly Water Consumption - Fire Station #2..... 65

Figure 43 Electricity Usage Breakdown - City Hall 67

Figure 44 Monthly Electrical Consumption - City Hall..... 69



Detailed Energy Study University City Municipal Buildings

| | |
|--|----|
| Figure 45 Monthly Electrical Demand - City Hall | 70 |
| Figure 46 Electricity Usage Breakdown - Centennial Commons Recreation Center..... | 72 |
| Figure 47 Natural Gas Usage Breakdown - Centennial Commons Recreation Center..... | 72 |
| Figure 48 Monthly Electrical Consumption - Centennial Commons Recreation Center | 74 |
| Figure 49 Monthly Electrical Demand - Centennial Commons Recreation Center..... | 75 |
| Figure 50 Monthly Natural Gas Consumption - Centennial Commons Recreation Center | 76 |
| Figure 51 Monthly Water Consumption - Centennial Commons Recreation Center | 77 |



EXECUTIVE SUMMARY

The purpose of this energy study is to provide the city with energy conservation measures (ECMs) to reduce energy use in their municipal buildings. Allen & Hoshall performed an on-site audit in September of 2011 to determine potential recommendations for reducing energy and water consumption at the following facilities:

- Annex (Police/Fire/Print Shop)
- Trinity Building
- Heman Park Community Center
- Heman Park Pool
- Central Garage
- Heman Park Tennis Court, Restroom and Pavilion
- Transfer Station and MRF
- Public Works Sign Shop
- Park Maintenance Facility
- Golf Club House
- Golf Maintenance Facility
- Golf Range Shack
- Fire House #2
- City Hall
- Centennial Commons Recreation Center

The report includes existing condition descriptions, utility bill analysis, ECM descriptions, energy savings, implementation costs, and description and cost estimate of measurement and verification for the proposed ECMs. Each ECM description will summarize the existing conditions related to the recommended ECM. The ECM description will also provide information regarding what is required for implementation. The appendix includes ECM calculations and other support information. Detailed ECM calculations include electrical consumption, electrical demand, natural gas consumptions, water consumption, and system maintenance savings where appropriate.

The energy conservation measures were separated into five categories: Lighting, HVAC controls, Water Conservation Improvements, HVAC Improvements, and Architectural Improvements. This report identifies ECM's in all categories except Water Conservation and Architectural. Water Conservation improvements are not feasible due to a large percentage of existing fixtures being low consumption and many of the buildings having to high of a fixture to occupant ratio. Architecturally the buildings that are fully conditioned were reasonably well insulated and the existing windows were double pane. Lighting ECMs included lighting fixture replacements, lighting fixture retrofits, and lighting system automated controls. Energy Management ECMs consisted of installing programmable thermostats in the Central Garage and installing plug load occupancy sensors in the City Hall and Annex. HVAC Improvements ECMs included replacement of inefficient HVAC equipment with high efficiency type equipment and the replacement of energy inefficient motors. The projected energy savings for all ECMs are shown in the Saving Summary of the report.



Utility bills were provided by the city for 2010 and 2011. The utility usage for 2010 was analyzed with information gained from the site visit to estimate the percentage of the utility bills serving different uses. Graphs of electrical consumption, electrical demand, natural gas consumption, and water consumption are also provided to represent how the utility bills vary throughout the year. The utility bills for 2011 were omitted from this information as the year is not yet complete and having a partial year would skew the findings. This information can be found in each facility description.

There are three recommendations that do not require any renovation work and therefore are not given a separate ECM. The first is to install a city policy to regulate space temperature setpoints for municipal buildings. This would help reduce energy use in buildings where more sophisticated control systems would not be economically feasible and would not require any capital expenditures. See Table 1 Recommended Space Temperature Setpoints below.

| Recommended Space Temp. Set Points | | | | |
|------------------------------------|---------|--------|---------|--------|
| Mode | Cooling | | Heating | |
| Occupancy | Occ. | Unocc. | Occ. | Unocc. |
| Office | 74°F | 80°F | 70°F | 60°F |
| Shops | - | - | 65°F | 55°F |

Table 1 Recommended Space Temperature Setpoints

The second recommendation is for the city to track the utility usage for each building. The current usage should be compared to the previous year's usage as well as a five year average usage. This would allow the city to notice any significant changes in usage and allow an investigation to be performed in an effort to control and minimize utility usage.

The third recommendation would be to investigate obtaining LEED Existing Buildings: Operations & Maintenance certification. This certification involves chemical use, recycling, maintenance, and system upgrades. This would assure the building is operated efficiently, maintains an excellent working conditions, and minimize the buildings negative impacts on the environment. The most applicable buildings are City Hall, Annex, Fire Station #2, and the Centennial Commons Recreation Center. Allen & Hoshall is capable of assisting with the city with assessing the modifications that would be necessary and the process of applying for LEED certifications.

INCENTIVES SUMMARY

When it comes to energy saving measures in the current economic and political climate, many utilities and government organizations offer incentives to encourage businesses to implement more efficient building systems. These incentives typically come in the form of tax deductions, tax refunds, or up-front funds to offset initial capital costs. As part of this study, potential candidates that could potentially provide incentives were explored.

University City's electric utility is Ameren Missouri. Their Energy Efficiency Incentive Programs closed on August 31, 2011. Future incentives from Ameren Missouri are uncertain. It is suggested to subscribe to their monthly electronic newsletter (<http://www.ameren.com/sites/aeu/Pages/home.aspx>) for updates.



Detailed Energy Study University City Municipal Buildings

The Missouri Department of Natural Resources Division of Energy has an Energy Revolving Fund providing low-interest loans to governments for energy efficiency improvements. However, their offerings for 2011 have not been released. Nor is there any information available for 2012.

The Department of Energy currently offers a tax deduction incentive program known as the CBTD (Commerical Buildings Tax Deduction), which was created by the Energy Policy Act of 2005. In order to receive this deduction, a certified individual (professional engineer) will survey the building and determine the current lighting power density (LPD). The lighting power density is the sum of all fixture loads divided by the building square footage. This power density is compared to the ASHRAE 2001 90.1 guidelines concerning lighting power densities for different facility types. If the building's calculated LPD is 25-40% below the ASHRAE 90.1 standard, then the building is eligible for a tax deduction that ranges from \$0.30-\$0.60/sq.ft. This incentive requires that the lighting project be completed by January, 1 2014. Based on the data gathered from this report, the Annex, City Hall, Golf Course Pro Shop & Maintenance Facility, and the Central Garage are all potential candidates. However, all of the buildings listed that are government owned and that do not pay taxes will not receive the deduction. Instead, the principle designer of the lighting system will be eligible for the deduction.

SAVINGS SUMMARY

| University City | Energy Consumption Savings | | | | | Energy Cost Savings | | | | Total Energy Savings | Avoided Maint. Savings | Capital Cost | SPB | |
|-----------------|---|----------------|-----------|------------|------------|---------------------|-----------------|----------|----------|----------------------|------------------------|--------------|------------------|-------------|
| | KWh | KW | Months | Steam klbs | Water kgal | KWh | KW | Steam | Water | | | | | |
| ECM-1.1 | Lighting Retrofit (Annex) | 58,934 | 17 | 12 | - | - | \$4,037 | \$0 | \$0 | \$0 | \$4,037 | \$0 | \$64,736 | 16.0 |
| ECM-1.2 | Lighting Retrofit (City Hall) | 12,081 | 6 | 12 | - | - | \$828 | \$0 | \$0 | \$0 | \$828 | \$0 | \$21,723 | 23.5 |
| ECM-1.3 | Lighting Retrofit (Community Center) | 5,502 | 4 | 12 | - | - | \$377 | \$0 | \$0 | \$0 | \$377 | \$0 | \$2,249 | 5.3 |
| ECM-1.4 | Lighting Retrofit (Fire Station #2) | 5,448 | - | 12 | - | - | \$373 | \$0 | \$0 | \$0 | \$373 | \$0 | \$5,829 | 14.4 |
| ECM-1.5 | Lighting Retrofit (Golf Course) | 1,277 | 1 | 12 | - | - | \$87 | \$0 | \$0 | \$0 | \$87 | \$0 | \$1,847 | 18.5 |
| ECM-1.6 | Lighting Retrofit (Public Works) | 39,387 | 9 | 12 | - | - | \$2,698 | \$0 | \$0 | \$0 | \$2,698 | \$0 | \$31,692 | 8.8 |
| ECM-1.7 | Lighting Retrofit (Recreation Center) | 27,897 | 12 | 12 | - | - | \$1,911 | \$0 | \$0 | \$0 | \$1,911 | \$0 | \$42,681 | 20.8 |
| ECM-1.8 | Lighting Retrofit (Trinity Building) | 1,226 | 6 | 12 | - | - | \$84 | \$0 | \$0 | \$0 | \$84 | \$0 | \$9,371 | 111.6 |
| ECM-2.1 | Install Programable T-stats Central Garage | 27,671 | 3 | 12 | - | - | \$1,895 | \$0 | \$0 | \$0 | \$1,895 | \$0 | \$227 | 0.1 |
| ECM-2.2 | Install Plug Load Occupancy Sensors City Hall | 16,527 | 0 | - | - | - | \$1,132 | \$0 | \$0 | \$0 | \$1,132 | \$0 | \$8,081 | 7.6 |
| ECM-2.3 | Install Plug Load Occupancy Sensors Annex | 19,016 | 0 | - | - | - | \$1,303 | \$0 | \$0 | \$0 | \$1,303 | \$0 | \$11,019 | 9.7 |
| ECM-4.1 | Unit Replacement Annex | 55,706 | 11 | 12 | - | 2,173 | \$3,816 | \$0 | \$0 | \$7,040 | \$10,856 | \$0 | \$101,983 | 9.5 |
| ECM-4.2 | Pump Motor Replacement Heman Park Pool | 15,709 | 5 | 4 | - | - | \$1,076 | \$0 | \$0 | \$0 | \$1,076 | \$0 | \$5,845 | 5.4 |
| ECM-4.3 | Unit Replacement Central Garage | 23,643 | 8 | 12 | - | - | \$1,620 | \$0 | \$0 | \$0 | \$1,620 | \$903 | \$19,718 | 7.8 |
| TOTAL | | 310,022 | 81 | 12 | - | - | \$21,237 | - | - | - | \$28,276 | \$903 | \$327,002 | 11.2 |

Table 2 Savings Summary

MEASUREMENT AND VERIFICATION SUMMARY

Measurement and Verification (M&V) for this project should be based upon the guidelines developed by the Department of Energy Federal Energy Management Program (FEMP). The FEMP M&V Guidelines outlines four different processes (Option A,B,C,D) that can be utilized to develop a M&V procedure. The type of process selected depends upon the ECM type and current available metering information. Due to the size of this project it is recommended that the cost of M&V be kept to a minimum.

The lighting ECM's will have a baseline and post-project energy usage calculated based upon the actual measurement process based on Option A. The calculated energy savings



of the M&V process will be compared to the estimated energy savings in the audit for both electrical demand (kW) and consumption (kWh).

The control ECMs should not be subject to M&V directly. The thermostat ECMs will be measured in conjunction with the unit replacement. M&V is not applicable to the plug load occupancy sensors.

The unit replacement ECMs will have a baseline and post-project energy usage calculated based upon the actual measurement process based on Option B. The calculated energy savings of the M&V process will be compared to the estimated energy savings in the audit for both electrical demand (kW) and consumption (kWh). The pump motor replacement at Heman Park Pool should not be subject to M&V as the only variable is the operation hours of the pool which are not subject to modification.

The semi-annual M&V report summary will include the proposed and actual kW savings, kWh savings, and energy cost savings for each ECM. The report will also include corrective actions that need to be taken to maximize savings. The M&V period should be 1 year. The cost for M&V is generally in a range of 3% to 6% of the construction costs. However, if a limited number of ECMs is implemented the costs on a percentage base can increase significantly.

ENVIRONMENTAL IMPACT

Along with the energy savings, 423,588 lbs of Greenhouse gases and other pollutants will be averted. For a complete breakdown see Table 3 Greenhouse Gases and Other Pollutants below.

| Greenhouse Gasses and Other Pollutants | | | | | | | | | | |
|--|-------------------------------------|------------------------------------|-----------------------------------|-------------------|----------|----------|-----------------------------------|----------------------------------|----------------------|---------|
| Annual Electricity Saved (kWh): | 310,022 | | | | | | | | | |
| Pollutant: | CO ₂ * | NO _x * | SO ₂ * | Hg* | PM10* | PM2.5 | VOC | CO | Sub-total (Electric) | |
| Emission Factor (lb/kWh): | 1.333 | 0.002258 | 0.005852 | 3.01E-08 | 0.024799 | 0.000139 | 0.000022 | 0.000147 | | |
| Lbs of Pollutant Saved: | 413,260 | 700 | 1,814 | 0.01 | 7,688 | 43 | 7 | 46 | 423,558 | |
| Pollutant: | Greenhouse Gases (CO ₂) | Nitrogen Oxides (NO _x) | Sulfur Dioxide (SO ₂) | Toxic Metals (Hg) | PM10 | PM2.5 | Nitrous Oxides (N ₂ O) | Volatile Organic Compounds (VOC) | Carbon Monoxide (CO) | Total |
| Total Lbs of Pollutant Saved: | 413,261 | 700 | 1,814 | 0 | 7,688 | 0 | 43 | 7 | 46 | 423,558 |

Table 3 Greenhouse Gases and Other Pollutants

FACILITY DESCRIPTIONS

Annex

Building Description



This facility is a three story building originally built in 1903 located at 6801 Delmar Blvd. It is approximately 49,000 ft² and has received various renovations over the years. It currently houses the Police Station, Fire House, and Print Shop. The majority of this building is in operation 24-7 and has approximately 141 full time staff.

HVAC Description

The Annex is served by multiple types of mechanical systems. The Police Dispatch, Detectives Offices, and Fire Bunks are served by rooftop units. The Police Dispatch unit newer unit with electric heat. The Fire Bunks unit is also a newer unit but has gas heat. The unit serving the Detectives Office is an older unit and also has gas heat.

There are also several split system units that serve the Office, Fire Chief/Kitchen, Fire Office/EOC, Police Offices, Locker Rooms, and Service Support. All of the units have steam heating coils with the exception of the units serving the Locker Rooms and Service Support, which have gas heat. Also on the steam system are three heaters serving the fire truck bay. Steam is provided from the adjacent Trinity Building.

The Server Room, Telephone Room, and Basement Jail Cells are served by Water-Source units. The water for these units are provided directly from the domestic water service then passes through the unit to the sewer. This causes a large amount of fresh water usage.

Utility Summary

Utility Usage Breakdown

Estimated Electric Consumption

| | |
|-------------------|------|
| Lights: | 20% |
| Miscellaneous: | 22% |
| AHU Fans & Pumps: | 15% |
| Cooling: | 42% |
| <hr/> Totals: | 100% |

Estimated Natural Gas Consumption

| | |
|-----------------|------|
| Heating: | 59% |
| Domestic water: | 41% |
| <hr/> Totals: | 100% |

The total utility cost for the Annex in 2010 was \$82,565.02 . It should be noted that a portion of the heat for this building comes from the steam boilers in the adjacent Trinity building and the Annex provides the City Hall with hot water. The breakdown for each item was calculated based upon the existing equipment and the operating hours from facility personnel.




Figure 1 Electrical Usage Breakdown - Annex



Detailed Energy Study University City Municipal Buildings




Figure 2 Natural Gas Usage Breakdown - Annex

| Utility Bill Analysis For ANNEX (Police / Fire / Print Shop) | | | | | | | | | | | | | | |
|--|-------------------------|------------------|------------------------------|--------------------|-------------------------|-------------------------|-------------------------|------------------|----------------------|-------------------|-------------|------------|------|-----|
| Period End | Electricity Consumption | Electricity Cost | Electricity Consumption Rate | Electricity Demand | Electricity Demand Cost | Electricity Demand Rate | Natural Gas Consumption | Natural Gas Cost | Gas Consumption Rate | Water Consumption | Water Cost | Water Rate | HDD | CDD |
| | (kWh) | (\$) | (\$/kWh) | (kW) | (\$) | (\$/kW) | (CCF) | (\$) | (\$/ccf) | (Gal.) | (\$) | (\$/kGal) | | |
| January-10 | 45,360 | \$ 1,761.90 | \$ 0.03884 | 100 | \$ 140.00 | \$ 1.40 | 7236 | \$ 5,540.14 | \$ 0.77 | 546,750 | \$ 1,518.87 | \$ 2.78 | 1009 | 0 |
| February-10 | 40,080 | \$ 1,595.98 | \$ 0.03982 | 100 | \$ 140.00 | \$ 1.40 | 6537 | \$ 5,027.73 | \$ 0.77 | 546,750 | \$ 1,518.87 | \$ 2.78 | 820 | 0 |
| March-10 | 40,800 | \$ 1,642.80 | \$ 0.04026 | 100 | \$ 140.00 | \$ 1.40 | 4678 | \$ 3,677.88 | \$ 0.79 | 457,250 | \$ 1,841.13 | \$ 4.03 | 350 | 15 |
| April-10 | 48,720 | \$ 1,656.77 | \$ 0.03401 | 144 | \$ 201.60 | \$ 1.40 | 2544 | \$ 2,135.04 | \$ 0.84 | 457,250 | \$ 1,841.13 | \$ 4.03 | 39 | 166 |
| May-10 | 49,680 | \$ 3,275.53 | \$ 0.06593 | 124 | \$ 469.85 | \$ 3.79 | 464 | \$ 429.78 | \$ 0.93 | 457,250 | \$ 1,841.13 | \$ 4.03 | 20 | 277 |
| June-10 | 75,120 | \$ 4,547.34 | \$ 0.06053 | 136 | \$ 527.82 | \$ 3.87 | 101 | \$ 137.45 | \$ 1.36 | 588,500 | \$ 1,756.08 | \$ 2.98 | 0 | 623 |
| July-10 | 73,200 | \$ 4,809.37 | \$ 0.06570 | 138 | \$ 573.53 | \$ 4.15 | 92 | \$ 130.40 | \$ 1.42 | 588,500 | \$ 1,756.08 | \$ 2.98 | 0 | 706 |
| August-10 | 70,800 | \$ 4,796.76 | \$ 0.06775 | 147 | \$ 609.64 | \$ 4.15 | 66 | \$ 110.00 | \$ 1.67 | 588,500 | \$ 1,756.08 | \$ 2.98 | 0 | 695 |
| September-10 | 64,080 | \$ 2,764.54 | \$ 0.04314 | 128 | \$ 196.66 | \$ 1.54 | 87 | \$ 131.03 | \$ 1.51 | 674,750 | \$ 2,152.45 | \$ 3.19 | 4 | 353 |
| October-10 | 45,600 | \$ 2,052.59 | \$ 0.04501 | 107 | \$ 164.78 | \$ 1.54 | 91 | \$ 138.13 | \$ 1.52 | 674,750 | \$ 2,152.45 | \$ 3.19 | 66 | 132 |
| November-10 | 48,720 | \$ 2,080.77 | \$ 0.04271 | 100 | \$ 154.00 | \$ 1.54 | 2307 | \$ 1,980.64 | \$ 0.86 | 674,750 | \$ 2,152.45 | \$ 3.19 | 336 | 9 |
| December-10 | 45,600 | \$ 1,943.62 | \$ 0.04262 | 100 | \$ 154.00 | \$ 1.54 | 5762 | \$ 4,443.29 | \$ 0.77 | 626,000 | \$ 1,996.94 | \$ 3.19 | 912 | 0 |
| Totals: | 647,760 | \$32,927.97 | \$ 0.05083 | 1,424 | \$3,471.88 | \$ 2.44 | 29,965 | \$ 23,881.51 | \$ 0.80 | 6,881,000 | \$22,283.66 | \$ 3.24 | | |

Electric Consumption Rate: \$0.05083 /kWh
 Electric Demand Rate: \$2.44 /kW
 Natural Gas Consumption Rate: \$0.80 /ccf

Annual Cost/Sq.ft - Electricity: \$0.743 /sqft
 Annual Cost/Sq.ft - Gas.: \$0.487 /sqft
 Annual Cost/Sq.ft - Total: \$1.230 /sqft

Table 4 Utility Bill Analysis - Annex




Figure 3 Monthly Electrical Consumption - Annex

Figure 3 Monthly Electrical Consumption - Annex details the electrical consumption and each month's corresponding heating and cooling degree days. Cooling degree days (CDD) are a measure of the severity of the cooling requirements in a given locality; the more cooling degree days, the hotter the summer. Based on the graph, the electrical consumption peaks in June and the cooling degree days peak in July. This slight discrepancy could be due the timing of the electric billing cycle.




Figure 4 Monthly Electrical Demand - Annex

Figure 4 Monthly Electrical Demand - Annex suggests the same conclusions as the electric consumption graph. The peak months correspond to the higher cooling load required during the summer season.




Figure 5 Monthly Natural Gas Consumption - Annex

Figure 5 Monthly Natural Gas Consumption - Annex details the natural gas consumption and each month’s corresponding heating degree days. Heating degree days (HDD) are a measure of the severity of the heating requirements in a given locality; the more heating degree days, the cooler the winter. Based on the graph, the gas consumption and the heating degree days peak in January.




Figure 6 Monthly Water Consumption - Annex

Figure 6 Monthly Water Consumption - Annex details the water consumption. The water consumption is relatively flat due to the limited use of water for HVAC systems. Where water is used for HVAC systems it is used for computer room type areas that require cooling much of the year and is not as dependant on weather.

Trinity Building



Building Description

This building is a three story building of approximately 16,000 ft² built in 1939 as a library. This building is unoccupied a majority of the year. Much of the space is storage, a few small offices that are used for fair planning. When it is occupied its hours are 8am-5pm Monday through Friday and there are only a few employees.

HVAC Description

Cooling is provided by several window air-conditioners. During the audit the building was empty and was being kept warmer than an occupied building would normally be. Even with minimal conditioning humidity did not appear to be a problem. Heat was provided by steam radiators along the exterior of the building.

Two seven year old steam boilers are located in the basement and each have a capacity of 2,650 lbs/hr. These boilers provide steam to the Trinity building as well as the adjacent City Hall and Annex buildings. At the time of the audit the boilers were open awaiting yearly state inspection. The boilers were in excellent condition. It should be noted that the entire steam distribution system in all three buildings was in excellent shape. It would be difficult to find system losses while the system is not operational, however the system appeared to be well maintained and any significant system losses would not be expected.



Utility Summary

Electrical and gas bills were not available for the Trinity Building. The total utility cost for water at the Trinity Building in 2010 was \$886.48 for the past 12 months.

| Utility Bill Analysis For Trinity Building | | | | | |
|---|-------------------|------------|------------|------|-----|
| Period End | Water Consumption | Water Cost | Water Rate | HDD | CDD |
| | (Gal.) | (\$) | (\$/kGal) | | |
| January-10 | 0 | \$ - | \$ - | 1009 | 0 |
| February-10 | 0 | \$ - | \$ - | 820 | 0 |
| March-10 | 36,000 | \$ 100.01 | \$ 2.78 | 350 | 15 |
| April-10 | 36,000 | \$ 100.01 | \$ 2.78 | 39 | 166 |
| May-10 | 36,000 | \$ 100.01 | \$ 2.78 | 20 | 277 |
| June-10 | 26,500 | \$ 79.85 | \$ 3.01 | 0 | 623 |
| July-10 | 26,500 | \$ 79.85 | \$ 3.01 | 0 | 706 |
| August-10 | 26,500 | \$ 79.85 | \$ 3.01 | 0 | 695 |
| September-10 | 30,750 | \$ 98.09 | \$ 3.19 | 4 | 353 |
| October-10 | 30,750 | \$ 98.09 | \$ 3.19 | 66 | 132 |
| November-10 | 30,750 | \$ 98.09 | \$ 3.19 | 336 | 9 |
| December-10 | 16,500 | \$ 52.64 | \$ 3.19 | 912 | 0 |
| Totals: | 296,250 | \$ 886.48 | \$ 2.99 | | |

Table 5 Utility Bill Analysis - Trinity Building




Figure 7 Monthly Water Consumption - Trinity Building

Figure 7 Monthly Water Consumption - Trinity Building details the water consumption. The water consumption is relatively flat due to no usage of water for HVAC systems. The fluctuations are attributed entirely to building occupancy.

Heman Park Community Center



Building Description

This building is a one story 9,100 square foot facility originally built in 1958. There is one office off the main entry room with the rest of the building divided into two large multi-purpose rooms. Each of which has a kitchen. The building is currently used 8am-5pm Monday through Thursday and as reserved Friday through Sunday. There is one full-time employee and an estimated thirty senior citizens occupying one of the multi-purpose rooms on the day of the audit. There was some uncertainty about the future use of the building as moving the senior citizens to another location.

HVAC Description

The building is conditioned by two packaged units with gas heat located on grade at the rear of the building in a fenced enclosure. There is also one split system to supplement the packaged units cooling capabilities.

Utility Summary

Utility Usage Breakdown

Estimated Electric Consumption

| | |
|-------------------|-------------|
| Lights: | 15% |
| Miscellaneous: | 6% |
| AHU Fans & Pumps: | 31% |
| Cooling: | 48% |
| Totals: | 100% |

Estimated Natural Gas Consumption

| | |
|-----------------|-------------|
| Heating: | 89% |
| Domestic water: | 11% |
| Totals: | 100% |

The total utility cost for the Heman Park Community Center in 2010 was \$19,663.78. The breakdown for each item was calculated based upon the existing equipment and the operating hours from facility personnel.




Figure 8 Electrical Usage Breakdown - Heman Park Community Center




Figure 9 Natural Gas Usage Breakdown - Heman Park Community Center



Detailed Energy Study University City Municipal Buildings

| Utility Bill Analysis For Heman Park Community Center | | | | | | | | | | | |
|---|-------------------------|------------------|------------------------------|-------------------------|------------------|----------------------|-------------------|------------|------------|------|-----|
| Period End | Electricity Consumption | Electricity Cost | Electricity Consumption Rate | Natural Gas Consumption | Natural Gas Cost | Gas Consumption Rate | Water Consumption | Water Cost | Water Rate | HDD | CDD |
| | (kWh) | (\$) | (\$/kWh) | (CCF) | (\$) | (\$/ccf) | (Gal.) | (\$) | \$/kGal | | |
| January-10 | 9,610 | \$ 588.13 | \$ 0.06120 | 1,682 | \$ 1,451.85 | \$ 0.86 | 16,000 | \$ 44.45 | \$ 2.78 | 1009 | 0 |
| February-10 | 10,560 | \$ 646.27 | \$ 0.06120 | 1,343 | \$ 1,203.49 | \$ 0.90 | 16,000 | \$ 44.45 | \$ 2.78 | 820 | 0 |
| March-10 | 8,230 | \$ 503.68 | \$ 0.06120 | 813 | \$ 817.02 | \$ 1.00 | 12,750 | \$ 35.41 | \$ 2.78 | 350 | 15 |
| April-10 | 10,090 | \$ 617.51 | \$ 0.06120 | 225 | \$ 287.22 | \$ 1.28 | 12,750 | \$ 35.41 | \$ 2.78 | 39 | 166 |
| May-10 | 11,240 | \$ 922.80 | \$ 0.08210 | 103 | \$ 117.95 | \$ 1.15 | 12,750 | \$ 35.41 | \$ 2.78 | 20 | 277 |
| June-10 | 25,350 | \$ 2,136.13 | \$ 0.08427 | 99 | \$ 114.62 | \$ 1.16 | 20,750 | \$ 61.92 | \$ 2.98 | 0 | 623 |
| July-10 | 22,780 | \$ 2,095.76 | \$ 0.09200 | 86 | \$ 104.30 | \$ 1.21 | 20,750 | \$ 61.92 | \$ 2.98 | 0 | 706 |
| August-10 | 22,470 | \$ 2,067.24 | \$ 0.09200 | 79 | \$ 98.67 | \$ 1.25 | 20,750 | \$ 61.92 | \$ 2.98 | 0 | 695 |
| September-10 | 17,700 | \$ 1,076.92 | \$ 0.06084 | 84 | \$ 106.58 | \$ 1.27 | 19,500 | \$ 62.21 | \$ 3.19 | 4 | 353 |
| October-10 | 10,100 | \$ 748.14 | \$ 0.07407 | 134 | \$ 150.12 | \$ 1.12 | 19,500 | \$ 62.21 | \$ 3.19 | 66 | 132 |
| November-10 | 8,560 | \$ 637.16 | \$ 0.07443 | 457 | \$ 571.06 | \$ 1.25 | 19,500 | \$ 62.21 | \$ 3.19 | 336 | 9 |
| December-10 | 10,230 | \$ 753.77 | \$ 0.07368 | 1,358 | \$ 1,231.22 | \$ 0.91 | 15,250 | \$ 48.65 | \$ 3.19 | 912 | 0 |
| Totals: | 166,920 | \$ 12,793.51 | \$ 0.07664 | 6,463 | \$ 6,254.10 | \$ 0.97 | 206,250 | \$ 616.17 | \$ 2.99 | | |

Electric Consumption Rate: \$0.07664 /kWh
 Natural Gas Consumption Rate: \$0.97 /ccf

Annual Cost/Sq.ft - Electricity: \$1.406 /sqft
 Annual Cost/Sq.ft - Gas.: \$0.687 /sqft
 Annual Cost/Sq.ft - Total: \$2.093 /sqft

Table 6 Utility Bill Analysis - Heman Park Community Center




Figure 10 Monthly Electrical Consumption - Heman Park Community Center

Figure 10 Monthly Electrical Consumption - Heman Park Community Center details the electrical consumption and each month’s corresponding heating and cooling degree days. Cooling degree days (CDD) are a measure of the severity of the cooling requirements in a given locality; the more cooling degree days, the hotter the summer. Based on the graph, the electrical consumption peaks in June and the cooling degree days peak in July. This slight discrepancy could be due the timing of the electric billing cycle.

2010 Monthly Natural Gas Consumption




Figure 11 Monthly Natural Gas Consumption - Heman Park Community Center

Figure 11 Monthly Natural Gas Consumption - Heman Park Community Center details the natural gas consumption and each month's corresponding heating degree days. Heating degree days (HDD) are a measure of the severity of the heating requirements in a given locality; the more heating degree days, the cooler the winter. Based on the graph, the gas consumption and the heating degree days peak in January. The baseline consumption comes from the gas water heater and the pilot lights on the stoves. It is our understanding that the stoves are used very infrequently. Money could be saved if it is feasible to shut off these pilot lights.




Figure 12 Monthly Water Consumption - Heman Park Community Center

Figure 12 Monthly Water Consumption - Heman Park Community Center details the water consumption. Water Consumption at Heman Park Community Center varies entirely with occupant usage as no water is used for HVAC.

Heman Park Pool



Building Description

This pool facility is 2,800 ft² and was built in 1933. The building consists of equipment rooms for the filtration equipment, a large breezeway, locker room for the lifeguards, and a small office. Outside are two pools, on large main pool and a smaller kiddies' pool. There are approximately ten employees during the swim season which runs from late May to early September and is open from 6am through 8 pm.

HVAC Description

The only conditioned space is the small office. It has one small window air-conditioner.

Utility Summary

Utility Usage Breakdown

Estimated Natural Gas Consumption

| | |
|-----------------|-------------|
| Heating: | 0% |
| Domestic water: | 100% |
| Totals: | 100% |

Overall, the total utility cost for the Heman Park Pool is \$473.42 for the past 12 months. The breakdown for each item was calculated based upon the existing equipment and the operating hours from facility personnel. Electric and water bills were not available. It appears that these are combined with the adjacent Centennial Commons.




Figure 13 Natural Gas Usage Breakdown - Heman Park Pool



| Utility Bill Analysis For Heman Park Pool | | | | | |
|---|-------------------------|------------------|----------------------|------|-----|
| Period End | Natural Gas Consumption | Natural Gas Cost | Gas Consumption Rate | HDD | CDD |
| | (CCF) | (\$) | (\$/ccf) | | |
| January-10 | 0 | \$ 21.54 | \$ - | 1009 | 0 |
| February-10 | 0 | \$ 21.54 | \$ - | 820 | 0 |
| March-10 | 0 | \$ 21.54 | \$ - | 350 | 15 |
| April-10 | 0 | \$ 21.81 | \$ - | 39 | 166 |
| May-10 | 1 | \$ 22.79 | \$ 22.79 | 20 | 277 |
| June-10 | 59 | \$ 69.32 | \$ 1.17 | 0 | 623 |
| July-10 | 69 | \$ 77.27 | \$ 1.12 | 0 | 706 |
| August-10 | 41 | \$ 55.14 | \$ 1.34 | 0 | 695 |
| September-10 | 41 | \$ 56.78 | \$ 1.38 | 4 | 353 |
| October-10 | 16 | \$ 38.39 | \$ 2.40 | 66 | 132 |
| November-10 | 13 | \$ 41.80 | \$ 3.22 | 336 | 9 |
| December-10 | 0 | \$ 25.50 | \$ - | 912 | 0 |
| Totals: | 240 | \$ 473.42 | \$ 1.97 | | |

Natural Gas Consumption Rate: \$ 1.97 /ccf

Annual Cost/Sq.ft - Gas.: \$ 0.17 /sqft

Annual Cost/Sq.ft - Total: \$ 0.17 /sqft

Table 7 Utility Bill Analysis - Heman Park Pool




Figure 14 Monthly Natural Gas Consumption - Heman Park Pool

Figure 14 Monthly Natural Gas Consumption - Heman Park Pool details the natural gas consumption and each month’s corresponding heating degree days. Heating degree days (HDD) are a measure of the severity of the heating requirements in a given locality; the more heating degree days, the cooler the winter. Based on the graph, the gas usage peaks during the summer when the pool is in use, and drops off in the winter. This is due to hot water usage and the lack of heated space.

Central Garage



Building Description

The Central Garage is the vehicle maintenance facility for city vehicles, is 14,000 ft² and was built in 1970. The main office at the front of the building is approximately 620 ft². There is also an office and break room in the shop that is approximately 460 ft². The remainder of the building is shop space. There are six full time employees and the operating hours are 6:30am-5pm Monday through Friday and 8am-Noon on Saturday.

HVAC Description

The main office and the office in the shop are conditioned by a 2.5-ton and a 3-ton split systems, respectively. The condensing unit for the main office has been replaced but the indoor unit was not. Staff reported continuing maintenance issues with this unit and the offices it served were being conditioned by window air conditioners. The shop area was heated by both gas fired low-intensity infrared heaters and gas fired unit heaters.

Utility Summary

Utility Usage Breakdown

Estimated Electric Consumption

| | |
|-------------------|-------------|
| Lights: | 40% |
| Miscellaneous: | 37% |
| AHU Fans & Pumps: | 5% |
| Cooling: | 18% |
| Totals: | 100% |

Estimated Natural Gas Consumption

| | |
|-----------------|-------------|
| Heating: | 83% |
| Domestic water: | 17% |
| Totals: | 100% |

Overall, the total utility cost for the Central Garage is \$20,335.03 for the past 12 months. The breakdown for each item was calculated based upon the existing equipment and the operating hours from facility personnel.




Figure 15 Electrical Usage Breakdown - Central Garage




Figure 16 Natural Gas Usage Breakdown - Central Garage



Detailed Energy Study University City Municipal Buildings

| Utility Bill Analysis For Central Garage | | | | | | | | | | | |
|--|-------------------------|------------------|------------------------------|-------------------------|------------------|----------------------|-------------------|------------|------------|------|-----|
| Period End | Electricity Consumption | Electricity Cost | Electricity Consumption Rate | Natural Gas Consumption | Natural Gas Cost | Gas Consumption Rate | Water Consumption | Water Cost | Water Rate | HDD | CDD |
| | (kWh) | (\$) | (\$/kWh) | (CCF) | (\$) | (\$/ccf) | (Gal.) | (\$) | | | |
| January-10 | 5,734 | \$ 288.50 | \$ 0.05031 | 6,048 | \$ 4,638.71 | \$ 0.77 | 14,750 | \$40.98 | \$2.78 | 1009 | 0 |
| February-10 | 5,672 | \$ 286.31 | \$ 0.05048 | 5,360 | \$ 4,132.70 | \$ 0.77 | 14,750 | \$40.98 | \$2.78 | 820 | 0 |
| March-10 | 3,472 | \$ 208.43 | \$ 0.06003 | 3,677 | \$ 2,905.41 | \$ 0.79 | 15,000 | \$41.67 | \$2.78 | 350 | 15 |
| April-10 | 2,518 | \$ 170.81 | \$ 0.06784 | 893 | \$ 878.30 | \$ 0.98 | 15,000 | \$41.67 | \$2.78 | 39 | 166 |
| May-10 | 2,050 | \$ 185.02 | \$ 0.09025 | 77 | \$ 97.08 | \$ 1.26 | 15,000 | \$41.67 | \$2.78 | 20 | 277 |
| June-10 | 2,913 | \$ 262.59 | \$ 0.09014 | 23 | \$ 53.51 | \$ 2.33 | 14,750 | \$44.01 | \$2.98 | 0 | 623 |
| July-10 | 2,804 | \$ 276.58 | \$ 0.09864 | 19 | \$ 50.33 | \$ 2.65 | 14,750 | \$44.01 | \$2.98 | 0 | 706 |
| August-10 | 2,744 | \$ 271.06 | \$ 0.09878 | 17 | \$ 48.75 | \$ 2.87 | 14,750 | \$44.01 | \$2.98 | 0 | 695 |
| September-10 | 2,780 | \$ 201.72 | \$ 0.07256 | 20 | \$ 54.18 | \$ 2.71 | 15,500 | \$49.45 | \$3.19 | 4 | 353 |
| October-10 | 2,520 | \$ 191.42 | \$ 0.07596 | 25 | \$ 60.95 | \$ 2.44 | 15,500 | \$49.45 | \$3.19 | 66 | 132 |
| November-10 | 3,180 | \$ 217.56 | \$ 0.06842 | 503 | \$ 619.72 | \$ 1.23 | 15,500 | \$49.45 | \$3.19 | 336 | 9 |
| December-10 | 5,360 | \$ 303.88 | \$ 0.05669 | 4,361 | \$ 3,392.32 | \$ 0.78 | 16,250 | \$51.84 | \$3.19 | 912 | 0 |
| Totals: | 41,747 | \$ 2,863.88 | \$ 0.06860 | 21,023 | \$ 16,931.96 | \$ 0.81 | 181,500 | \$539.19 | \$2.97 | | |

Electric Consumption Rate: \$0.06860 /kWh
 Natural Gas Consumption Rate \$0.81 /ccf

Annual Cost/Sq.ft - Electricity: \$0.205 /sqft
 Annual Cost/Sq.ft - Gas.: \$1.209 /sqft
 Annual Cost/Sq.ft - Total: \$1.414 /sqft

Table 8 Utility Bill Analysis - Central Garage




Figure 17 Monthly Electrical Consumption - Central Garage

Figure 17 Monthly Electrical Consumption - Central Garage details the electrical consumption and each month's corresponding heating and cooling degree days. Cooling degree days (CDD) are a measure of the severity of the cooling requirements in a given locality; the more cooling degree days, the hotter the summer. Based on the graph, the electrical consumption peaks in June and the cooling degree days peak in July. This slight discrepancy could be due the timing of the electric billing cycle.




Figure 18 Monthly Natural Gas Consumption - Central Garage

Figure 18 Monthly Natural Gas Consumption - Central Garage details the natural gas consumption and each month's corresponding heating degree days. Heating degree days (HDD) are a measure of the severity of the heating requirements in a given locality; the more heating degree days, the cooler the winter. Based on the graph, the gas consumption and the heating degree days peak in January.




Figure 19 Monthly Water Consumption - Central Garage

Figure 19 Monthly Water Consumption - Central Garage details the water consumption. Water is not used for the Central Garage HVAC. Usage fluctuations is based solely on occupant usage.

Heman Park Tennis court, Restroom, and Pavilion



Building Description

This recreation area has approximately 850 ft² of covered facilities with no conditioned spaces. Staff noted that a renovation had been completed recently and any renovations to the tennis courts would likely draw complaints from the users. It was decided by public works staff that an audit of this facility was unnecessary.

Utility Summary

Utility Usage Breakdown

Estimated Electric Consumption

| | |
|-------------------|-------------|
| Lights: | 100% |
| Miscellaneous: | 0% |
| AHU Fans & Pumps: | 0% |
| Cooling: | 0% |
| <u>Totals:</u> | <u>100%</u> |

Overall, the total utility cost for the Heman Park Tennis Court, Restroom and Pavilion is \$2,510.50 for the past 12 months. The breakdown for each item was calculated based upon the existing equipment and the operating hours from facility personnel.




Figure 20 Electricity Usage Breakdown - Heman Park Tennis Court, Restroom and Pavilion

| Utility Bill Analysis For Heman Park Tennis Court, Restroom, and Pavilion | | | | | |
|---|-------------------------|------------------|------------------------------|------|-----|
| Period End | Electricity Consumption | Electricity Cost | Electricity Consumption Rate | HDD | CDD |
| | (kWh) | (\$) | (\$/kWh) | | |
| January-10 | 1,300 | \$ 87.59 | \$ 0.06738 | 1009 | 0 |
| February-10 | 521 | \$ 39.92 | \$ 0.07662 | 820 | 0 |
| March-10 | 2,714 | \$ 174.13 | \$ 0.06416 | 350 | 15 |
| April-10 | 3,183 | \$ 193.59 | \$ 0.06082 | 39 | 166 |
| May-10 | 2,269 | \$ 146.89 | \$ 0.06474 | 20 | 277 |
| June-10 | 3,369 | \$ 284.62 | \$ 0.08448 | 0 | 623 |
| July-10 | 3,018 | \$ 281.79 | \$ 0.09337 | 0 | 706 |
| August-10 | 3,388 | \$ 321.03 | \$ 0.09476 | 0 | 695 |
| September-10 | 3,729 | \$ 352.40 | \$ 0.09450 | 4 | 353 |
| October-10 | 3,864 | \$ 228.14 | \$ 0.05904 | 66 | 132 |
| November-10 | 3,884 | \$ 228.93 | \$ 0.05894 | 336 | 9 |
| December-10 | 2,433 | \$ 171.47 | \$ 0.07048 | 912 | 0 |
| Totals: | 33,672 | \$ 2,510.50 | \$ 0.07456 | | |

Electric Consumption Rate: \$0.07456 /kWh

Annual Cost/Sq.ft - Electricity: \$2.954 /sqft
Annual Cost/Sq.ft - Total: \$2.954 /sqft

Table 9 Utility Bill Analysis - Heman Park Tennis Court, Restroom and Pavilion




Figure 21 Monthly Electrical Consumption - Heman Park Tennis Court, Restroom and Pavilion

Figure 21 Monthly Electrical Consumption - Heman Park Tennis Court, Restroom and Pavilion details the electrical consumption and each month’s corresponding heating and cooling degree days. Cooling degree days (CDD) are a measure of the severity of the cooling requirements in a given locality; the more cooling degree days, the hotter the summer. This buildings is not conditioned. All electrical use is lighting and will vary with the lighting usage.

Transfer Station and MRF



Building Description

The Transfer Station is a 9,600 ft² facility built in 1969 to transfer garbage from the route trucks to larger trucks for delivery to the landfill. The building also has a recyclables sorting machine that is no longer in use. There is also open space where other miscellaneous work is performed. There are eleven full time employees and the operating hours are 6:30am-5pm Monday through Friday and 8am-Noon on Saturday.

HVAC Description

The majority of this facility is heated only. This is provided by a 900 MBH direct fired unit. There is also a small office/break room that appears to be unoccupied that is conditioned by a PTAC unit that is inoperable. The MRF is a small shack there the route trucks unload that is conditioned by a small window unit and heated by a small electric wall heater.

Utility Summary

Utility Usage Breakdown

Estimated Electric Consumption

| | |
|-------------------|-------------|
| Lights: | 44% |
| Miscellaneous: | 29% |
| AHU Fans & Pumps: | 27% |
| Cooling: | 0% |
| Totals: | 100% |

Estimated Natural Gas Consumption

| | |
|-----------------|------|
| Heating: | 100% |
| Domestic water: | 0% |
| Totals: | 100% |

Overall, the total utility cost for the Transfer Station and MRF is \$4,385.35 for the past 12 months. The breakdown for each item was calculated based upon the existing equipment and the operating hours from facility personnel.




Figure 22 Electricity Usage Breakdown - Transfer Station and MRF




Figure 23 Natural Gas Usage Breakdown - Transfer Station and MRF



Detailed Energy Study University City Municipal Buildings

| Utility Bill Analysis For Transfer Station & MRF | | | | | | | | | | | |
|--|-------------------------|------------------|------------------------------|-------------------------|------------------|----------------------|-------------------|------------|------------|------|-----|
| Period End | Electricity Consumption | Electricity Cost | Electricity Consumption Rate | Natural Gas Consumption | Natural Gas Cost | Gas Consumption Rate | Water Consumption | Water Cost | Water Rate | HDD | CDD |
| | (kWh) | (\$) | (\$/kWh) | (CCF) | (\$) | (\$/ccf) | (Gal.) | (\$) | | | |
| January-10 | 934 | \$ 65.19 | \$ 0.06980 | 1,091 | \$ 829.49 | \$ 0.76 | 4,250 | \$ 11.81 | \$2.78 | 1009 | 0 |
| February-10 | 937 | \$ 65.37 | \$ 0.06977 | 988 | \$ 755.25 | \$ 0.76 | 4,250 | \$ 11.81 | \$2.78 | 820 | 0 |
| March-10 | 660 | \$ 48.42 | \$ 0.07336 | 611 | \$ 486.12 | \$ 0.80 | 4,250 | \$ 11.81 | \$2.78 | 350 | 15 |
| April-10 | 589 | \$ 44.08 | \$ 0.07484 | 87 | \$ 112.65 | \$ 1.29 | 4,250 | \$ 11.81 | \$2.78 | 39 | 166 |
| May-10 | 532 | \$ 51.71 | \$ 0.09720 | 27 | \$ 43.83 | \$ 1.62 | 4,250 | \$ 11.81 | \$2.78 | 20 | 277 |
| June-10 | 845 | \$ 79.51 | \$ 0.09409 | 7 | \$ 27.65 | \$ 3.95 | 4,250 | \$ 12.68 | \$2.98 | 0 | 623 |
| July-10 | 784 | \$ 81.46 | \$ 0.10390 | 8 | \$ 28.45 | \$ 3.56 | 4,250 | \$ 12.68 | \$2.98 | 0 | 706 |
| August-10 | 740 | \$ 77.41 | \$ 0.10461 | 7 | \$ 27.65 | \$ 3.95 | 4,250 | \$ 12.68 | \$2.98 | 0 | 695 |
| September-10 | 718 | \$ 58.58 | \$ 0.08159 | 7 | \$ 29.50 | \$ 4.21 | 5,250 | \$ 16.75 | \$3.19 | 4 | 353 |
| October-10 | 627 | \$ 52.34 | \$ 0.08348 | 13 | \$ 35.94 | \$ 2.76 | 5,250 | \$ 16.75 | \$3.19 | 66 | 132 |
| November-10 | 771 | \$ 62.22 | \$ 0.08070 | 480 | \$ 393.88 | \$ 0.82 | 5,250 | \$ 16.75 | \$3.19 | 336 | 9 |
| December-10 | 938 | \$ 73.68 | \$ 0.07855 | 899 | \$ 685.30 | \$ 0.76 | 7,000 | \$ 22.33 | \$3.19 | 912 | 0 |
| Totals: | 9,075 | \$ 759.97 | \$ 0.08374 | 4,225 | \$ 3,455.71 | \$ 0.82 | 56,750 | \$ 169.67 | \$2.99 | | |

Electric Consumption Rate: \$0.08374 /kWh
 Natural Gas Consumption Rate \$0.82 /ccf

Annual Cost/Sq.ft - Electricity: \$0.079 /sqft
 Annual Cost/Sq.ft - Gas.: \$0.360 /sqft
 Annual Cost/Sq.ft - Total: \$0.439 /sqft

Table 10 Utility Bill Analysis - Transfer Station and MRF




Figure 24 Monthly Electrical Consumption - Transfer Station and MRF

Figure 24 Monthly Electrical Consumption - Transfer Station and MRF details the electrical consumption and each month’s corresponding heating and cooling degree days. Cooling degree days (CDD) are a measure of the severity of the cooling requirements in a given locality; the more cooling degree days, the hotter the summer. Based on the graph, the electrical consumption peaks in February due to some electric heat, increased light usage due to shorter daylight hours, and the lack of cooling.




Figure 25 Monthly Gas Consumption - Transfer Station and MRF

Figure 25 Monthly Gas Consumption - Transfer Station and MRF details the natural gas consumption and each month’s corresponding heating degree days. Heating degree days (HDD) are a measure of the severity of the heating requirements in a given locality; the more heating degree days, the cooler the winter. Based on the graph, the gas consumption and the heating degree days peak in January.

Public Works Sign Shop



Building Description

This building is 1,900 ft² and was built in 1970. It is set up to produce signage. There is one full time employee and the official operating hours are 6:30am-5pm Monday through Friday and 8am-Noon on Saturday. The building was unoccupied during the site visit and staff noted that the occupancy varies.

HVAC Description

The sign shop is heated only by two gas fired unit heaters. The window air conditioner was not connected to a power supply.

Utility Summary

Utility Usage Breakdown

Estimated Electric Consumption

| | |
|-------------------|-------------|
| Lights: | 42% |
| Miscellaneous: | 47% |
| AHU Fans & Pumps: | 11% |
| Cooling: | 0% |
| Totals: | 100% |

Natural gas consumption data was not available for the Public Works Sign Shop.



Detailed Energy Study University City Municipal Buildings

Overall, the total utility cost for the Public Works Sign Shop is \$8,202.82 for the past 12 months, excluding gas and water usage. The breakdown for each item was calculated based upon the existing equipment and the operating hours from facility personnel.




Figure 26 Electricity Usage Breakdown - Public Works Sign Shop

| Utility Bill Analysis For Public Works Sign Shop | | | | | |
|--|-------------------------|------------------|------------------------------|------|-----|
| Period End | Electricity Consumption | Electricity Cost | Electricity Consumption Rate | HDD | CDD |
| | (kWh) | (\$) | (\$/kWh) | | |
| January-10 | 8,819 | \$ 530.22 | \$ 0.06012 | 1009 | 0 |
| February-10 | 8,507 | \$ 519.17 | \$ 0.06103 | 820 | 0 |
| March-10 | 7,908 | \$ 497.97 | \$ 0.06297 | 350 | 15 |
| April-10 | 7,508 | \$ 476.20 | \$ 0.06343 | 39 | 166 |
| May-10 | 7,818 | \$ 658.57 | \$ 0.08424 | 20 | 277 |
| June-10 | 11,685 | \$ 1,001.76 | \$ 0.08573 | 0 | 623 |
| July-10 | 12,080 | \$ 1,129.97 | \$ 0.09354 | 0 | 706 |
| August-10 | 11,547 | \$ 1,080.93 | \$ 0.09361 | 0 | 695 |
| September-10 | 9,940 | \$ 629.97 | \$ 0.06338 | 4 | 353 |
| October-10 | 7,405 | \$ 526.59 | \$ 0.07111 | 66 | 132 |
| November-10 | 8,283 | \$ 564.35 | \$ 0.06813 | 336 | 9 |
| December-10 | 8,858 | \$ 587.12 | \$ 0.06628 | 912 | 0 |
| Totals: | 110,358 | \$ 8,202.82 | \$ 0.07433 | | |

Electric Consumption Rate: \$0.07433 /kWh

Annual Cost/Sq.ft - Electricity: \$4.317 /sqft
 Annual Cost/Sq.ft - Total: \$4.317 /sqft

Table 11 Utility Bill Analysis - Public Works Sign Shop




Figure 27 Monthly Electrical Consumption - Public Works Sign Shop

Figure 27 Monthly Electrical Consumption - Public Works Sign Shop details the electric consumption and each month’s corresponding heating and cooling degree days. Cooling degree days (CDD) are a measure of the severity of the cooling requirements in a given locality; the more cooling degree days, the hotter the summer. Based on the graph, the electrical consumption and the cooling degree days peak in July.

Park Maintenance Facility



Building Description

This building is a 6,300 ft² building built in 1970. The majority of the facility is a workshop and storage area with a 285 ft² office. There are two full time employees and the operating hours are 6:30am-5pm Monday through Friday and 8am-Noon on Saturday. However the occupancy varies depending on how many of the crew has come in from the field. During the site visit there were approximately 10 employees.

HVAC Description

The shop area of the building is heated only by four gas fired unit heaters and one gas fired furnace. The office is cooled by a window air conditioner unit.

Utility Summary

Utility Usage Breakdown

Estimated Electric Consumption

| | |
|-------------------|-------------|
| Lights: | 48% |
| Miscellaneous: | 42% |
| AHU Fans & Pumps: | 7% |
| Cooling: | 4% |
| Totals: | 100% |

Estimated Natural Gas Consumption

| | |
|-----------------|-------------|
| Heating: | 88% |
| Domestic water: | 12% |
| Totals: | 100% |

Overall, the total utility cost for the Park Maintenance Facility is \$5,230.31 for the past 12 months. The breakdown for each item was calculated based upon the existing equipment and the operating hours from facility personnel.




Figure 28 Electricity Usage Breakdown - Park Maintenance Facility




Figure 29 Natural Gas Usage Breakdown - Park Maintenance Facility



Detailed Energy Study University City Municipal Buildings

| Utility Bill Analysis For Park Maintenance Facility | | | | | | | | | | | |
|--|-------------------------|------------------|------------------------------|-------------------------|------------------|----------------------|-------------------|------------|------------|------|-----|
| Period End | Electricity Consumption | Electricity Cost | Electricity Consumption Rate | Natural Gas Consumption | Natural Gas Cost | Gas Consumption Rate | Water Consumption | Water Cost | Water Rate | HDD | CDD |
| | (kWh) | (\$) | (\$/kWh) | (CCF) | (\$) | (\$/ccf) | (Gal.) | (\$) | (\$/kGal) | | |
| January-10 | 75 | \$ 12.62 | \$ 0.16827 | 1,419 | \$ 1,259.00 | \$ 0.89 | 4750 | \$13.20 | \$2.78 | 1009 | 0 |
| February-10 | 69 | \$ 12.25 | \$ 0.17754 | 1,250 | \$ 1,135.65 | \$ 0.91 | 4750 | \$13.20 | \$2.78 | 820 | 0 |
| March-10 | 64 | \$ 11.95 | \$ 0.18672 | 651 | \$ 698.84 | \$ 1.07 | 6000 | \$16.67 | \$2.78 | 350 | 15 |
| April-10 | 118 | \$ 15.25 | \$ 0.12924 | 195 | \$ 253.34 | \$ 1.30 | 6000 | \$16.67 | \$2.78 | 39 | 166 |
| May-10 | 149 | \$ 20.26 | \$ 0.13597 | 59 | \$ 82.56 | \$ 1.40 | 6000 | \$16.67 | \$2.78 | 20 | 277 |
| June-10 | 235 | \$ 28.11 | \$ 0.11962 | 30 | \$ 59.14 | \$ 1.97 | 14000 | \$41.78 | \$2.98 | 0 | 623 |
| July-10 | 205 | \$ 28.19 | \$ 0.13751 | 0 | \$ 35.02 | \$ - | 14000 | \$41.78 | \$2.98 | 0 | 706 |
| August-10 | 179 | \$ 25.80 | \$ 0.14413 | 37 | \$ 64.86 | \$ 1.75 | 14000 | \$41.78 | \$2.98 | 0 | 695 |
| September-10 | 212 | \$ 23.87 | \$ 0.11259 | 40 | \$ 70.02 | \$ 1.75 | 9500 | \$30.31 | \$3.19 | 4 | 353 |
| October-10 | 188 | \$ 22.23 | \$ 0.11824 | 39 | \$ 72.48 | \$ 1.86 | 9500 | \$30.31 | \$3.19 | 66 | 132 |
| November-10 | 167 | \$ 20.79 | \$ 0.12449 | 99 | \$ 155.48 | \$ 1.57 | 9500 | \$30.31 | \$3.19 | 336 | 9 |
| December-10 | 92 | \$ 15.64 | \$ 0.17000 | 756 | \$ 799.13 | \$ 1.06 | 4750 | \$15.15 | \$3.19 | 912 | 0 |
| Totals: | 1,753 | \$ 236.96 | \$ 0.13517 | 4,575 | \$ 4,685.52 | \$ 1.02 | 102,750 | \$307.83 | \$3.00 | | |

Electric Consumption Rate: \$ 0.14 /kWh
 Natural Gas Consumption Rate: \$ 1.02 /ccf

Annual Cost/Sq.ft - Electricity: \$0.038 /sqft
 Annual Cost/Sq.ft - Gas.: \$0.744 /sqft
 Annual Cost/Sq.ft - Total: \$0.781 /sqft

Table 12 Utility Bill Analysis - Park Maintenance Facility




Figure 30 Monthly Electricity Consumption - Park Maintenance Facility

Figure 30 Monthly Electricity Consumption - Park Maintenance Facility details the electrical consumption and each month’s corresponding heating and cooling degree days. Cooling degree days (CDD) are a measure of the severity of the cooling requirements in a given locality; the more cooling degree days, the hotter the summer. Based on the graph, the electrical consumption peaks in June and the cooling degree days peak in July. This discrepancy could be due to the timing of the billing cycle.

2010 Monthly Natural Gas Consumption




Figure 31 Monthly Natural Gas Consumption - Park Maintenance Facility

Figure 31 Monthly Natural Gas Consumption - Park Maintenance Facility details the natural gas consumption and each month's corresponding heating degree days. Heating degree days (HDD) are a measure of the severity of the heating requirements in a given locality; the more heating degree days, the cooler the winter. Based on the graph, the gas consumption and the heating degree days peak in January.




Figure 32 Monthly Water Consumption - Park Maintenance Facility

Figure 32 Monthly Water Consumption - Park Maintenance Facility details the water consumption for the Park Maintenance Facility. Although all water usage is due to occupants there is a corresponding rise in water usage during the hotter months. This is likely due to increased work load during that time of year.

Golf Course



Building Description

The Golf Course consists of three buildings; Club House, Maintenance Facility, and Range Shack. The Club House is a two story facility that is 3,500 ft² and was built in 1935. The basement of the club house is approximately half the size of the ground floor and is mainly a storage and equipment room. The ground floor is divided between the pro shop with a small office and a snack area. There is one full-time employee and the operating hours are 6am-8:30pm seven days a week.

The Golf Range Shack is 850 ft² and was built in 2009. Its only function is to house the ball dispensing machine for the driving range. This building is not occupied except to service the machine.

The Golf Maintenance Facility is 1,600 ft² and was built in 1960. There is a small office located in this building with the remainder of being a storage and workshop for the maintenance equipment.

HVAC Description

The Club House is served by two split systems. One 2.5-ton and one 5-ton. Both are less than five years old and in good condition. The Range Shack is not conditioned. The office in the Maintenance Facility is conditioned with a window air conditioner. A portion of the building is unconditioned storage while the shop is heated only by a 100-MBH gas fired unit heater.

Utility Summary

Utility Usage Breakdown

Estimated Electric Consumption

| | |
|-------------------|------------|
| Lights: | 17% |
| Miscellaneous: | 37% |
| AHU Fans & Pumps: | 10% |
| Cooling: | 36% |
| <hr/> Totals: | <hr/> 100% |

Estimated Natural Gas Consumption

| | |
|-----------------|------------|
| Heating: | 34% |
| Domestic water: | 66% |
| <hr/> Totals: | <hr/> 100% |

Overall, the total utility cost for the Golf Course is \$18,461.40 for the past 12 months. The breakdown for each item was calculated based upon the existing equipment and the operating hours from facility personnel.




Figure 33 Electricity Usage Breakdown - Golf Course



Detailed Energy Study University City Municipal Buildings




Figure 34 Natural Gas Consumption - Golf Course

| Utility Bill Analysis For the Golf Course | | | | | | | | | | | |
|---|-------------------------|------------------|------------------------------|-------------------------|------------------|----------------------|-------------------|-------------|------------|------|-----|
| Period End | Electricity Consumption | Electricity Cost | Electricity Consumption Rate | Natural Gas Consumption | Natural Gas Cost | Gas Consumption Rate | Water Consumption | Water Cost | Water Rate | HDD | CDD |
| | (kWh) | (\$) | (\$/kWh) | (CCF) | (\$) | (\$/ccf) | (Gal.) | (\$) | (\$/kGal) | | |
| January-10 | 3,960 | \$ 258.42 | \$ 0.06526 | 758 | \$ 641.59 | \$ 0.85 | 5,250 | \$ 14.58 | \$ 2.78 | 1009 | 0 |
| February-10 | 3,684 | \$ 241.52 | \$ 0.06556 | 575 | \$ 510.45 | \$ 0.89 | 5,250 | \$ 14.58 | \$ 2.78 | 820 | 0 |
| March-10 | 3,713 | \$ 243.29 | \$ 0.06552 | 381 | \$ 371.96 | \$ 0.98 | 139,750 | \$ 388.22 | \$ 2.78 | 350 | 15 |
| April-10 | 4,344 | \$ 268.46 | \$ 0.06180 | 109 | \$ 172.94 | \$ 1.59 | 139,750 | \$ 388.22 | \$ 2.78 | 39 | 166 |
| May-10 | 4,632 | \$ 381.28 | \$ 0.08231 | 42 | \$ 77.94 | \$ 1.86 | 139,750 | \$ 388.22 | \$ 2.78 | 20 | 277 |
| June-10 | 8,071 | \$ 696.38 | \$ 0.08628 | 38 | \$ 74.66 | \$ 1.96 | 254,750 | \$ 762.51 | \$ 2.99 | 0 | 623 |
| July-10 | 7,929 | \$ 745.91 | \$ 0.09407 | 32 | \$ 69.88 | \$ 2.18 | 254,750 | \$ 762.51 | \$ 2.99 | 0 | 706 |
| August-10 | 6,649 | \$ 630.37 | \$ 0.09481 | 22 | \$ 61.83 | \$ 2.81 | 254,750 | \$ 762.51 | \$ 2.99 | 0 | 695 |
| September-10 | 5,433 | \$ 378.95 | \$ 0.06975 | 24 | \$ 67.08 | \$ 2.80 | 791,000 | \$ 2,523.29 | \$ 3.19 | 4 | 353 |
| October-10 | 3,798 | \$ 279.20 | \$ 0.07351 | 28 | \$ 73.54 | \$ 2.63 | 791,000 | \$ 2,523.29 | \$ 3.19 | 66 | 132 |
| November-10 | 3,589 | \$ 264.87 | \$ 0.07380 | 101 | \$ 170.92 | \$ 1.69 | 791,000 | \$ 2,523.29 | \$ 3.19 | 336 | 9 |
| December-10 | 4,053 | \$ 296.70 | \$ 0.07321 | 421 | \$ 400.94 | \$ 0.95 | 9,750 | \$ 31.10 | \$ 3.19 | 912 | 0 |
| Totals: | 59,855 | \$ 4,685.35 | \$ 0.07828 | 2,531 | \$ 2,693.73 | \$ 1.06 | 3,576,750 | \$11,082.32 | \$ 3.10 | | |

Electric Consumption Rate: \$0.07828 /kWh
 Natural Gas Consumption Rate: \$1.06 /ccf

Annual Cost/Sq.ft - Electricity: \$0.787 /sqft
 Annual Cost/Sq.ft - Gas.: \$0.453 /sqft
 Annual Cost/Sq.ft - Total: \$1.240 /sqft

Table 13 Utility Bill Analysis - Golf Course




Figure 35 Monthly Electrical Consumption - Golf Course

Figure 35 Monthly Electrical Consumption - Golf Course details the electrical consumption and each month’s corresponding heating and cooling degree days. Cooling degree days (CDD) are a measure of the severity of the cooling requirements in a given locality; the more cooling degree days, the hotter the summer. Based on the graph, the electrical consumption peaks in June and the cooling degree days peak in July. This discrepancy could be due to the timing of the billing cycle.




Figure 36 Monthly Natural Gas Consumption - Golf Course

Figure 36 Monthly Natural Gas Consumption - Golf Course details the natural gas consumption and each month’s corresponding heating degree days. Heating degree days (HDD) are a measure of the severity of the heating requirements in a given locality; the more heating degree days, the cooler the winter. Based on the graph, the gas consumption and the heating degree days peak in January.




Figure 37 Monthly Water Consumption - Golf Course

Figure 37 Monthly Water Consumption - Golf Course details the water consumption for the Golf Course. Water is not used for HVAC and therefore should not follow the cooling degree days. The peak late in the year is likely due to maintenance or a leak.

Fire Station #2



Building Description

Fire Station #2 is 10,800 ft² was originally built in 1939. It received a major renovation and addition in 2006. On the first floor are the truck bays, kitchen, dining room, and entertainment room. The second floor contains the bunk rooms, exercise room, and a training room. There are sixteen full time employees divided into three shifts and the building is occupied continuously.

HVAC Description

The entire HVAC system was replaced during the 2006 renovation with new high efficiency equipment. The truck bays are heated only by four gas fired unit heaters. The remainder of the building is conditioned by five split systems totaling 23-tons. The units on the second floor were equipped with humidifiers.

Utility Summary

Utility Usage Breakdown

Estimated Electric Consumption

| | |
|-------------------|-------------|
| Lights: | 17% |
| Miscellaneous: | 5% |
| AHU Fans & Pumps: | 10% |
| Cooling: | 34% |
| Heating: | 34% |
| Totals: | 100% |

Estimated Natural Gas Consumption

| | |
|-----------------|-------------|
| Heating: | 68% |
| Domestic water: | 32% |
| Totals: | 100% |

Overall, the total utility cost for Fire Station #2 is \$12,422.62 for the past 12 months. The breakdown for each item was calculated based upon the existing equipment and the operating hours from facility personnel.




Figure 38 Electricity Usage Breakdown - Fire Station #2




Figure 39 Natural Gas Usage Breakdown - Fire Station #2



Detailed Energy Study University City Municipal Buildings

| Utility Bill Analysis For Fire Station #2 | | | | | | | | | | | |
|---|-------------------------|------------------|------------------------------|-------------------------|------------------|----------------------|-------------------|------------|------------|------|-----|
| Period End | Electricity Consumption | Electricity Cost | Electricity Consumption Rate | Natural Gas Consumption | Natural Gas Cost | Gas Consumption Rate | Water Consumption | Water Cost | Water Rate | HDD | CDD |
| | (kWh) | (\$) | (\$/kWh) | (CCF) | (\$) | (\$/ccf) | (Gal.) | (\$) | (\$/kGal) | | |
| January-10 | 11,020 | \$ 624.32 | \$ 0.05665 | 1,091 | \$ 1,020.48 | \$ 0.94 | 13,750 | \$38.20 | \$2.78 | 1009 | 0 |
| February-10 | 10,330 | \$ 599.89 | \$ 0.05807 | 804 | \$ 810.44 | \$ 1.01 | 13,750 | \$38.20 | \$2.78 | 820 | 0 |
| March-10 | 8,350 | \$ 527.73 | \$ 0.06320 | 433 | \$ 517.78 | \$ 1.20 | 15,000 | \$41.67 | \$2.78 | 350 | 15 |
| April-10 | 8,990 | \$ 552.45 | \$ 0.06145 | 145 | \$ 197.30 | \$ 1.36 | 15,000 | \$41.67 | \$2.78 | 39 | 166 |
| May-10 | 8,330 | \$ 700.60 | \$ 0.08411 | 55 | \$ 79.31 | \$ 1.44 | 15,000 | \$41.67 | \$2.78 | 20 | 277 |
| June-10 | 11,670 | \$ 1,004.17 | \$ 0.08605 | 37 | \$ 64.70 | \$ 1.75 | 15,500 | \$46.25 | \$2.98 | 0 | 623 |
| July-10 | 11,550 | \$ 1,081.21 | \$ 0.09361 | 36 | \$ 63.98 | \$ 1.78 | 15,500 | \$46.25 | \$2.98 | 0 | 706 |
| August-10 | 11,540 | \$ 1,080.29 | \$ 0.09361 | 33 | \$ 61.61 | \$ 1.87 | 15,500 | \$46.25 | \$2.98 | 0 | 695 |
| September-10 | 8,620 | \$ 609.94 | \$ 0.07076 | 38 | \$ 68.82 | \$ 1.81 | 14,250 | \$45.46 | \$3.19 | 4 | 353 |
| October-10 | 5,800 | \$ 416.49 | \$ 0.07181 | 44 | \$ 60.86 | \$ 1.38 | 14,250 | \$45.46 | \$3.19 | 66 | 132 |
| November-10 | 6,470 | \$ 462.45 | \$ 0.07148 | 154 | \$ 161.83 | \$ 1.05 | 14,250 | \$45.46 | \$3.19 | 336 | 9 |
| December-10 | 8,610 | \$ 609.26 | \$ 0.07076 | 671 | \$ 524.71 | \$ 0.78 | 14,250 | \$45.46 | \$3.19 | 912 | 0 |
| Totals: | 111,280 | \$ 8,268.80 | \$ 0.07431 | 3,541 | \$ 3,631.82 | \$ 1.03 | 176,000 | \$522.00 | \$2.97 | | |

Electric Consumption Rate: \$0.07431 /kWh
 Natural Gas Consumption Rate: \$1.03 /ccf

Annual Cost/Sq.ft - Electricity: \$0.766 /sqft
 Annual Cost/Sq.ft - Gas.: \$0.336 /sqft
 Annual Cost/Sq.ft - Total: \$1.102 /sqft

Table 14 Utility Bill Analysis - Fire Station #2




Figure 40 Monthly Electrical Consumption - Fire Station #2

Figure 40 Monthly Electrical Consumption - Fire Station #2 details the electrical consumption and each month’s corresponding heating and cooling degree days. Cooling degree days (CDD) are a measure of the severity of the cooling requirements in a given locality; the more cooling degree days, the hotter the summer. Based on the graph, the electrical consumption peaks when the CDDs are the highest. There is also a second peak in the winter months attributed to a portion of the building having electric heat.




Figure 41 Monthly Natural Gas Consumption - Fire Station #2

Figure 41 Monthly Natural Gas Consumption - Fire Station #2 details the natural gas consumption and each month's corresponding heating degree days. Heating degree days (HDD) are a measure of the severity of the heating requirements in a given locality; the more heating degree days, the cooler the winter. Based on the graph, the gas consumption and the heating degree days peak in January.




Figure 42 Monthly Water Consumption - Fire Station #2

Figure 42 Monthly Water Consumption - Fire Station #2 details the water consumption for Fire Station #2. There is a slight peak in summer however, water is not used for cooling. The water use increases approximately 10% during the summer. This can be attributed to occupants using more water during the hotter portion of the year.

City Hall



Building Description

City Hall is a six story building of 39,900 ft² originally built in 1903. It was completely renovated in 2005 and became LEED certified in 2008. The basement is largely storage and mechanical space while the first through fourth floors are office space. The sixth floor is the council chambers and courtroom. There are 55 full time employees and is operated from 7am-5pm Monday through Friday.

HVAC Description

The entire HVAC system was replaced during the latest renovation in 2005. The system consists of water-source heat pumps (WSHP) with a cooling tower outside for heat rejection. In the basement there are two building loop pumps (one backup) to provide water to the WSHPs and two condenser water loop pumps (one backup) to circulate water through the cooling tower and the plate and frame heat exchanger where heat is transferred from the building loop to the condenser water loop. There is also a shell and tube heat exchanger that transfers heat from the central steam loop to the building loop during the winter. The steam is provided by the boilers in the basement of the adjacent Trinity Building. The system is controlled by a modern DDC system with night set back.

Utility Summary

Utility Usage Breakdown

Estimated Electric Consumption

| | |
|-------------------|------------|
| Lights: | 14% |
| Miscellaneous: | 18% |
| AHU Fans & Pumps: | 34% |
| Cooling: | 35% |
| <hr/> Totals: | <hr/> 100% |

Overall, the total utility cost for City Hall is \$27,975.71 for the past 12 months. It should be noted that water is supplied from the adjacent Annex building and that heating is provided by steam from the adjacent Trinity building. The breakdown for each item was calculated based upon the existing equipment and the operating hours from facility personnel.




Figure 43 Electricity Usage Breakdown - City Hall




Figure 44 Monthly Electrical Consumption - City Hall

Figure 44 Monthly Electrical Consumption - City Hall details the electrical consumption and each month’s corresponding heating and cooling degree days. Cooling degree days (CDD) are a measure of the severity of the cooling requirements in a given locality; the more cooling degree days, the hotter the summer. Based on the graph, the electrical consumption peaks in June and the cooling degree days peak in July. This discrepancy could be due to the timing of the billing cycle. The winter peak is due to the compressors in the WSHPs running in the winter even though the hot water loop is heated with steam from a nearby building. Part of the winter increase could also be due to increased light usage since there is a day lighting controls to limit lighting usage when sun light is sufficient. Therefore, lighting usage would rise during the winter when daylight hours are shorter.




Figure 45 Monthly Electrical Demand - City Hall

Figure 45 Monthly Electrical Demand - City Hall, which shows the monthly electrical demand, suggests the same conclusions as the electric consumption graph. The electric usage for the City Hall is fairly constant.

Centennial Commons Recreation Center



Building Description

This facility is a 67,000 ft² recreation facility built in 2005 adjacent to the Heman Pool. The building contains a basketball court, weight room, cardio rooms, and an indoor soccer field. The building has five full time employees but a highly variable number of occupants. The facility is open from 5:30am-10pm Monday through Friday, 8am-8pm Saturday, and 10am-6pm Sunday.

HVAC Description

The facility is conditioned by two large rooftop units, one for the basketball court and one for the exercise area. There is an energy recovery ventilator preconditioning the outside air to the rooftop unit serving the exercise spaces. These units are controlled with a modern DDC control system with night setback. The indoor soccer field is heated by gas fired forced air furnace set up for recirculation and 100% outside air.

Utility Summary

Utility Usage Breakdown

Estimated Electric Consumption

| | |
|-------------------|-------------|
| Lights: | 28% |
| Miscellaneous: | 28% |
| AHU Fans & Pumps: | 15% |
| Cooling: | 29% |
| Totals: | 100% |

Estimated Natural Gas Consumption

| | |
|-----------------|-------------|
| Heating: | 95% |
| Domestic water: | 5% |
| Totals: | 100% |

Overall, the total utility cost for the Centennial Commons Recreation Center is \$102,275.67 for the past 12 months. It appears from the bills that the adjacent Heman Park Pool is on the same water meter. The large spike in the June through August water bill is most likely attributed to refilling the pool for the summer season. Due to water billing once a quarter and the exact meter reading date would explain the lag time for it to show on the bill. The breakdown for each item was calculated based upon the existing equipment and the operating hours from facility personnel.




Figure 46 Electricity Usage Breakdown - Centennial Commons Recreation Center




Figure 47 Natural Gas Usage Breakdown - Centennial Commons Recreation Center



Detailed Energy Study University City Municipal Buildings

| Utility Bill Analysis For Centennial Commons Recreation Center | | | | | | | | | | | | | | |
|--|-------------------------|------------------|------------------------------|--------------------|-------------------------|-------------------------|-------------------------|------------------|----------------------|-------------------|-------------|------------|------|-----|
| Period End | Electricity Consumption | Electricity Cost | Electricity Consumption Rate | Electricity Demand | Electricity Demand Cost | Electricity Demand Rate | Natural Gas Consumption | Natural Gas Cost | Gas Consumption Rate | Water Consumption | Water Cost | Water Rate | HDD | CDD |
| | (kWh) | (\$) | (\$/kWh) | (kW) | (\$) | (\$) | (CCF) | (\$) | (\$/ccf) | (Gal.) | (\$) | (\$/kGal) | | |
| January-10 | 118,560 | \$ 4,458.19 | \$ 0.03760 | 195 | \$ 273.28 | \$ 1.40 | 3,380 | \$ 2,691.30 | \$ 0.80 | 40,000 | \$111.12 | \$2.78 | 1009 | 0 |
| February-10 | 97,920 | \$ 3,778.94 | \$ 0.03859 | 181 | \$ 253.96 | \$ 1.40 | 2,882 | \$ 2,325.60 | \$ 0.81 | 40,000 | \$111.12 | \$2.78 | 820 | 0 |
| March-10 | 90,840 | \$ 3,527.39 | \$ 0.03883 | 173 | \$ 241.92 | \$ 1.40 | 1,577 | \$ 1,374.08 | \$ 0.87 | 76,250 | \$211.82 | \$2.78 | 350 | 15 |
| April-10 | 79,080 | \$ 3,157.48 | \$ 0.03993 | 169 | \$ 235.90 | \$ 1.40 | 381 | \$ 461.40 | \$ 1.21 | 76,250 | \$211.82 | \$2.78 | 39 | 166 |
| May-10 | 77,160 | \$ 3,033.74 | \$ 0.03932 | 155 | \$ 216.44 | \$ 1.40 | 240 | \$ 228.35 | \$ 0.95 | 76,250 | \$211.82 | \$2.78 | 20 | 277 |
| June-10 | 125,040 | \$ 7,872.00 | \$ 0.06296 | 276 | \$1,041.39 | \$ 3.78 | 2 | \$ 36.60 | \$ 18.30 | 1,344,250 | \$4,011.24 | \$2.98 | 0 | 623 |
| July-10 | 156,240 | \$10,490.08 | \$ 0.06714 | 330 | \$1,349.15 | \$ 4.09 | 1 | \$ 35.82 | \$ 35.82 | 1,344,250 | \$4,011.24 | \$2.98 | 0 | 706 |
| August-10 | 168,840 | \$11,225.02 | \$ 0.06648 | 331 | \$1,372.82 | \$ 4.15 | 2 | \$ 36.60 | \$ 18.30 | 1,344,250 | \$4,011.24 | \$2.98 | 0 | 695 |
| September-10 | 138,480 | \$10,105.54 | \$ 0.07297 | 353 | \$1,466.20 | \$ 4.15 | 1 | \$ 38.57 | \$ 38.57 | 400,250 | \$1,276.80 | \$3.19 | 4 | 353 |
| October-10 | 82,080 | \$ 3,413.12 | \$ 0.04158 | 282 | \$ 433.66 | \$ 1.54 | 53 | \$ 83.92 | \$ 1.58 | 400,250 | \$1,276.80 | \$3.19 | 66 | 132 |
| November-10 | 85,800 | \$ 3,588.76 | \$ 0.04183 | 259 | \$ 399.17 | \$ 1.54 | 192 | \$ 263.50 | \$ 1.37 | 400,250 | \$1,276.80 | \$3.19 | 336 | 9 |
| December-10 | 93,120 | \$ 3,818.86 | \$ 0.04101 | 261 | \$ 401.79 | \$ 1.54 | 2,040 | \$ 1,722.82 | \$ 0.84 | 31,500 | \$100.49 | \$3.19 | 912 | 0 |
| Totals: | 1,313,160 | \$68,469.12 | \$ 0.05214 | 2,964 | \$7,685.68 | \$ 2.59 | 10,751 | \$ 9,298.56 | \$ 0.86 | 5,573,750 | \$16,822.31 | \$3.02 | | |

Electric Consumption Rate: \$0.05214 /kWh
 Electric Demand Rate \$2.59318 /kW
 Natural Gas Consumption Rate \$0.86 /ccf

Annual Cost/Sq.ft - Electricity: \$1.137 /sqft
 Annual Cost/Sq.ft - Gas.: \$0.139 /sqft
 Annual Cost/Sq.ft - Total: \$1.275 /sqft

Table 16 Utility Bill Analysis - Centennial Commons Recreation Center




Figure 48 Monthly Electrical Consumption - Centennial Commons Recreation Center

Figure 48 Monthly Electrical Consumption - Centennial Commons Recreation Center details the electric consumption and each month’s corresponding heating and cooling degree days. Cooling degree days (CDD) are a measure of the severity of the cooling requirements in a given locality; the more cooling degree days, the hotter the summer. Based on the graph, the electrical consumption peaks in August and the cooling degree days peak in July. This discrepancy could be due to the timing of the billing cycle.




Figure 49 Monthly Electrical Demand - Centennial Commons Recreation Center

Figure 49 Monthly Electrical Demand - Centennial Commons Recreation Center, which shows the monthly electric demand, suggests the same conclusions as the electric consumption graph. The peak months correspond to the higher cooling load required during the summer season.




Figure 50 Monthly Natural Gas Consumption - Centennial Commons Recreation Center

Figure 50 Monthly Natural Gas Consumption - Centennial Commons Recreation Center details the natural gas consumption and each month's corresponding heating degree days. Heating degree days (HDD) are a measure of the severity of the heating requirements in a given locality; the more heating degree days, the cooler the winter. Based on the graph, the gas consumption and the heating degree days peak in January.




Figure 51 Monthly Water Consumption - Centennial Commons Recreation Center

Figure 51 Monthly Water Consumption - Centennial Commons Recreation Center details the water consumption. It appears from the meter that the Heman Park Pool that is adjacent to the Centennial Commons Recreation Center is on the same meter which would explain the large spike in water usage during the summer.



1.0 LIGHTING IMPROVEMENTS

ECM-1.1: Lighting Retrofit (Annex)

Existing Conditions

The University City Annex building houses the police station and one of the city’s fire stations. These facilities are in operation 24/7. The lighting systems in the Annex consist exclusively of outdated linear fluorescents, high-pressure sodium low bays, halogen floods, and incandescent exit signs. All of these fixtures can be replaced or retrofitted to increase their performance, reduce energy consumption, and decrease fixture maintenance. Although the facilities are in use all day, many areas of the building do not have the lights on. This limits the practicality of installing lighting controls and retrofitting fixtures with the expectation of a reasonable payback in all portions of the building. For optimal return on investment, only the fixtures with reasonable paybacks should be considered for retrofit or replacement. All enclosed fixtures that are to remain should have their lenses cleaned and wiped down, as the photometrics and lumen output have been severely compromised due to dust collection and the presence of foreign matter in most cases.

Savings Summary

| Energy Consumption Savings | | | | | Energy Cost Savings | | | | Total Energy Savings | Avoided Maint. Savings | Capital Cost | SPB |
|----------------------------|----|--------|------------|------------|---------------------|-----|-------|-------|----------------------|------------------------|--------------|------|
| KWh | KW | Months | Steam klbs | Water kgal | KWh | KW | Steam | Water | | | | |
| 58,934 | 17 | 12 | - | - | \$4,037 | \$0 | \$0 | \$0 | \$4,037 | \$0 | \$64,736 | 16.0 |

Table 17 Savings Summary - ECM-1.1 Lighting Retrofit (Annex)

Physical Changes

To the occupant, there will be some visible changes. With current lamp technology and fixture design, occupants will notice more appropriate light levels with greater uniformity and increased color rendering. All suggested retrofit and replacement applications meet or exceed existing light levels for the applicable area. The maintenance staff will also notice several changes. As a result of changing incandescents to compact fluorescents, there will be a lower frequency of lamp replacements. Elimination of fixtures that are in poor operational condition, due to age or environmental degradation, will result in a safer work environment for the entire staff. Other positive changes include the removal of out-dated or obsolete technology, as well as a moderate amount of electrical savings for the facility.

Interface with Agency Equipment

Contractor shall provide all labor and material to inspect, test, and adjust the lighting and the electrical control systems affecting the given spaces to ensure the new lighting systems fulfill existing requirements, while offering a reduction in consumption, especially during peak hours.



Utility Interruptions and Site Coordination

There will be no significant utility interruptions. There will be some downtime associated with fixture replacement and retrofit, but will be strictly limited to the given area and the panel breakers involved. All work shall be coordinated with the administration and the maintenance staff.

Environmental Impacts

There are minimal environmental drawbacks and numerous benefits associated with the suggested retrofitting and replacement of the lighting in the areas outlined. The new lamps and fixtures will consume less energy, resulting in decreased demand from the reactor processes involved in power production. The new fluorescent lamps are far lower in mercury content, which is beneficial concerning disposal. The only negative impact is from the disposal of the existing lamps and fixtures, but this is negligible when compared to the positives. See Table 3 Greenhouse Gases and Other Pollutants

Salvage and Disposal

Existing equipment in operational condition shall be given to University City as requested. All remaining equipment will be removed and disposed of properly by the electrical contractor.



Individual Recommendations Per Location

The following is a summary of the individual floors and areas of the University City Annex facility, and the individual recommendations therein:

Police Station – Basement - Corridor

Energy Saving Opportunity:

- (15) 1x4, 2-lamp T12 recessed cove strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 60 hours/week. Re-lamp with (15) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.

Police Station – Basement – Break Room

Energy Saving Opportunity:

- (5) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 60 hours/week. Re-lamp with (5) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.
- (1) 2x2, 2 U-lamp T12 recessed troffer. Fixture utilizes a standard magnetic ballast. Average foot candle reading for this fixture is 15-20 fc. Fixture operates 60 hours/week. Re-lamp with (1) 2, 31W T8 U-lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.
- (1) 2-lamp 60W incandescent surface round. Average foot candle reading for this fixture is 4-7 fc. Fixture operates 1 hour/week. Re-lamp with (2) 13W compact fluorescent, screw type lamps.

Police Station – Basement – Fire Chief’s Office

Energy Saving Opportunity:

- (10) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 40-50 fc. Fixtures operate 60 hours/week. Re-lamp with (10) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.

Police Station – Basement - Corridor

Energy Saving Opportunity:

- (10) 26W compact fluorescent, triple, twin tube recessed can. Average foot candle reading for these fixtures is 4-7 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain.



- (3) Incandescent Exit Sign. Fixtures operate 168 hours/week. Replace with new (3) LED Exit Sign.

Police Station – Basement – E.O.C. Room

Energy Saving Opportunity:

- (1) 26W compact fluorescent, triple, twin tube recessed can. Average foot candle reading for this fixture is 4-7 fc. Fixture operates 10 hours/week. There are no recommendations, fixture is to remain.
- (1) 1x2, 2-lamp T12 wall mount. Fixture utilizes a standard magnetic ballast. Average foot candle reading for this fixture is 15-20 fc. Fixture operates 10 hours/week. Re-lamp with (1) 2, 17W 2' T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.
- (27) 1x4, 2-lamp T12 surface wrap. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 10 hours/week. Re-lamp with (27) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.
- (2) 1x4, 2-lamp T12 surface wrap. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 168 hours/week. Re-lamp with (2) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.

Police Station – Basement – E.O.C. Kitchen

Energy Saving Opportunity:

- (1) 2-lamp T12 strip. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 10-15 fc. Fixture operates 5 hours/week. Re-lamp with (1) 2, 28W T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.

Police Station – Basement – E.O.C. Mechanical Room

Energy Saving Opportunity:

- (2) 2-lamp T12 strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 1 hour/week. Re-lamp with (2) 2, 28W T8 lamps and high-efficiency, electronic ballasts.
- (2) 52W exposed incandescent. Average foot candle reading for these fixtures is 3-5 fc. Fixtures operate 1 hour/week. Re-lamp with (2) 13W compact fluorescent, screw type lamps.



Police Station – Basement – E.O.C.

Energy Saving Opportunity:

- (2) Incandescent Exit Sign. Fixtures operate 168 hours/week. Replace with new (2) LED Exit Sign.

Police Station – Basement – E.O.C. Communications Room

Energy Saving Opportunity:

- (3) 2-lamp T12 strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 1 hour/week. Re-lamp with (3) 2, 28W T8 lamps and high-efficiency, electronic ballasts.

Police Station – Basement – E.O.C. Storeroom

Energy Saving Opportunity:

- (5) 2-lamp T12 surface wrap. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 1 hour/week. Re-lamp with (5) 2, 28W T8 lamps and high-efficiency, electronic ballasts.

Police Station – Basement – E.O.C. Restroom

Energy Saving Opportunity:

- (2) 2-lamp T12 surface wrap. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 1 hour/week. Re-lamp with (2) 2, 28W T8 lamps and high-efficiency, electronic ballasts.

Police Station – Basement – Shooting Range

Energy Saving Opportunity:

- (6) PAR38 Halogen Flood. Average foot candle reading for these fixtures is 10-12 fc. Fixtures operate 5 hours/week. There are no recommendations, fixtures are to remain.
- (5) 52W exposed incandescent. Average foot candle reading for these fixtures is 3-5 fc. Fixtures operate 5 hours/week. Re-lamp with (5) 13W compact fluorescent, screw type lamps.

Police Station – Basement – Shooting Range File Room

Energy Saving Opportunity:

- (4) 2-lamp T12 strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 1 hour/week. Re-lamp with (4) 2, 28W T8 lamps and high-efficiency, electronic ballasts.



Police Station – Basement – Files

Energy Saving Opportunity:

- (2) 1x8, 2-lamp T12 strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 1 hour/week. Re-lamp with (2) 2, 59W, 8' T8 lamps and high-efficiency, electronic ballasts.

Police Station – Basement – Corridor

Energy Saving Opportunity:

- (2) 2-lamp T12 strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 2 hours/week. Re-lamp with (2) 2, 28W T8 lamps and high-efficiency, electronic ballasts.

Police Station – Basement – Closet

Energy Saving Opportunity:

- (1) 52W exposed incandescent. Average foot candle reading for this fixture is 3-5 fc. Fixture operates 1 hour/week. Re-lamp with (1) 13W compact fluorescent, screw type lamp.

Police Station – Basement – Weapons Storage

Energy Saving Opportunity:

- (4) 2-lamp T12 strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 30-35 fc. Fixtures operate 5 hours/week. Re-lamp with (4) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.

Police Station – Basement – Bike Storage

Energy Saving Opportunity:

- (14) 100W exposed incandescent. Average foot candle reading for these fixtures is 2-4 fc. Fixtures operate 1 hour/week. Re-lamp with (14) 26W compact fluorescent, screw type lamps.

Police Station – Basement – Stairs

Energy Saving Opportunity:

- (2) 2-lamp 60W incandescent surface mount. Average foot candle reading for these fixtures is 3-5 fc. Fixtures operate 5 hours/week. Re-lamp with (2) 13W compact fluorescent, screw type lamps.



Police Station – 1st Floor – Print Shop

Energy Saving Opportunity:

- (6) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 50-55 fc. Fixtures operate 40 hours/week. Re-lamp with (6) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.

Police Station – 1st Floor – Police Dispatch

Energy Saving Opportunity:

- (21) 2x4, 4-lamp T12 recessed volumetric. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 50-55 fc. Fixtures operate 60 hours/week. Re-lamp with (21) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.
- (10) 2x4, 4-lamp T12 recessed volumetric. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 50-55 fc. Fixtures operate 168 hours/week. Re-lamp with (10) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.

Police Station – 1st Floor – Entry Corridor

Energy Saving Opportunity:

- (8) 1x4, 1-lamp T12 wall strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 60 hours/week. Re-lamp with (8) 1, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.

Police Station – Basement – Men's Cells

Energy Saving Opportunity:

- (1) 2-lamp T12, 3' strip. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 15-20 fc. Fixture operates 84 hours/week. Re-lamp with (1) 2, 25W, 3' T8 lamps and high-efficiency, electronic ballast.
- (2) 1x4, 2-lamp T12 strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 84 hours/week. Re-lamp with (2) 2, 28W T8 lamps and high-efficiency, electronic ballasts.
- (2) PAR38 Halogen Flood. Average foot candle reading for these fixtures is 10-12 fc. Fixtures operate 84 hours/week. There are no recommendations, fixtures are to remain.
- (1) 1x4, 2-lamp T12 wall-mounted strip. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 15-20 fc. Fixture operates 84



hours/week. Re-lamp with (1) 2, 28W T8 lamps and high-efficiency, electronic ballast.

Police Station – Basement – Stairs

Energy Saving Opportunity:

- (1) 1x1, 60W incandescent surface mount. Average foot candle reading for this fixture is 3-5 fc. Fixture operates 84 hours/week. Re-lamp with (1) 13W compact fluorescent, screw type lamp.

Police Station – 1st Floor – Private Offices

Energy Saving Opportunity:

- (12) 2x4, 4-lamp T12 recessed volumetric. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 45-50 fc. Fixtures operate 60 hours/week. Re-lamp with (12) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.

Police Station – 1st Floor – Conference Room

Energy Saving Opportunity:

- (4) 2x4, 2-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 45-50 fc. Fixtures operate 60 hours/week. Re-lamp with (4) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.

Police Station – 1st Floor – Men's Locker Room

Energy Saving Opportunity:

- (6) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 60 hours/week. Re-lamp with (6) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.

Police Station – 1st Floor – Women's Locker Room

Energy Saving Opportunity:

- (4) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 60 hours/week. Re-lamp with (4) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.



Police Station – 1st Floor – Mechanical Storage

Energy Saving Opportunity:

- (3) 100W exposed incandescent. Average foot candle reading for these fixtures is 2-4 fc. Fixtures operate 1 hour/week. Re-lamp with (3) 26W compact fluorescent, screw type lamps.

Police Station – 1st Floor – Offices

Energy Saving Opportunity:

- (9) 1x4, 2-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 12-15 fc. Fixtures operate 60 hours/week. Re-lamp with (9) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.

Police Station – 1st Floor – Cell Entry

Energy Saving Opportunity:

- (6) 2x4, 2-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 50-55 fc. Fixtures operate 60 hours/week. Re-lamp with (6) 2, 28W T8 lamps and high-efficiency, electronic ballasts.
- (2) 40W recessed incandescent can. Average foot candle reading for these fixtures is 3-5 fc. Fixtures operate 60 hours/week. Re-lamp with (2) 9W compact fluorescent, screw type lamps.

Police Station – 1st Floor – Hall

Energy Saving Opportunity:

- (1) 1x1, 2-lamp 60W recessed incandescent square. Average foot candle reading for this fixture is 2-3 fc. Fixture operates 168 hours/week. Re-lamp with (1) 2, 13W compact fluorescent, screw type lamp.
- (1) PAR38 Halogen Flood. Average foot candle reading for these fixtures is 10-15 fc. Fixtures operate 168 hours/week. There are no recommendations, fixtures are to remain.

Police Station – 1st Floor – Men's Restroom

Energy Saving Opportunity:

- (4) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 60 hours/week. Re-lamp with (4) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.



Police Station – 1st Floor – Women’s Restroom

Energy Saving Opportunity:

- (4) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 60 hours/week. Re-lamp with (4) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.
- (1) 2-lamp 60W incandescent vanity. Average foot candle reading for this fixture is 2-3 fc. Fixture operates 60 hours/week. Re-lamp with (1) 2, 13W compact fluorescent, screw type lamp.

Police Station – 1st Floor – Entry

Energy Saving Opportunity:

- (9) PAR38 Halogen Flood. Average foot candle reading for these fixtures is 10-15 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain.
- (1) 2x4, 4-lamp T12 recessed volumetric. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 45-55 fc. Fixture operates 60 hours/week. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.

Police Station – 1st Floor – Field Ops

Energy Saving Opportunity:

- (2) 2x4, 4-lamp T12 recessed volumetric. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 45-55 fc. Fixtures operate 60 hours/week. Re-lamp with (2) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.
- (1) 2x4, 4-lamp T12 recessed troffer. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 50-70 fc. Fixture operates 60 hours/week. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballast. Fixtures to be controlled by dual-technology occupancy sensor.
- (1) 2x2, 2 U-lamp T12 recessed troffer. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 5-10 fc. Fixture operates 60 hours/week. Re-lamp with (1) 2, 31W T8 U-lamps and high-efficiency, electronic ballast. Fixtures to be controlled by dual-technology occupancy sensor.

Police Station – 1st Floor – Traffic

Energy Saving Opportunity:

- (3) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 60



hours/week. Re-lamp with (3) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.

- (4) 1x4, 2-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 10-20 fc. Fixtures operate 60 hours/week. Re-lamp with (4) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.

Police Station – 2nd Floor – Offices

Energy Saving Opportunity:

- (17) 2x4, 4-lamp T12 recessed volumetric. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 60 hours/week. Re-lamp with (17) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.
- (5) 2x4, 4-lamp T12 recessed volumetric. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 5 hours/week. Re-lamp with (5) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.

Police Station – 2nd Floor – Hall

Energy Saving Opportunity:

- (1) 2-lamp T12 strip. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 10-15 fc. Fixture operates 60 hours/week. Re-lamp with (1) 2, 28W T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.

Police Station – 2nd Floor – Interrogation Room

Energy Saving Opportunity:

- (6) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 10 hours/week. Re-lamp with (6) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.

Police Station – 2nd Floor – Men's Restroom

Energy Saving Opportunity:

- (1) 2x4, 4-lamp T12 recessed troffer. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 20-25 fc. Fixture operates 60 hours/week. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.



Police Station – 2nd Floor – Women’s Restroom

Energy Saving Opportunity:

- (1) 2x4, 4-lamp T12 recessed troffer. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 20-25 fc. Fixture operates 60 hours/week. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.

Police Station – 2nd Floor – Entry

Energy Saving Opportunity:

- (6) 2-lamp T12 strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 30-35 fc. Fixtures operate 168 hours/week. Re-lamp with (6) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.

Police Station – 2nd Floor – Narcotics Evidence Room

Energy Saving Opportunity:

- (8) 2-lamp T12 strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 30-35 fc. Fixtures operate 10 hours/week. Re-lamp with (8) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.

Police Station – 2nd Floor – Entry

Energy Saving Opportunity:

- (2) Incandescent Exit Sign. Fixtures operate 168 hours/week. Replace with new (2) LED Exit Sign.

Police Station – 2nd Floor – Homicide Evidence Room

Energy Saving Opportunity:

- (4) 2x4, 4-lamp T12 recessed volumetric. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 45-55 fc. Fixtures operate 10 hours/week. Re-lamp with (4) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.

Police Station – 2nd Floor – Lobby

Energy Saving Opportunity:

- (5) 1x2, 2-lamp T12 wall mount. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 10-15 fc. Fixtures operate 60



hours/week. Re-lamp with (5) 2,17W 2' T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.

Police Station – 3rd Floor – Offices

Energy Saving Opportunity:

- (17) 2x4, 4-lamp T12 recessed volumetric. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-50 fc. Fixtures operate 60 hours/week. Re-lamp with (17) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.

Police Station – 3rd Floor – Mechanical Room

Energy Saving Opportunity:

- (4) 2x4, 2-lamp T12 parabolic strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 10-20 fc. Fixtures operate 2 hours/week. Re-lamp with (4) 2, 28W T8 lamps and high-efficiency, electronic ballasts.

Police Station – 3rd Floor – Offices

Energy Saving Opportunity:

- (2) Incandescent Exit Sign. Fixtures operate 168 hours/week. Replace with new (2) LED Exit Sign.

Police Station – 3rd Floor – Stairs

Energy Saving Opportunity:

- (2) 1x4, 2-lamp T12 parabolic strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 1-2 fc. Fixtures operate 60 hours/week. Re-lamp with (2) 2, 28W T8 lamps and high-efficiency, electronic ballasts.

Police Station – 3rd Floor – Restroom

Energy Saving Opportunity:

- (1) 2x4, 4-lamp T12 recessed troffer. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 50-60 fc. Fixture operates 60 hours/week. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballast. Fixtures to be controlled by dual-technology occupancy sensor.



Police Station – 3rd Floor – Elevator Lobby

Energy Saving Opportunity:

- (1) 2x2, 2 U-lamp T12 recessed troffer. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 10-15 fc. Fixture operates 60 hours/week. Re-lamp with (1) 2, 31W T8 U-lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.

Police Station – Exterior Entry

Energy Saving Opportunity:

- (2) 1x1, 60W incandescent surface square. Average foot candle reading for these fixtures is 3-5 fc. Fixtures operate 84 hours/week. Re-lamp with (2) 9W compact fluorescent, screw type lamps.

Fire Station – 1st Floor – Apparatus Bay

Energy Saving Opportunity:

- (6) 400W, High-Pressure Sodium low bay. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 30-35 fc. Fixtures operate 60hours/week. Fixtures to be demolished and replaced with (7) 4-lamp T5HO High-bays, with electronic ballasts. Fixtures to be controlled by integrated occupancy sensors in fixture.
- (1) 250W, Mercury Vapor wall mount. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 10-15 fc. Fixture operates 60 hours/week. Fixture to be demolished.
- (3) 2-lamp T8 strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 15-25 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain.

Fire Station – 1st Floor – Office

Energy Saving Opportunity:

- (4) 1x4, 2-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 10-20 fc. Fixtures operate 60 hours/week. Re-lamp with (4) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.



Fire Station – 1st Floor – Stairs

Energy Saving Opportunity:

- (1) 100W exposed incandescent. Average foot candle reading for this fixture is 1-2 fc. Fixture operates 1 hour/week. Re-lamp with (1) 26W compact fluorescent, screw type lamp.

Fire Station – 1st Floor – Mechanical Room

Energy Saving Opportunity:

- (2) 100W exposed incandescent. Average foot candle reading for these fixtures is 1-2 fc. Fixtures operate 1 hour/week. Re-lamp with (2) 26W compact fluorescent, screw type lamps.

Fire Station – 1st Floor – Corridor

Energy Saving Opportunity:

- (1) 2-lamp, 60W incandescent surface square. Average foot candle reading for this fixture is 1-2 fc. Fixture operates 1 hour/week. Re-lamp with (1) 2, 13W compact fluorescent, screw type lamps.

Fire Station – 1st Floor – Store Room

Energy Saving Opportunity:

- (4) 100W exposed incandescent. Average foot candle reading for these fixtures is 1-2 fc. Fixtures operate 1 hour/week. Re-lamp with (4) 26W compact fluorescent, screw type lamps.

Fire Station – 1st Floor – Kitchen

Energy Saving Opportunity:

- (2) 2-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-25 fc. Fixtures operate 60 hours/week. Re-lamp with (2) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.
- (1) 1-lamp, 3' T8 strip. Fixture utilizes electronic ballast. Average foot candle reading for this fixture is 20-25 fc. Fixture operates 60 hours/week. There are no recommendations, fixture is to remain.



Fire Station – 1st Floor – Break Room

Energy Saving Opportunity:

- (2) 4-lamp 13W CFL Ceiling Fan. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 5-10 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain.

Fire Station – 2nd Floor – Restroom

Energy Saving Opportunity:

- (2) 1x1, 60W incandescent recessed square. Average foot candle reading for these fixtures is 10-12 fc. Fixtures operate 20 hours/week. Re-lamp with (2) 9W compact fluorescent, screw type lamps.

Fire Station – 2nd Floor – Showers

Energy Saving Opportunity:

- (2) 60W recessed incandescent can. Average foot candle reading for these fixtures is 5-7 fc. Fixtures operate 20 hours/week. Re-lamp with (2) 13W compact fluorescent, screw type lamps.

Fire Station – 2nd Floor – Sleep Area

Energy Saving Opportunity:

- (9) 1x2, 2-lamp T12 surface wrap. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 3-5 fc. Fixtures operate 80 hours/week. Re-lamp with (9) 2, 17W 2' T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.

Fire Station – 2nd Floor – Weight Room

Energy Saving Opportunity:

- (8) 1x4, 2-lamp T12 surface wrap. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 20 hours/week. Re-lamp with (8) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.

Fire Station – 2nd Floor – Media Room

Energy Saving Opportunity:

- (4) 1x4, 2-lamp T12 surface wrap. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 10 hours/week. Re-lamp with (4) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.



Fire Station – 2nd Floor – Restroom

Energy Saving Opportunity:

- (2) 1x4, 2-lamp T12 surface vanity. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 40-45 fc. Fixtures operate 80 hours/week. Re-lamp with (2) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.
- (1) 2x4, 4-lamp T12 recessed troffer. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 30-35 fc. Fixture operates 80 hours/week. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.

Fire Station – 2nd Floor – Storage

Energy Saving Opportunity:

- (1) 90W exposed incandescent. Average foot candle reading for this fixture is 2-5 fc. Fixture operates 1 hour/week. Re-lamp with (1) 26W compact fluorescent, screw type lamp.

Fire Station – 2nd Floor – Sleep Room

Energy Saving Opportunity:

- (1) 4-lamp 52W incandescent ceiling fan. Average foot candle reading for this fixture is 5-10 fc. Fixture operates 5 hours/week. Re-lamp with (1) 4, 13W compact fluorescent, screw type lamps.

Fire Station – 2nd Floor – Stairs

Energy Saving Opportunity:

- (2) Incandescent Exit Sign. Fixtures operate 168 hours/week. Replace with new (2) LED Exit Sign.
- (2) 2-lamp T12 wall strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 10-15 fc. Fixtures operate 10 hours/week. Re-lamp with (2) 2, 28W T8 lamps and high-efficiency, electronic ballasts.
- (1) 1-lamp T12 wall strip. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 10-15 fc. Fixture operates 80 hours/week. Re-lamp with (1) 1, 28W T8 lamps and high-efficiency, electronic ballast.



ECM-1.2: Lighting Retrofit (City Hall)

Existing Conditions

The University City, City Hall building houses the mayor’s office, finance department, engineering services, permits, administration, and the courthouse. The building recently underwent a substantial energy efficiency renovation in 2006. The building’s lights are now controlled by a time clock that turns the lights on at 6:30 AM and turns them off at 11:30 PM, Monday through Friday. The lighting systems in City Hall consist primarily of T8 linear fluorescents, compact fluorescents, halogen track lights, and LED exit signs. The remaining T12, magnetically-ballasted fixtures, and incandescent lamps can be retrofitted to bring the building’s lighting system fully up-to-date. There are also select areas and offices where occupancy sensing, lighting controls should be installed. This will save energy by turning off the lights in unoccupied spaces before the occupant arrives and after the occupant leaves the space each day. All enclosed fixtures that are to remain should have their lenses cleaned and wiped down, as the photometrics and lumen output have been severely compromised due to dust collection and the presence of foreign matter in most cases.

Savings Summary

| Energy Consumption Savings | | | | | Energy Cost Savings | | | | Total Energy Savings | Avoided Maint. Savings | Capital Cost | SPB |
|----------------------------|----|--------|------------|------------|---------------------|-----|-------|-------|----------------------|------------------------|--------------|------|
| KWh | KW | Months | Steam klbs | Water kgal | KWh | KW | Steam | Water | | | | |
| 12,081 | 6 | 12 | - | - | \$828 | \$0 | \$0 | \$0 | \$828 | \$0 | \$21,723 | 23.5 |

Table 18 Savings Summary - ECM-1.2 Lighting Retrofit (City Hall)

Physical Changes

To the occupant, there will be minimal visible changes. With current lamp technology and fixture design, occupants will notice more appropriate light levels with greater uniformity and increased color rendering in the selected retrofit areas. All suggested retrofit and replacement applications meet or exceed existing light levels for the applicable area. The maintenance staff will also notice slight changes. As a result of changing incandescents to compact fluorescents, there will be a lower frequency of lamp replacements. Elimination of fixtures that are in poor operational condition, due to age or environmental degradation, will result in a safer work environment for the entire staff. Other positive changes include the removal of out-dated or obsolete technology, as well as a moderate amount of electrical savings for the facility.

Interface with Agency Equipment

Contractor shall provide all labor and material to inspect, test, and adjust the lighting and the electrical control systems affecting the given spaces to ensure the new lighting systems fulfill existing requirements, while offering a reduction in consumption, especially during peak hours.



Utility Interruptions and Site Coordination

There will be no significant utility interruptions. There will be some downtime associated with fixture replacement and retrofit, but will be strictly limited to the given area and the panel breakers involved. All work shall be coordinated with the administration and the maintenance staff.

Environmental Impacts

There are minimal environmental drawbacks and numerous benefits associated with the suggested retrofitting and replacement of the lighting in the areas outlined. The new lamps and fixtures will consume less energy, resulting in decreased demand from the reactor processes involved in power production. The new fluorescent lamps are far lower in mercury content, which is beneficial concerning disposal. The only negative impact is from the disposal of the existing lamps and fixtures, but this is negligible when compared to the positives. See Table 3 Greenhouse Gases and Other Pollutants

Salvage and Disposal

Existing equipment in operational condition shall be given to University City as requested. All remaining equipment will be removed and disposed of properly by the electrical contractor.



Individual Recommendations Per Location

The following is a summary of the individual floors and areas of the University City, City Hall building and the individual recommendations therein:

City Hall - Elevator

Energy Saving Opportunity:

- (6) MR16 20W Halogen Can. Average foot candle reading for these fixtures is 5-8 fc. Fixtures operate 85 hours/week. There are no recommendations, fixtures are to remain.

City Hall – 5th Floor - Courtroom

Energy Saving Opportunity:

- (21) PAR38 Halogen Flood. Average foot candle reading for these fixtures is 10-15 fc. Fixtures operate 8 hours/week. There are no recommendations, fixtures are to remain.
- (6) 26W CFL Decorative Wall Torch. Average foot candle reading for these fixtures is 5-7 fc. Fixtures operate 8 hours/week. There are no recommendations, fixtures are to remain.
- (16) 2-lamp T8 cove strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 8 hours/week. There are no recommendations, fixtures are to remain.
- (3) Incandescent Exit Sign. Fixtures operate 168 hours/week. Replace with new (3) LED Exit Sign.

City Hall – 5th Floor – Courtroom Storage

Energy Saving Opportunity:

- (2) 2-lamp T8 strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 1 hour/week. There are no recommendations, fixtures are to remain.

City Hall – 5th Floor - Courtroom

Energy Saving Opportunity:

- (1) 16-lamp 40W incandescent decorative chandelier. Average foot candle reading for this fixture is 20-25 fc. Fixture operates 8 hours/week. Re-lamp with (16) 13W compact fluorescent, screw type lamps.



- (1) 9-lamp, 13W CFL Decorative Chandelier. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 8 hours/week. There are no recommendations, fixtures are to remain.

City Hall – 5th Floor - Elevator Lobby

Energy Saving Opportunity:

- (1) 100W exposed incandescent pendant. Average foot candle reading for this fixture is 3-5 fc. Fixture operates 8 hours/week. Re-lamp with (1) 26W compact fluorescent, screw type lamp.

City Hall – 5th Floor - Penthouse

Energy Saving Opportunity:

- (8) 13W Exposed CFL Screw-Type Lamp. Average foot candle reading for these fixtures is 3-5 fc. Fixtures operate 1 hour/week. There are no recommendations, fixtures are to remain.
- (4) 2-lamp T8 strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 30-35 fc. Fixtures operate 1 hour/week. There are no recommendations, fixtures are to remain.

City Hall – 4th Floor – Women’s Restroom

Energy Saving Opportunity:

- (3) 2-lamp T8 vanity strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 5-30 fc. Fixtures operate 85 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.
- (1) 13W CFL Wall Sconce. Average foot candle reading for this fixture is 5-6 fc. Fixture operates 85 hours/week. There are no recommendations, fixture is to remain.

City Hall – 4th Floor - Elevator Lobby

Energy Saving Opportunity:

- (1) 2-lamp, 13W Decorative CFL Wall Sconce. Average foot candle reading for this fixture is 3-5 fc. Fixture operates 1 hour/week. There are no recommendations, fixture is to remain.



City Hall – 4th Floor – Engineering Offices

Energy Saving Opportunity:

- (21) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 60 hours/week. Re-lamp with (21) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.
- (9) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 20 hours/week. Re-lamp with (9) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.
- (19) 2x4, 4-lamp, 25W T8 recessed troffer. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 90-105 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensors.
- (5) Incandescent Exit Sign. Fixtures operate 168 hours/week. Replace with new (5) LED Exit Sign.

City Hall – 4th Floor – Engineering Office Conference Room

Energy Saving Opportunity:

- (6) 2-lamp T12 above ceiling strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 5-10 fc. Fixtures operate 5 hours/week. Re-lamp with (6) 2, 28W T8 lamps and high-efficiency, electronic ballasts.
- (1) 4-lamp, 13W CFL Ceiling Fan. Average foot candle reading for this fixture is 5-10 fc. Fixture operates 5 hours/week. There are no recommendations, fixture is to remain.

City Hall – 4th Floor – Engineering Office File Room

Energy Saving Opportunity:

- (3) 3-lamp, T8 pendant wrap. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 50-60 fc. Fixtures operate 5 hours/week. There are no recommendations, fixtures are to remain.

City Hall – 4th Floor – Engineering Office File Room Corridor

Energy Saving Opportunity:

- (1) 2-lamp, 75W T12 8' parabolic pendant. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 5-10 fc. Fixture operates 5 hours/week. Re-lamp with (1) 2, 59W, 8' T8 lamps and high-efficiency, electronic ballast.



City Hall – 3rd Floor – Men’s Restroom

Energy Saving Opportunity:

- (3) 2-lamp T8 vanity strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 5-30 fc. Fixtures operate 85 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.
- (1) 13W CFL Wall Sconce. Average foot candle reading for this fixture is 5-6 fc. Fixture operates 85 hours/week. There are no recommendations, fixture is to remain.

City Hall – 3rd Floor – Elevator Lobby

Energy Saving Opportunity:

- (1) 2-lamp, 13W Decorative CFL Wall Sconce. Average foot candle reading for this fixture is 3-5 fc. Fixture operates 85 hour/week. There are no recommendations, fixture is to remain.
- (1) Incandescent Exit Sign. Fixture operates 168 hours/week. Replace with new (1) LED Exit Sign.

City Hall – 3rd Floor – Private Offices

Energy Saving Opportunity:

- (17) 1x4, 2-lamp T8 direct/indirect pendant. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensors.
- (19) 1x4, 2-lamp T8 direct/indirect pendant. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 10 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensors.

City Hall – 3rd Floor – Storage Vault

Energy Saving Opportunity:

- (1) 90W exposed incandescent pendant. Average foot candle reading for this fixture is 3-5 fc. Fixture operates 1 hour/week. Re-lamp with (1) 26W compact fluorescent, screw type lamp.

City Hall – 3rd Floor – Conference Room

Energy Saving Opportunity:

- (6) 1x4, 2-lamp T8 direct/indirect pendant. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 40



hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.

City Hall – 3rd Floor – Open Offices

Energy Saving Opportunity:

- (27) 1x4, 2-lamp T8 direct/indirect pendant. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensors.

City Hall – 3rd Floor – Private Offices

Energy Saving Opportunity:

- (1) 3-lamp, 60W incandescent ceiling fan. Average foot candle reading for this fixture is 5-10 fc. Fixture operates 60 hours/week. Re-lamp with (3) 13W compact fluorescent, screw type lamps.

City Hall – 3rd Floor – Open Offices

Energy Saving Opportunity:

- (1) LED Exit Sign. Fixture operates 168 hours/week. There are no recommendations, fixture is to remain.

City Hall – 3rd Floor – Private Offices

Energy Saving Opportunity:

- (3) 1-lamp 22W Circline Ceiling Fan. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 2 hours/week. There are no recommendations, fixtures are to remain.
- (2) LED Exit Sign. Fixtures operate 168 hours/week. There are no recommendations, fixtures are to remain.
- (10) 2x4, 4-lamp T8 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 35-40 fc. Fixtures operate 5 hours/week. Re-lamp with (10) 4, 25W T8 lamps and high-efficiency, electronic ballasts.

City Hall – 2nd Floor – Women's Restroom

Energy Saving Opportunity:

- (3) 2-lamp T8 vanity strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 5-30 fc. Fixtures operate 85 hours/week. There are no



recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.

- (1) 13W CFL Wall Sconce. Average foot candle reading for this fixture is 5-6 fc. Fixture operates 85 hours/week. There are no recommendations, fixture is to remain.

City Hall – 2nd Floor – Elevator Lobby

Energy Saving Opportunity:

- (1) 2-lamp, 13W Decorative CFL Wall Sconce. Average foot candle reading for this fixture is 3-5 fc. Fixture operates 1 hour/week. There are no recommendations, fixture is to remain.

City Hall – 2nd Floor – Center Rotunda

Energy Saving Opportunity:

- (8) 9W CFL 4-lamp decorative torches. Average foot candle reading for these fixtures is 3-5 fc. Fixtures operate 85 hours/week. There are no recommendations, fixtures are to remain.
- (2) LED Exit Sign. Fixtures operate 168 hours/week. There are no recommendations, fixtures are to remain.
- (1) 12-lamp, 25W Incandescent Decorative Chandelier. Average foot candle reading for these fixtures is 3-5 fc. Fixtures operate 85 hours/week. There are no recommendations, fixtures are to remain.
- (1) 14-lamp, 25W Incandescent Decorative Chandelier. Average foot candle reading for these fixtures is 3-5 fc. Fixtures operate 85 hours/week. There are no recommendations, fixtures are to remain.

City Hall – 2nd Floor – City Clerk

Energy Saving Opportunity:

- (5) 1x4, 2-lamp T8 direct/indirect pendant. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.
- (2) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 60 hours/week. Re-lamp with (2) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.



City Hall – 2nd Floor – Mayor

Energy Saving Opportunity:

- (2) 90W exposed incandescent pendant. Average foot candle reading for these fixtures is 2-3 fc. Fixtures operate 1 hour/week. Re-lamp with (2) 26W compact fluorescent, screw type lamps.
- (9) PAR38 Halogen Flood. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain.
- (4) 40W incandescent wall torches. Average foot candle reading for these fixtures is 8-10 fc. Fixtures operate 60 hours/week. Re-lamp with (4) 9W compact fluorescent, screw type lamps.
- (2) 2-lamp T5 task strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 3-7 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.

City Hall – 2nd Floor – Mayor’s Restroom

Energy Saving Opportunity:

- (8) 13W CFL 3-lamp decorative torches. Average foot candle reading for these fixtures is 5-10 fc. Fixtures operate 1 hour/week. There are no recommendations, fixtures are to remain.
- (1) 52W exposed incandescent. Average foot candle reading for this fixture is 3-5 fc. Fixture operates 1 hour/week. Re-lamp with (1) 13W compact fluorescent, screw type lamps.

City Hall – 2nd Floor – Mayor’s Fireplace

Energy Saving Opportunity:

- (1) 4-lamp 60W decorative incandescent surface mount. Average foot candle reading for this fixture is 5-10 fc. Fixture operates 1 hour/week. Re-lamp with (1) 13W compact fluorescent, screw type lamps.

City Hall – 2nd Floor – Administrative Office 7

Energy Saving Opportunity:

- (6) 1x4, 2-lamp T8 direct/indirect pendant. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.



City Hall – 2nd Floor – Administrative Office 8

Energy Saving Opportunity:

- (6) 1x4, 2-lamp T8 direct/indirect pendant. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.

City Hall – 2nd Floor – Storage Closets

Energy Saving Opportunity:

- (3) 60W exposed incandescent pendant. Average foot candle reading for these fixtures is 2-3 fc. Fixtures operate 1 hour/week. Re-lamp with (3) 13W compact fluorescent, screw type lamps.

City Hall – 2nd Floor – Conference Room

Energy Saving Opportunity:

- (3) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 30-40 fc. Fixtures operate 10 hours/week. Re-lamp with (3) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.
- (2) 2-lamp T8 vanity strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 5-30 fc. Fixtures operate 1 hour/week. There are no recommendations, fixtures are to remain.

City Hall – 1st Floor – Men's Restroom

Energy Saving Opportunity:

- (3) 2-lamp T8 vanity strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 5-30 fc. Fixtures operate 85 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.
- (1) 13W CFL Wall Sconce. Average foot candle reading for this fixture is 5-6 fc. Fixture operates 85 hours/week. There are no recommendations, fixture is to remain.

City Hall – 1st Floor – Elevator Lobby

Energy Saving Opportunity:

- (1) 2-lamp, 60W decorative incandescent wall sconce. Average foot candle reading for this fixture is 2-3 fc. Fixture operates 1 hour/week. Re-lamp with (2) 13W compact fluorescent, screw type lamps.



City Hall – 1st Floor – Lobby

Energy Saving Opportunity:

- (36) 2-lamp, 13W CFL decorative torches. Average foot candle reading for these fixtures is 8-10 fc. Fixtures operate 85 hours/week. There are no recommendations, fixtures are to remain.
- (4) LED Exit Sign. Fixtures operate 168 hours/week. There are no recommendations, fixtures are to remain.
- (7) 15W Incandescent statue lights. Average foot candle reading for these fixtures is 1-2 fc. Fixtures operate 85 hours/week. There are no recommendations, fixtures are to remain.
- (4) 5-lamp, Decorative Incandescent Candleabra. Average foot candle reading for these fixtures is 2-3 fc. Fixtures operate 85 hours/week. There are no recommendations, fixtures are to remain.

City Hall – 1st Floor – Offices

Energy Saving Opportunity:

- (42) 1x4, 2-lamp T8 direct/indirect pendant. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensors.

City Hall – 1st Floor – Vault Closet

Energy Saving Opportunity:

- (3) 90W exposed incandescent pendant. Average foot candle reading for these fixtures is 2-3 fc. Fixtures operate 1 hour/week. Re-lamp with (3) 26W compact fluorescent, screw type lamps.
- (1) 13W CFL Exposed Lamp. Average foot candle reading for this fixture is 5-6 fc. Fixture operates 1 hour/week. There are no recommendations, fixture is to remain.

City Hall – 1st Floor – Offices

Energy Saving Opportunity:

- (4) 1x4, 2-lamp T8 direct/indirect pendant. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.



City Hall – 1st Floor – Sink Closet

Energy Saving Opportunity:

- (3) 52W exposed incandescent pendant. Average foot candle reading for these fixtures is 2-3 fc. Fixtures operate 1 hour/week. Re-lamp with (3) 13W compact fluorescent, screw type lamps.

City Hall – Basement - Stairs

Energy Saving Opportunity:

- (11) MR16, 50W Halogen Track Light. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 85 hours/week. There are no recommendations, fixtures are to remain.
- (2) LED Exit Sign. Fixtures operate 168 hours/week. There are no recommendations, fixtures are to remain.
- (1) Incandescent Exit Sign. Fixture operates 168 hours/week. Replace with new (1) LED Exit Sign.
- (8) 13W CFL wall sconce. Average foot candle reading for these fixtures is 5-6 fc. Fixtures operate 168 hours/week. There are no recommendations, fixtures are to remain.

City Hall – Basement - Shops

Energy Saving Opportunity:

- (2) 2-lamp T8 damp-location strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.
- (1) LED Exit Sign. Fixtures operate 168 hours/week. There are no recommendations, fixture is to remain.

City Hall – Basement – Mechanical Room

Energy Saving Opportunity:

- (2) 2-lamp T8 damp-location pendant. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 2 hours/week. There are no recommendations, fixtures are to remain.



City Hall – Basement – Electrical Room

Energy Saving Opportunity:

- (2) 2-lamp T8 damp-location pendant. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 2 hours/week. There are no recommendations, fixtures are to remain.

City Hall – Basement – Closet

Energy Saving Opportunity:

- (9) 90W exposed incandescent pendant. Average foot candle reading for these fixtures is 5-7 fc. Fixtures operate 1 hour/week. Re-lamp with (9) 26W compact fluorescent, screw type lamps.

City Hall – Basement – File Room

Energy Saving Opportunity:

- (7) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-30 fc. Fixtures operate 2 hours/week. Re-lamp with (7) 4, 25W T8 lamps and high-efficiency, electronic ballasts.
- (6) 2-lamp T12 strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 10-15 fc. Fixtures operate 2 hours/week. Re-lamp with (6) 2, 28W T8 lamps and high-efficiency, electronic ballasts.

City Hall – Basement – Shops

Energy Saving Opportunity:

- (2) 2-lamp T12 surface wrap. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-30 fc. Fixtures operate 60 hours/week. Re-lamp with (2) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.
- (8) 2-lamp T12 surface wrap. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 60 hours/week. Re-lamp with (8) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.



ECM-1.3: Lighting Retrofit (Community Center)

Existing Conditions

The University City Community Center is now in use as a senior citizen’s center. The building is occupied for a limited number of hours each week. The lighting systems in the community center consist primarily of T8 and T12 linear fluorescents, compact fluorescents, exposed incandescents and incandescent exit signs. The T12, magnetically-ballasted fixtures, and incandescent lamps can be retrofitted to modernize the building’s lighting system. There are also select areas and offices where occupancy sensing, lighting controls should be installed. This will save energy by turning off the lights in unoccupied spaces that are accidentally left on after the occupant leaves the space. Unfortunately, due to the limited number of fixture burn hours, these upgrades do not offer a reasonable, financial payback. All enclosed fixtures that are to remain should have their lenses cleaned and wiped down, as the photometrics and lumen output have been severely compromised due to dust collection and the presence of foreign matter in most cases.

Savings Summary

| Energy Consumption Savings | | | | | Energy Cost Savings | | | | Total Energy Savings | Avoided Maint. Savings | Capital Cost | SPB |
|----------------------------|----|--------|------------|------------|---------------------|-----|-------|-------|----------------------|------------------------|--------------|-----|
| KWh | KW | Months | Steam klbs | Water kgal | KWh | KW | Steam | Water | | | | |
| 5,502 | 4 | 12 | - | - | \$377 | \$0 | \$0 | \$0 | \$377 | \$0 | \$2,249 | 5.3 |

Table 19 Savings Summary - ECM 1.3 Lighting Retrofit (Community Center)

Physical Changes

To the occupant, there will be slight visible changes. With current lamp technology and fixture design, occupants will notice more appropriate light levels with greater uniformity and increased color rendering in the selected retrofit areas. All suggested retrofit and replacement applications meet or exceed existing light levels for the applicable area. The maintenance staff will also notice slight changes. As a result of changing incandescents to compact fluorescents, there will be a lower frequency of lamp replacements. Elimination of fixtures that are in poor operational condition, due to age or environmental degradation, will result in a safer work environment for the entire staff. Other positive changes include the removal of out-dated or obsolete technology, as well as a moderate amount of electrical savings for the facility.

Interface with Agency Equipment

Contractor shall provide all labor and material to inspect, test, and adjust the lighting and the electrical control systems affecting the given spaces to ensure the new lighting systems fulfill existing requirements, while offering a reduction in consumption, especially during peak hours.



Utility Interruptions and Site Coordination

There will be no significant utility interruptions. There will be some downtime associated with fixture replacement and retrofit, but will be strictly limited to the given area and the panel breakers involved. All work shall be coordinated with the administration and the maintenance staff.

Environmental Impacts

There are minimal environmental drawbacks and numerous benefits associated with the suggested retrofitting and replacement of the lighting in the areas outlined. The new lamps and fixtures will consume less energy, resulting in decreased demand from the reactor processes involved in power production. The new fluorescent lamps are far lower in mercury content, which is beneficial concerning disposal. The only negative impact is from the disposal of the existing lamps and fixtures, but this is negligible when compared to the positives. See Table 3 Greenhouse Gases and Other Pollutants

Salvage and Disposal

Existing equipment in operational condition shall be given to University City as requested. All remaining equipment will be removed and disposed of properly by the electrical contractor.



Individual Recommendations Per Location

The following is a summary of the individual floors and areas of the University City Community Center building and the individual recommendations therein:

Community Center – Conference Room / Stage

Energy Saving Opportunity:

- (4) 2x4, 4-lamp T8 recessed troffer. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 20 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensors.
- (16) 2x4, 4-lamp T8 recessed troffer. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 10 hours/month. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.
- (16) PAR38 Halogen Flood. Average foot candle reading for these fixtures is 1-30 fc. Fixtures operate 2 hours/week. There are no recommendations, fixtures are to remain.
- (2) Incandescent Exit Sign. Fixtures operate 168 hours/week. Replace with new (2) LED Exit Sign.

Community Center – Store Room

Energy Saving Opportunity:

- (7) 100W recessed incandescent square. Average foot candle reading for these fixtures is 5-7 fc. Fixtures operate 1 hour/week. Re-lamp with (7) 26W compact fluorescent, screw type lamps.
- (1) 200W exposed incandescent. Average foot candle reading for this fixture is 7-9 fc. Fixture operates 2 hour/week. Re-lamp with (1) 59W compact fluorescent, screw type lamps.

Community Center – Kitchen

Energy Saving Opportunity:

- (3) Incandescent Exit Sign. Fixtures operate 168 hours/week. Replace with new (3) LED Exit Sign.
- (8) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-30 fc. Fixtures operate 5 hours/month. Re-lamp with (8) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.



Community Center – Hall

Energy Saving Opportunity:

- (2) 2-lamp, 60W incandescent surface round. Average foot candle reading for this fixture is 7-9 fc. Fixture operates 20 hours/week. Re-lamp with (4) 13W compact fluorescent, screw type lamps.

Community Center – Men’s Restroom

Energy Saving Opportunity:

- (4) 2-lamp, 60W recessed incandescent square. Average foot candle reading for this fixture is 7-9 fc. Fixture operates 20 hours/week. Re-lamp with (8) 13W compact fluorescent, screw type lamps.

Community Center – Women’s Restroom

Energy Saving Opportunity:

- (4) 2-lamp, 60W recessed incandescent square. Average foot candle reading for this fixture is 7-9 fc. Fixture operates 20 hours/week. Re-lamp with (8) 13W compact fluorescent, screw type lamps.

Community Center – Janitor’s Closet

Energy Saving Opportunity:

- (1) 100W exposed incandescent. Average foot candle reading for these fixtures is 5-7 fc. Fixtures operate 1 hour/month. Re-lamp with (1) 26W compact fluorescent, screw type lamps.

Community Center – Dining Hall

Energy Saving Opportunity:

- (20) 2x4, 4-lamp T8 recessed troffer. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 15-25 fc. Fixtures operate 20 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensors.

Community Center – Mechanical Room

Energy Saving Opportunity:

- (3) 200W exposed incandescent. Average foot candle reading for these fixtures is 7-9 fc. Fixtures operate 1 hour/month. Re-lamp with (3) 59W compact fluorescent, screw type lamps.



Community Center – Office / Storage

Energy Saving Opportunity:

- (1) 200W exposed incandescent. Average foot candle reading for this fixture is 7-9 fc. Fixture operates 1 hour/month. Re-lamp with (1) 59W compact fluorescent, screw type lamp.
- (1) 2-lamp T12 strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 10-15 fc. Fixtures operate 5 hours/week. Re-lamp with (1) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixture to be controlled by dual-technology occupancy sensor.
- (2) 2-lamp T8 surface wrap. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 40-45 fc. Fixtures operate 5 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.

Community Center – Dining Hall

Energy Saving Opportunity:

- (2) Incandescent Exit Sign. Fixtures operate 168 hours/week. Replace with new (2) LED Exit Sign.
- (16) PAR38 Halogen Flood. Average foot candle reading for these fixtures is 1-30 fc. Fixtures operate 1 hour/month. There are no recommendations, fixtures are to remain.

Community Center – Entry

Energy Saving Opportunity:

- (3) PAR38 23W CFL Flood. Average foot candle reading for these fixtures is 1-30 fc. Fixtures operate 2 hours/week. There are no recommendations, fixtures are to remain.
- (1) PAR38 Halogen Flood. Average foot candle reading for this fixture is 1-30 fc. Fixture operates 2 hours/month. There are no recommendations, fixture is to remain.

Community Center – Office

Energy Saving Opportunity:

- (1) 2x4, 4-lamp T12 recessed troffer. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 15-20 fc. Fixture operates 20 hours/month. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.



Detailed Energy Study University City Municipal Buildings

- (1) 2x4, 4-lamp T12 recessed troffer. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 15-20 fc. Fixture operates 5 hours/month. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.



ECM-1.4: Lighting Retrofit (Fire Station #2)

Existing Conditions

The University City Fire Station #2 is a combination of a building constructed in the 1930s, and an addition that occurred a few years ago. The lighting system in the building consist is completely modernized and there are no recommendations for retrofits other than the ceiling fans with incandescent lamps. Occupancy sensors are present in many areas, but should be installed in the sleep rooms for further energy savings.

Savings Summary

| Energy Consumption Savings | | | | | Energy Cost Savings | | | | Total Energy Savings | Avoided Maint. Savings | Capital Cost | SPB |
|----------------------------|----|--------|------------|------------|---------------------|-----|-------|-------|----------------------|------------------------|--------------|------|
| KWh | KW | Months | Steam klbs | Water kgal | KWh | KW | Steam | Water | | | | |
| 5,448 | - | - | - | - | \$373 | \$0 | \$0 | \$0 | \$373 | \$0 | \$5,829 | 14.4 |

Table 20 Savings Summary - ECM-1.4 Lighting Retrofit (Fire Station #2)

Physical Changes

To the occupant, there will be no noticeable visible changes.

Interface with Agency Equipment

Contractor shall provide all labor and material to inspect, test, and adjust the lighting and the electrical control systems affecting the given spaces to ensure the new lighting systems fulfill existing requirements, while offering a reduction in consumption, especially during peak hours.

Utility Interruptions and Site Coordination

There will be no significant utility interruptions. There will be some downtime associated with fixture replacement and retrofit, but will be strictly limited to the given area and the panel breakers involved. All work shall be coordinated with the administration and the maintenance staff.

Environmental Impacts

There are minimal environmental drawbacks and numerous benefits associated with the suggested retrofitting and replacement of the lighting in the areas outlined. The new lamps and fixtures will consume less energy, resulting in decreased demand from the reactor processes involved in power production. The new fluorescent lamps are far lower in mercury content, which is beneficial concerning disposal. The only negative impact is from the disposal of the existing lamps and fixtures, but this is negligible when compared to the positives. See Table 3 Greenhouse Gases and Other Pollutants



Salvage and Disposal

Existing equipment in operational condition shall be given to University City as requested. All remaining equipment will be removed and disposed of properly by the electrical contractor.



Individual Recommendations Per Location

The following is a summary of the individual floors and areas of the University City Fire Station #2 building and the individual recommendations therein:

Fire Station #2 – 1st Floor – Movie Room

Energy Saving Opportunity:

- (4) 2x4, 2-lamp T8 surface wrap. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 13-15 fc. Fixtures operate 5 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.
- (2) 4-lamp 60W incandescent ceiling fan. Average foot candle reading for this fixture is 5-10 fc. Fixture operates 1 hour/week. Re-lamp with (8) 13W compact fluorescent, screw type lamps.

Fire Station #2 – 1st Floor – Corridor

Energy Saving Opportunity:

- (3) LED Exit Sign. Fixtures operate 168 hours/week. There are no recommendations, fixtures are to remain.
- (3) 1x4, 2-lamp T8 surface wrap. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 30-35 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.

Fire Station #2 – 1st Floor – Kitchen

Energy Saving Opportunity:

- (1) 2x4, 8-lamp T8 surface wrap. Fixture utilizes electronic ballast. Average foot candle reading for this fixture is 55-60 fc. Fixture operates 60 hours/week. There are no recommendations, fixture is to remain. Fixture to be controlled by dual-technology occupancy sensor.
- (3) 2-lamp, 13W Quad CFL recessed can. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.



Fire Station #2 – 1st Floor – Office Dispatch

Energy Saving Opportunity:

- (3) 2x4, 4-lamp T8 recessed troffer. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 30-35 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.

Fire Station #2 – 1st Floor – Garage

Energy Saving Opportunity:

- (4) 2-lamp T8 strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 15-25 fc. Fixtures operate 5 hours/week. There are no recommendations, fixtures are to remain.

Fire Station #2 – 1st Floor – Apparatus Bay

Energy Saving Opportunity:

- (15) 2-lamp T8 caged strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 13-15 fc. Fixtures operate 168 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensors.
- (26) 2-lamp T8 caged strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 13-15 fc. Fixtures operate 10 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensors.

Fire Station #2 – 1st Floor – Electrical Room

Energy Saving Opportunity:

- (1) 1x4, 2-lamp T8 surface strip. Fixture utilizes electronic ballast. Average foot candle reading for this fixture is 22-25 fc. Fixture operates 2 hours/week. There are no recommendations, fixture is to remain.

Fire Station #2 – 1st Floor – Janitor's Closet

Energy Saving Opportunity:

- (1) 1x4, 2-lamp T8 surface strip. Fixture utilizes electronic ballast. Average foot candle reading for this fixture is 22-25 fc. Fixture operates 2 hours/week. There are no recommendations, fixture is to remain.
- (1) 1x4, 1-lamp T8 surface strip. Fixture utilizes electronic ballast. Average foot candle reading for this fixture is 22-25 fc. Fixture operates 2 hours/week. There are no recommendations, fixture is to remain.



Fire Station #2 – 1st Floor – Apparatus Bay

Energy Saving Opportunity:

- (3) LED Exit Sign. Fixtures operate 168 hours/week. There are no recommendations, fixtures are to remain.

Fire Station #2 – 1st Floor – Apparatus Bay Stairs

Energy Saving Opportunity:

- (3) 1x4, 2-lamp T8 surface wrap. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 22-25 fc. Fixtures operate 168 hours/week. There are no recommendations, fixtures are to remain.

Fire Station #2 – 1st Floor – Storage

Energy Saving Opportunity:

- (2) 1x4, 2-lamp T8 surface strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 22-25 fc. Fixtures operate 2 hours/week. There are no recommendations, fixtures are to remain.

Fire Station #2 – 1st Floor – Restroom

Energy Saving Opportunity:

- (2) 1x4, 2-lamp T8 wall strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 22-25 fc. Fixtures operate 5 hours/week. There are no recommendations, fixtures are to remain.

Fire Station #2 – 1st Floor – Outside

Energy Saving Opportunity:

- (1) 100W HID Wall Pack. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 5-7 fc. Fixtures operate 84 hours/week. There are no recommendations, fixtures are to remain.

Fire Station #2 – 2nd Floor – Stairs

Energy Saving Opportunity:

- (2) 2-lamp, 26W CFL surface round. Average foot candle reading for these fixtures is 10-15 fc. Fixtures operate 168 hours/week. There are no recommendations, fixtures are to remain.



Fire Station #2 – 2nd Floor – Corridors

Energy Saving Opportunity:

- (5) LED Exit Sign. Fixtures operate 168 hours/week. There are no recommendations, fixtures are to remain.
- (5) 26W CFL step light. Average foot candle reading for these fixtures is 1-2 fc. Fixtures operate 168 hours/week. There are no recommendations, fixtures are to remain.

Fire Station #2 – 2nd Floor – Mechanical Room

Energy Saving Opportunity:

- (1) 2-lamp, 26W CFL surface round. Average foot candle reading for this fixture is 10-15 fc. Fixture operates 2 hours/week. There are no recommendations, fixture is to remain.

Fire Station #2 – 2nd Floor – Corridors

Energy Saving Opportunity:

- (11) 1x4, 2-lamp T8 surface wrap. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 22-25 fc. Fixtures operate 10 hours/week. There are no recommendations, fixtures are to remain.

Fire Station #2 – 2nd Floor – Restrooms

Energy Saving Opportunity:

- (3) 1x4, 2-lamp T8 surface wrap. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 22-25 fc. Fixtures operate 5 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.
- (3) 1x4, 2-lamp T8 vanity. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 22-25 fc. Fixtures operate 5 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.
- (3) 26W CFL surface round shower light. Average foot candle reading for these fixtures is 1-2 fc. Fixtures operate 5 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.



Fire Station #2 – 2nd Floor – Bedrooms

Energy Saving Opportunity:

- (14) 1x4, 2-lamp T8 surface wrap. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 22-25 fc. Fixtures operate 5 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensors.

Fire Station #2 – 2nd Floor – Closet

Energy Saving Opportunity:

- (2) 1x4, 1-lamp T8 surface strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 22-25 fc. Fixtures operate 1 hour/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.

Fire Station #2 – 2nd Floor – Laundry

Energy Saving Opportunity:

- (2) 1x4, 2-lamp T8 surface wrap. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 22-25 fc. Fixtures operate 15 hours/week. There are no recommendations, fixtures are to remain.

Fire Station #2 – 2nd Floor – Mechanical Room / Janitor's Closet

Energy Saving Opportunity:

- (2) 1x4, 2-lamp T8 surface wrap. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 22-25 fc. Fixtures operate 1 hour/week. There are no recommendations, fixtures are to remain.

Fire Station #2 – 2nd Floor – Conference Briefing Room

Energy Saving Opportunity:

- (11) 2x4, 4-lamp T8 recessed troffer. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 30-35 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.

Fire Station #2 – 2nd Floor – Weight Room

Energy Saving Opportunity:

- (3) 1x4, 2-lamp T8 surface wrap. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 22-25 fc. Fixtures operate 1 hour/week. There



Detailed Energy Study University City Municipal Buildings

are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.



ECM-1.5: Lighting Retrofit (Golf Course)

Existing Conditions

The University City Golf Course audit focuses on two main buildings: the pro shop and the maintenance garage. The pro shop is occupied approximately 15 hours per day. There are several outdated T12 fixtures in use in the building. These should all be retrofitted with T8 lamps and high-efficiency, electronic ballasts for a substantial payback. These fixtures should also be controlled by dual-technology occupancy sensors to further increase savings by reducing burn hours. The maintenance garage has the same recommendations as well as replacing exposed incandescent lamps with compact fluorescents. All enclosed fixtures that are to remain should have their lenses cleaned and wiped down, as the photometrics and lumen output have been severely compromised due to dust collection and the presence of foreign matter in most cases.

Savings Summary

| Energy Consumption Savings | | | | | Energy Cost Savings | | | | Total Energy Savings | Avoided Maint. Savings | Capital Cost | SPB |
|----------------------------|----|--------|------------|------------|---------------------|-----|-------|-------|----------------------|------------------------|--------------|------|
| KWh | KW | Months | Steam klbs | Water kgal | KWh | KW | Steam | Water | | | | |
| 1,277 | 1 | 12 | - | - | \$87 | \$0 | \$0 | \$0 | \$87 | \$0 | \$1,847 | 18.5 |

Table 21 Savings Summary - ECM-1.5 Lighting Retrofit (Golf Course)

Physical Changes

To the occupant, there will be slight visible changes. With current lamp technology and fixture design, occupants will notice more appropriate light levels with greater uniformity and increased color rendering in the selected retrofit areas. All suggested retrofit and replacement applications meet or exceed existing light levels for the applicable area. The maintenance staff will also notice slight changes. As a result of changing incandescents to compact fluorescents, there will be a lower frequency of lamp replacements. Elimination of fixtures that are in poor operational condition, due to age or environmental degradation, will result in a safer work environment for the entire staff. Other positive changes include the removal of out-dated or obsolete technology, as well as a moderate amount of electrical savings for the facility.

Interface with Agency Equipment

Contractor shall provide all labor and material to inspect, test, and adjust the lighting and the electrical control systems affecting the given spaces to ensure the new lighting systems fulfill existing requirements, while offering a reduction in consumption, especially during peak hours.



Utility Interruptions and Site Coordination

There will be no significant utility interruptions. There will be some downtime associated with fixture replacement and retrofit, but will be strictly limited to the given area and the panel breakers involved. All work shall be coordinated with the administration and the maintenance staff.

Environmental Impacts

There are minimal environmental drawbacks and numerous benefits associated with the suggested retrofitting and replacement of the lighting in the areas outlined. The new lamps and fixtures will consume less energy, resulting in decreased demand from the reactor processes involved in power production. The new fluorescent lamps are far lower in mercury content, which is beneficial concerning disposal. The only negative impact is from the disposal of the existing lamps and fixtures, but this is negligible when compared to the positives. See Table 3 Greenhouse Gases and Other Pollutants

Salvage and Disposal

Existing equipment in operational condition shall be given to University City as requested. All remaining equipment will be removed and disposed of properly by the electrical contractor.



Individual Recommendations Per Location

The following is a summary of the individual floors and areas of the University City Golf Course building and the individual recommendations therein:

Golf Course – Pro Shop

Energy Saving Opportunity:

- (4) 1x4, 2-lamp T12 wall-mounted strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 105 hours/week. Re-lamp with (4) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.
- (8) R40 Halogen Flood Track Light. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 105 hours/month. There are no recommendations, fixtures are to remain.
- (8) 2x4, 4-lamp T8 recessed troffer. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 80-100 fc. Fixtures operate 105 hours/week. Re-lamp with (8) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.
- (1) 2x4, 4-lamp T8 surface wrap. Fixture utilizes electronic ballast. Average foot candle reading for this fixture is 60-80 fc. Fixture operates 105 hours/week. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.

Golf Course – Pro Shop - Office

Energy Saving Opportunity:

- (1) 1x4, 4-lamp T12 surface wrap. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 35-40 fc. Fixtures operate 60 hours/week. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixture to be controlled by dual-technology occupancy sensor.

Golf Course – Pro Shop – Men’s Restroom

Energy Saving Opportunity:

- (1) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-30 fc. Fixtures operate 60 hours/week. Re-lamp with (1) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixture to be controlled by dual-technology occupancy sensor.



Golf Course – Pro Shop – Women’s Restroom

Energy Saving Opportunity:

- (1) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-30 fc. Fixtures operate 10 hours/week. Re-lamp with (1) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixture to be controlled by dual-technology occupancy sensor.

Golf Course – Pro Shop – Stairs

Energy Saving Opportunity:

- (4) 100W recessed incandescent square. Average foot candle reading for these fixtures is 5-7 fc. Fixtures operate 5 hours/week. Re-lamp with (4) 26W compact fluorescent, screw type lamps.

Golf Course – Pro Shop – Basement

Energy Saving Opportunity:

- (1) 2-lamp T12 strip. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 20-25 fc. Fixture operates 5 hours/week. Re-lamp with (1) 2, 28W T8 lamps and high-efficiency, electronic ballast.

Golf Course – Pro Shop – Kitchen

Energy Saving Opportunity:

- (1) 2-lamp T12 strip. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 20-25 fc. Fixture operates 5 hours/week. Re-lamp with (1) 2, 28W T8 lamps and high-efficiency, electronic ballast.
- (1) 100W incandescent globe. Average foot candle reading for this fixture is 10-15 fc. Fixture operates 5 hours/week. Re-lamp with (1) 26W compact fluorescent, screw type lamp.

Golf Course – Pro Shop – Ball Shack

Energy Saving Opportunity:

- (1) 1x4, 2-lamp T8 surface wrap. Fixture utilizes electronic ballast. Average foot candle reading for this fixture is 12-15 fc. Fixture operates 20 hours/week. There are no recommendations, fixtures are to remain.



Golf Course – Grounds Maintenance Building - Storage

Energy Saving Opportunity:

- (1) 100W incandescent globe. Average foot candle reading for this fixture is 2-3 fc. Fixture operates 2 hours/year. Re-lamp with (1) 26W compact fluorescent, screw type lamp.

Golf Course – Grounds Maintenance Building - Garage

Energy Saving Opportunity:

- (1) 60W incandescent globe. Average foot candle reading for this fixture is 2-3 fc. Fixture operates 60 hours/week. Re-lamp with (1) 13W compact fluorescent, screw type lamp.
- (5) 60W incandescent globe. Average foot candle reading for this fixture is 2-3 fc. Fixture operates 2 hours/year. Re-lamp with (5) 13W compact fluorescent, screw type lamp.
- (2) 13W Exposed CFL screw type lamp. Average foot candle reading for these fixtures is 3-5 fc. Fixtures operate 60 hours/week. There are no recommendations, fixtures are to remain.
- (5) 2-lamp T12 strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 10-15 fc. Fixtures operate 120 hours/week. Re-lamp with (5) 2, 28W T8 lamps and high-efficiency, electronic ballasts.

Golf Course – Grounds Maintenance Building – Garage Office

Energy Saving Opportunity:

- (2) 2x4, 4-lamp T8 recessed troffer. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 55-60 fc. Fixtures operate 60 hours/week. Re-lamp with (2) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.

Golf Course – Grounds Maintenance Building – Exterior

Energy Saving Opportunity:

- (2) PAR38 Halogen Flood. Average foot candle reading for this fixture is 5-10 fc. Fixture operates 10 hours/week. There are no recommendations, fixture is to remain.



ECM-1.6: Lighting Retrofit (Public Works)

Existing Conditions

The University City Public Works site consists of several buildings: the central garage, recycling center, sign shop, and grounds maintenance storage and shops. All of these buildings use antiquated T12 strips and recessed troffers with magnetic ballast. All of these fixtures should be retrofitted with T8 lamps and low-power, electronic ballasts. The garage fixtures should be replaced with high-bay, T8 fixtures that will drastically increase light levels, while reducing the total numbers of fixtures and saving significant energy. These fixtures will be equipped with integral occupancy sensors to further increase energy savings. Other upgraded fixtures should also be controlled by new, dual-technology, occupancy sensors for a reduction in burn hours. Although many of these upgrades offer a slightly less than ideal payback, the improvements in light quality and worker productivity make these upgrades a wise investment. All enclosed fixtures that are to remain should have their lenses cleaned and wiped down, as the photometrics and lumen output have been severely compromised due to dust collection and the presence of foreign matter in most cases.

Savings Summary

| Energy Consumption Savings | | | | | Energy Cost Savings | | | | Total Energy Savings | Avoided Maint. Savings | Capital Cost | SPB |
|----------------------------|----|--------|------------|------------|---------------------|-----|-------|-------|----------------------|------------------------|--------------|-----|
| KWh | KW | Months | Steam klbs | Water kgal | KWh | KW | Steam | Water | | | | |
| 39,387 | 9 | 12 | - | - | \$2,698 | \$0 | \$0 | \$0 | \$2,698 | \$0 | \$31,692 | 8.8 |

Table 22 Savings Summary - ECM-1.6 Lighting Retrofit (Public Works)

Physical Changes

To the occupant, there will be slight visible changes. With current lamp technology and fixture design, occupants will notice more appropriate light levels with greater uniformity and increased color rendering in the selected retrofit areas. All suggested retrofit and replacement applications meet or exceed existing light levels for the applicable area. The maintenance staff will also notice slight changes. As a result of changing incandescents to compact fluorescents, there will be a lower frequency of lamp replacements. Elimination of fixtures that are in poor operational condition, due to age or environmental degradation, will result in a safer work environment for the entire staff. Other positive changes include the removal of out-dated or obsolete technology, as well as a moderate amount of electrical savings for the facility.

Interface with Agency Equipment

Contractor shall provide all labor and material to inspect, test, and adjust the lighting and the electrical control systems affecting the given spaces to ensure the new lighting systems fulfill existing requirements, while offering a reduction in consumption, especially during peak hours.



Utility Interruptions and Site Coordination

There will be no significant utility interruptions. There will be some downtime associated with fixture replacement and retrofit, but will be strictly limited to the given area and the panel breakers involved. All work shall be coordinated with the administration and the maintenance staff.

Environmental Impacts

There are minimal environmental drawbacks and numerous benefits associated with the suggested retrofitting and replacement of the lighting in the areas outlined. The new lamps and fixtures will consume less energy, resulting in decreased demand from the reactor processes involved in power production. The new fluorescent lamps are far lower in mercury content, which is beneficial concerning disposal. The only negative impact is from the disposal of the existing lamps and fixtures, but this is negligible when compared to the positives. See Table 3 Greenhouse Gases and Other Pollutants

Salvage and Disposal

Existing equipment in operational condition shall be given to University City as requested. All remaining equipment will be removed and disposed of properly by the electrical contractor.



Individual Recommendations Per Location

The following is a summary of the individual floors and areas of the University City Central Garage building and the individual recommendations therein:

Central Garage – Vehicle Workshop

Energy Saving Opportunity:

- (41) 1x8, 2-lamp 75W T12 surface strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 10-25 fc. Fixtures operate 55 hours/week. Fixtures to be demolished and replaced with (25) 4-lamp T8 High-bays, with electronic ballasts. Fixtures to be controlled by integrated occupancy sensors in fixtures.
- (13) 1x4, 2-lamp T12 surface strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 10-25 fc. Fixtures operate 55 hours/week. Fixtures to be demolished and replaced with (7) 4-lamp T8 High-bays, with electronic ballasts. Fixtures to be controlled by integrated occupancy sensors in fixtures.
- (4) 1x4, 2-lamp T12 pendant industrial task. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 10-25 fc. Fixtures operate 55 hours/week. Re-lamp with (4) 2, 28W T8 lamps and high-efficiency, electronic ballasts.

Central Garage – High-Bay Garage

Energy Saving Opportunity:

- (21) 1x8, 2-lamp 75W T12 surface strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 40-60 fc. Fixtures operate 55 hours/week. Fixtures to be demolished and replaced with (8) 4-lamp T5HO High-bays, with electronic ballasts. Fixtures to be controlled by integrated occupancy sensors in fixtures.
- (3) 1x4, 2-lamp T12 industrial strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 55 hours/week. All fixtures to be demolished.

Central Garage – Garage

Energy Saving Opportunity:

- (1) Incandescent Exit Sign. Fixture operates 168 hours/week. Replace with new (1) LED Exit Sign.



Central Garage – Tool/Compressor Room

Energy Saving Opportunity:

- (1) 1x8, 2-lamp 75W T12 industrial strip. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 10-12 fc. Fixture operates 55 hours/week. Re-lamp with (1) 2, 59W 8', T8 lamps and high-efficiency, electronic ballasts. Fixture to be controlled by dual-technology occupancy sensor.

Central Garage – Parts Supply Room

Energy Saving Opportunity:

- (5) 1x4, 2-lamp T12 industrial strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-22 fc. Fixtures operate 55 hours/week. Re-lamp with (5) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.
- (2) 1x4, 1-lamp T12 industrial strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 18-20 fc. Fixtures operate 55 hours/week. Re-lamp with (2) 1, 28W T8 lamp and high-efficiency, electronic ballast. Fixtures to be controlled by dual-technology occupancy sensor.

Central Garage – Print Room

Energy Saving Opportunity:

- (1) 2x4, 4-lamp T12 recessed troffer. Fixture utilizes standard, magnetic ballast. Average foot candle reading for this fixture is 25-30 fc. Fixture operates 55 hours/week. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.

Central Garage – Offices

Energy Saving Opportunity:

- (2) 2x4, 4-lamp T12 surface wrap. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 55 hours/week. Re-lamp with (2) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.
- (3) 1x4, 2-lamp T12 surface wrap. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 10-20 fc. Fixtures operate 55 hours/week. Re-lamp with (3) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.



Central Garage – Break Room

Energy Saving Opportunity:

- (1) 1x4, 2-lamp T12 industrial strip. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 15-20 fc. Fixture operates 55 hours/week. Re-lamp with (1) 2, 28W T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.

Central Garage – Men’s Locker & Restroom

Energy Saving Opportunity:

- (14) 1x4, 2-lamp T12 industrial strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 55 hours/week. Re-lamp with (14) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.
- (1) 1x4, 2-lamp T8 industrial strip. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 15-20 fc. Fixture operates 55 hours/week. Re-lamp with (1) 2, 28W T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.
- (1) 1x4, 1-lamp T12 vanity strip. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 10-12 fc. Fixture operates 55 hours/week. Re-lamp with (1) 1, 28W T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.
- (2) 1x4, 2-lamp T8 strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixture operates 55 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensor.

Central Garage – Offices

Energy Saving Opportunity:

- (15) 1x4, 2-lamp T12 industrial strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 15-20 fc. Fixtures operate 55 hours/week. Re-lamp with (15) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.

Central Garage – Women’s Restroom

Energy Saving Opportunity:

- (1) 1x4, 2-lamp T12 industrial strip. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 10-15 fc. Fixture operates 55 hours/week. Re-lamp with (1) 2, 28W T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.



Central Garage – Fuel Station

Energy Saving Opportunity:

- (2) 175W Metal Halide Class 1, Division 1 surface mount. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 8-10 fc. Fixtures operate 84 hours/week. There are no recommendations, fixtures are to remain.

Materials Recycling Facility - Storage

Energy Saving Opportunity:

- (6) 1x4, 2-lamp T8 surface strip. Fixture utilizes electronic ballast. Average foot candle reading for this fixture is 20-22 fc. Fixture operates 40 hours/week. There are no recommendations, fixtures are to remain. Fixtures to be controlled by dual-technology occupancy sensors.
- (10) 1x4, 2-lamp T12 surface strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-22 fc. Fixtures operate 40 hours/week. Re-lamp with (10) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensors.

Materials Recycling Facility - Break

Energy Saving Opportunity:

- (3) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 20-30 fc. Fixtures operate 2 hours/week. Re-lamp with (3) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures to be controlled by dual-technology occupancy sensor.

Materials Recycling Facility - Restroom

Energy Saving Opportunity:

- (1) 2x4, 4-lamp T12 recessed troffer. Fixture utilizes standard, magnetic ballast. Average foot candle reading for this fixture is 20-25 fc. Fixture operates 40 hours/week. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.

Materials Recycling Facility – Janitor’s Closet

Energy Saving Opportunity:

- (1) 1x4, 2-lamp T8 industrial strip. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 25-30 fc. Fixture operates 40 hours/week. Re-lamp with (1) 2, 28W T8 lamps and high-efficiency, electronic ballast. Fixture to be controlled by dual-technology occupancy sensor.



Materials Recycling Facility – Storage

Energy Saving Opportunity:

- (2) Incandescent Exit Sign. Fixtures operate 168 hours/week. Replace with new (2) LED Exit Sign.

Materials Recycling Facility – Trash Sorting

Energy Saving Opportunity:

- (3) 100W Metal Halide Wall Flood. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 3-7 fc. Fixtures operate 84 hours/week. There are no recommendations, fixtures are to remain.
- (2) 150W High-Pressure Sodium Wall Pack. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 4-7 fc. Fixtures operate 168 hours/week. There are no recommendations, fixtures are to remain.

Materials Recycling Facility – Break Shack

Energy Saving Opportunity:

- (2) 1x4, 2-lamp T12 surface wrap. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 10-20 fc. Fixtures operate 2 hours/week. Re-lamp with (2) 2, 28W T8 lamps and high-efficiency, electronic ballasts.

Parks Storage and Shops - Storage

Energy Saving Opportunity:

- (19) 1x4, 2-lamp T12 pendant strip. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 11-15 fc. Fixtures operate 168 hours/week. Re-lamp with (19) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures shall be controlled by dual-technology occupancy sensors.
- (1) 1x4, 4-lamp T12 pendant strip. Fixture utilizes standard, magnetic ballast. Average foot candle reading for this fixture is 21-25 fc. Fixture operates 168 hours/week. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballast. Fixture shall be controlled by dual-technology occupancy sensor.

Parks Storage and Shops – Break Area

Energy Saving Opportunity:

- (27) 1x4, 2-lamp T12 pendant strip. Fixture utilizes standard, magnetic ballast. Average foot candle reading for this fixture is 20-22 fc. Fixture operates 168 hours/week. Re-lamp with (27) 2, 28W T8 lamps and high-efficiency, electronic ballast. Fixtures shall be controlled by dual-technology occupancy sensors.



- (1) 2x4, 4-lamp T12 pendant strip. Fixture utilizes standard, magnetic ballast. Average foot candle reading for this fixture is 21-25 fc. Fixture operates 168 hours/week. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballast. Fixtures shall be controlled by dual-technology occupancy sensor.

Parks Storage and Shops - Storage

Energy Saving Opportunity:

- (5) 26W CFL Pendant Globe. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 4-6 fc. Fixtures operate 50 hours/week. There are no recommendations, fixtures are to remain.

Parks Storage and Shops – Back Garage

Energy Saving Opportunity:

- (6) 1x4, 2-lamp T12 pendant strip. Fixture utilizes standard, magnetic ballast. Average foot candle reading for this fixture is 15-20 fc. Fixture operates 168 hours/week. Re-lamp with (6) 2, 28W T8 lamps and high-efficiency, electronic ballast. Fixtures shall be controlled by dual-technology occupancy sensor.

Parks Storage and Shops – Machine Shop

Energy Saving Opportunity:

- (20) 1x4, 2-lamp T12 pendant strip. Fixture utilizes standard, magnetic ballast. Average foot candle reading for this fixture is 15-20 fc. Fixture operates 168 hours/week. Re-lamp with (20) 2, 28W T8 lamps and high-efficiency, electronic ballast. Fixtures shall be controlled by dual-technology occupancy sensors.

Parks Storage and Shops – Entry Hall

Energy Saving Opportunity:

- (3) 1x4, 2-lamp T12 surface wrap. Fixture utilizes standard, magnetic ballast. Average foot candle reading for this fixture is 23-25 fc. Fixture operates 50 hours/week. Re-lamp with (3) 2, 28W T8 lamps and high-efficiency, electronic ballast. Fixtures shall be controlled by dual-technology occupancy sensor.

Parks Storage and Shops – Locker

Energy Saving Opportunity:

- (3) 1x4, 2-lamp T12 surface wrap. Fixture utilizes standard, magnetic ballast. Average foot candle reading for this fixture is 23-25 fc. Fixture operates 50 hours/week. Re-lamp with (3) 2, 28W T8 lamps and high-efficiency, electronic ballast. Fixtures shall be controlled by dual-technology occupancy sensor.
- (2) 1x8, 2-lamp 75W T12 industrial strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 40-50 fc. Fixtures



operate 50 hours/week. Re-lamp with (2) 2, 59W 8', T8 lamps and high-efficiency, electronic ballasts. Fixtures shall be controlled by dual-technology occupancy sensor.

Parks Storage and Shops – Restroom

Energy Saving Opportunity:

- (2) 100W exposed incandescent pendant. Average foot candle reading for this fixture is 3-5 fc. Fixture operates 50 hours/year. Re-lamp with (2) 26W compact fluorescent, screw type lamp.
- (1) 2-lamp 60W incandescent vanity. Average foot candle reading for this fixture is 9-11 fc. Fixture operates 50 hours/year. Re-lamp with (2) 13W compact fluorescent, screw type lamp.

Parks Storage and Shops – Office

Energy Saving Opportunity:

- (3) 2x4, 4-lamp T8 recessed troffer. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 90-110 fc. Fixtures operate 50 hours/week. Fixtures shall be demolished and replaced with 2-lamp, T8 recessed volumetric fixtures with high-efficiency, electronic ballasts. Fixtures shall be controlled by dual-technology occupancy sensor.
- (3) 2-lamp T12 strip above lay-in lens. Fixture utilizes standard, magnetic ballast. Average foot candle reading for this fixture is 10-15 fc. Fixture operates 50 hours/week. Re-lamp with (3) 2, 28W T8 lamps and high-efficiency, electronic ballast. Fixtures shall be controlled by dual-technology occupancy sensor.

Lawn Equipment Storage - Garage

Energy Saving Opportunity:

- (4) PAR38 Halogen Flood. Average foot candle reading for these fixtures is 5-10 fc. Fixtures operate 5 hours/month. There are no recommendations, fixtures are to remain.
- (1) 26W Exposed CFL. Fixture utilizes standard, magnetic ballast. Average foot candle reading for this fixture is 4-6 fc. Fixture operates 5 hours/month. There are no recommendations, fixture is to remain.
- (1) 1x4, 1-lamp T12 surface strip. Fixture utilizes standard, magnetic ballast. Average foot candle reading for this fixture is 10-15 fc. Fixture operates 5 hours/month. Re-lamp with (1) 1, 28W T8 lamp and high-efficiency, electronic ballast.



Sign Shop - Storage

Energy Saving Opportunity:

- (20) 1x4, 2-lamp T12 surface industrial strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 10-25 fc. Fixtures operate 45 hours/week. Fixtures to be demolished and replaced with (8) 4-lamp T8 High-bays, with electronic ballasts. Fixtures to be controlled by integrated occupancy sensors in fixtures.

Sign Shop - Office

Energy Saving Opportunity:

- (1) 1x8, 2-lamp 75W T12 industrial strip. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 10-25 fc. Fixture operates 45 hours/week. Re-lamp with (1) 2, 59W 8', T8 lamps and high-efficiency, electronic ballast. Fixture shall be controlled by dual-technology occupancy sensor.

Sign Shop - Restroom

Energy Saving Opportunity:

- (1) 1x4, 1-lamp T12 industrial strip. Fixture utilizes standard, magnetic ballast. Average foot candle reading for this fixture is 3-5 fc. Fixture operates 45 hours/week. Re-lamp with (1) 1, 28W T8 lamp and high-efficiency, electronic ballast. Fixture shall be controlled by dual-technology occupancy sensor.

Sign Shop - Storage

Energy Saving Opportunity:

- (1) Incandescent Exit Sign. Fixture operates 168 hours/week. Replace with new (1) LED Exit Sign.



ECM-1.7: Lighting Retrofit (Recreation Center)

Existing Conditions

The University City Recreation Center houses a gym, basketball court, indoor soccer field, offices, and a pool. Many portions of the gym were added in in the mid-2000s and do not require any upgrades. The basketball court and indoor soccer field currently use metal halide high-bay fixtures for illumination. By replacing these T5HO high-bay fixtures, the overall number of fixtures will be significantly reduced, the lighting will improve, energy will be saved, and controllability and safety will be increased due to “instant on” technology. These fixtures shall be installed with integral occupancy sensors to avoid wasted burn hours when the areas are not in use. The weight rooms as well as the pool house still use T12 lamps with magnetic ballasts. These should be retrofitted with T8 lamps and high-efficiency, electronic ballasts to save energy and improve all aspects of the existing fixtures. Controls should also be implemented in these areas to reduce unnecessary burn time. Unfortunately, most of the suggested upgrades are for quality and productivity as well as increased control; but they do not offer a reasonable payback in most cases. All enclosed fixtures that are to remain should have their lenses cleaned and wiped down, as the photometrics and lumen output have been severely compromised due to dust collection and the presence of foreign matter in most cases.

Savings Summary

| Energy Consumption Savings | | | | | Energy Cost Savings | | | | Total Energy Savings | Avoided Maint. Savings | Capital Cost | SPB |
|----------------------------|----|--------|------------|------------|---------------------|-----|-------|-------|----------------------|------------------------|--------------|------|
| KWh | KW | Months | Steam klbs | Water kgal | KWh | KW | Steam | Water | | | | |
| 27,897 | 12 | 12 | - | - | \$1,911 | \$0 | \$0 | \$0 | \$1,911 | \$0 | \$42,681 | 20.8 |

Table 23 Savings Summary - ECM-1.7 Lighting Retrofit (Recreation Center)

Physical Changes

To the occupant, there will be moderate visible changes. With current lamp technology and fixture design, occupants will notice more appropriate light levels with greater uniformity and increased color rendering in the selected retrofit areas. All suggested retrofit and replacement applications meet or exceed existing light levels for the applicable area. The maintenance staff will also notice slight changes. As a result of changing incandescents to compact fluorescents, there will be a lower frequency of lamp replacements. Elimination of fixtures that are in poor operational condition, due to age or environmental degradation, will result in a safer work environment for the entire staff. Other positive changes include the removal of out-dated or obsolete technology, as well as a moderate amount of electrical savings for the facility.

Interface with Agency Equipment

Contractor shall provide all labor and material to inspect, test, and adjust the lighting and the electrical control systems affecting the given spaces to ensure the new lighting systems fulfill existing requirements, while offering a reduction in consumption, especially during peak hours.



Utility Interruptions and Site Coordination

There will be no significant utility interruptions. There will be some downtime associated with fixture replacement and retrofit, but will be strictly limited to the given area and the panel breakers involved. All work shall be coordinated with the administration and the maintenance staff.

Environmental Impacts

There are minimal environmental drawbacks and numerous benefits associated with the suggested retrofitting and replacement of the lighting in the areas outlined. The new lamps and fixtures will consume less energy, resulting in decreased demand from the reactor processes involved in power production. The new fluorescent lamps are far lower in mercury content, which is beneficial concerning disposal. The only negative impact is from the disposal of the existing lamps and fixtures, but this is negligible when compared to the positives. See Table 3 Greenhouse Gases and Other Pollutants

Salvage and Disposal

Existing equipment in operational condition shall be given to University City as requested. All remaining equipment will be removed and disposed of properly by the electrical contractor.



Individual Recommendations Per Location

The following is a summary of the individual floors and areas of the University City Recreation Center building and the individual recommendations therein:

Recreation Center – Weight Room

Energy Saving Opportunity:

- (22) 2x4, 4-lamp T8 recessed troffer. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 45-50 fc. Fixtures operate 103 hours/week. There are no recommendations, fixtures are to remain. Fixtures shall be controlled by dual-technology occupancy sensors.
- (2) LED Exit Sign. Fixtures operate 168 hours/week. There are no recommendations, fixtures are to remain.
- (8) PAR38 CFL Flood. Average foot candle reading for these fixtures is 10-15 fc. Fixtures operate 103 hours/week. There are no recommendations, fixtures are to remain.

Recreation Center – Restroom Corridor

Energy Saving Opportunity:

- (2) 2x4, 4-lamp T12 surface wrap. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 35-40 fc. Fixtures operate 103 hours/week. Re-lamp with (2) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures shall be controlled by dual-technology occupancy sensor.
- (1) 2x4, 4-lamp T12 recessed troffer. Fixture utilizes standard, magnetic ballast. Average foot candle reading for this fixture is 20-25 fc. Fixture operates 103 hours/week. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballast. Fixture shall be controlled by dual-technology occupancy sensor.

Recreation Center – Men’s Restroom

Energy Saving Opportunity:

- (3) 2x4, 4-lamp T12 surface wrap. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 103 hours/week. Re-lamp with (3) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures shall be controlled by dual-technology occupancy sensor.

Recreation Center – Women’s Restroom

Energy Saving Opportunity:

- (5) 2x4, 4-lamp T12 surface wrap. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 103



hours/week. Re-lamp with (5) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures shall be controlled by dual-technology occupancy sensor.

Recreation Center – Rock Wall

Energy Saving Opportunity:

- (4) 250W, Metal Halide low bay. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 5-12 fc. Fixtures operate 103 hours/week. Fixtures to be demolished and replaced with (4) 4-lamp T5HO High-bays, with electronic ballasts. Fixtures to be controlled by integrated occupancy sensors in fixtures.

Recreation Center – Indoor Soccer

Energy Saving Opportunity:

- (11) 250W, Metal Halide low bay. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 1-16 fc. Fixtures operate 103 hours/week. Fixtures to be demolished and replaced with (21) 4-lamp T5HO High-bays, with electronic ballasts. Fixtures to be controlled by integrated occupancy sensors in fixtures.
- (32) 250W, Metal Halide low bay. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 1-16 fc. Fixtures operate 10 hours/week. Fixtures to be demolished.
- (4) LED Exit Sign. Fixtures operate 168 hours/week. There are no recommendations, fixtures are to remain.

Recreation Center – Basketball Court

Energy Saving Opportunity:

- (20) 250W, Metal Halide low bay. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 8-10 fc. Fixtures operate 103 hours/week. Fixtures to be demolished and replaced with (15) 4-lamp T5HO High-bays, with electronic ballasts. Fixtures to be controlled by integrated occupancy sensors in fixtures.

Recreation Center – Pool Entry

Energy Saving Opportunity:

- (10) 26W CFL Recessed Can. Fixture utilizes standard, magnetic ballast. Average foot candle reading for this fixture is 4-6 fc. Fixture operates 2 hours/week. There are no recommendations, fixture is to remain.



Recreation Center – Pool House

Energy Saving Opportunity:

- (3) Incandescent Exit Sign. Fixtures operate 168 hours/week. Replace with new (3) LED Exit Sign.
- (59) 1-lamp T12 strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 11-13 fc. Fixtures operate 66 hours/week. Re-lamp with (59) 1, 28W T8 lamp and high-efficiency, electronic ballasts. Fixtures shall be controlled by dual-technology occupancy sensors.
- (17) 2-lamp T12 strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 66 hours/week. Re-lamp with (17) 2, 28W T8 lamps and high-efficiency, electronic ballasts. Fixtures shall be controlled by dual-technology occupancy sensors.
- (7) 2-lamp T12 strip. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 20-25 fc. Fixtures operate 5 hours/week. Re-lamp with (7) 2, 28W T8 lamps and high-efficiency, electronic ballasts.
- (4) 2x4, 4-lamp T12 surface wrap. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 66 hours/week. Re-lamp with (4) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixtures shall be controlled by dual-technology occupancy sensor.

Recreation Center – Pool Electrical / Pump Room

Energy Saving Opportunity:

- (11) 2-lamp T8 damp-location strip. Fixtures utilize electronic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 66 hours/week. There are no recommendations, fixtures are to remain. Fixtures shall be controlled by dual-technology occupancy sensors.

Recreation Center – Pool Office

Energy Saving Opportunity:

- (1) 2x4, 4-lamp T12 surface wrap. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 35-40 fc. Fixtures operate 60 hours/week. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballasts. Fixture shall be controlled by dual-technology occupancy sensor.

Recreation Center – Pool Storage

Energy Saving Opportunity:

- (1) 100W exposed incandescent pendant. Average foot candle reading for this fixture is 3-5 fc. Fixture operates 1 hour/year. Re-lamp with (1) 26W compact fluorescent, screw type lamp.



ECM-1.8: Lighting Retrofit (Trinity Building)

Existing Conditions

The University City Trinity Building was a former library that is now used for storage. The building is rarely occupied, thus no upgrades will offer a reasonable payback. Therefore, there are no recommendations for the Trinity Building although there are potential upgrades listed if payback was not a factor or the building occupancy increases.

Savings Summary

| Energy Consumption Savings | | | | | Energy Cost Savings | | | | Total Energy Savings | Avoided Maint. Savings | Capital Cost | SPB |
|----------------------------|----|--------|------------|------------|---------------------|-----|-------|-------|----------------------|------------------------|--------------|-------|
| KWh | KW | Months | Steam klbs | Water kgal | KWh | KW | Steam | Water | | | | |
| 1,226 | 6 | 12 | - | - | \$84 | \$0 | \$0 | \$0 | \$84 | \$0 | \$9,371 | 111.6 |

Table 24 Savings Summary - ECM-1.8 Lighting Retrofit (Trinity Building)

Physical Changes

To the occupant, there will be moderate visible changes. With current lamp technology and fixture design, occupants will notice more appropriate light levels with greater uniformity and increased color rendering in the selected retrofit areas. All suggested retrofit and replacement applications meet or exceed existing light levels for the applicable area. The maintenance staff will also notice slight changes. As a result of changing incandescents to compact fluorescents, there will be a lower frequency of lamp replacements. Elimination of fixtures that are in poor operational condition, due to age or environmental degradation, will result in a safer work environment for the entire staff. Other positive changes include the removal of out-dated or obsolete technology, as well as a moderate amount of electrical savings for the facility.

Interface with Agency Equipment

Contractor shall provide all labor and material to inspect, test, and adjust the lighting and the electrical control systems affecting the given spaces to ensure the new lighting systems fulfill existing requirements, while offering a reduction in consumption, especially during peak hours.

Utility Interruptions and Site Coordination

There will be no significant utility interruptions. There will be some downtime associated with fixture replacement and retrofit, but will be strictly limited to the given area and the panel breakers involved. All work shall be coordinated with the administration and the maintenance staff.



Environmental Impacts

There are minimal environmental drawbacks and numerous benefits associated with the suggested retrofitting and replacement of the lighting in the areas outlined. The new lamps and fixtures will consume less energy, resulting in decreased demand from the reactor processes involved in power production. The new fluorescent lamps are far lower in mercury content, which is beneficial concerning disposal. The only negative impact is from the disposal of the existing lamps and fixtures, but this is negligible when compared to the positives. See Table 3 Greenhouse Gases and Other Pollutants

Salvage and Disposal

Existing equipment in operational condition shall be given to University City as requested. All remaining equipment will be removed and disposed of properly by the electrical contractor.

Individual Recommendations Per Location

The following is a summary of the individual floors and areas of the University City Trinity Building and the individual recommendations therein:

Trinity Building – 1st Floor - Storage

Energy Saving Opportunity:

- (11) 2x4, 4-lamp T12 surface wrap. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 10-15 fc. Fixtures operate 20 hours/year. Re-lamp with (11) 4, 25W T8 lamps and high-efficiency, electronic ballasts.
- (3) Incandescent Exit Sign. Fixtures operate 168 hours/week. Replace with new (3) LED Exit Sign.

Trinity Building – 1st Floor - Offices

Energy Saving Opportunity:

- (2) 2x4, 4-lamp T12 recessed troffer. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 25-30 fc. Fixtures operate 10 hours/year. Re-lamp with (2) 4, 25W T8 lamps and high-efficiency, electronic ballasts.

Trinity Building – 1st Floor - Kitchen

Energy Saving Opportunity:

- (1) 2-lamp T12 strip. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 10-15 fc. Fixture operates 10 hours/year. Re-lamp with (1) 2, 28W T8 lamps and high-efficiency, electronic ballast.



Trinity Building – 1st Floor – Stage / Mechanical

Energy Saving Opportunity:

- (15) 90W exposed incandescent pendant. Average foot candle reading for these fixtures is 2-3 fc. Fixtures operate 5 hours/year. Re-lamp with (15) 26W compact fluorescent, screw type lamps.

Trinity Building – 1st Floor – Stairs

Energy Saving Opportunity:

- (2) 26W CFL Pendant. Fixtures utilize standard, magnetic ballasts. Average foot candle reading for these fixtures is 2-3 fc. Fixtures operate 40 hours/week. There are no recommendations, fixtures are to remain.

Trinity Building – 1st Floor – Men's Restroom

Energy Saving Opportunity:

- (1) 90W exposed incandescent pendant. Average foot candle reading for this fixture is 2-3 fc. Fixture operates 5 hours/year. Re-lamp with (1) 26W compact fluorescent, screw type lamp.

Trinity Building – 1st Floor – Women's Restroom

Energy Saving Opportunity:

- (1) 90W exposed incandescent pendant. Average foot candle reading for this fixture is 2-3 fc. Fixture operates 5 hours/year. Re-lamp with (1) 26W compact fluorescent, screw type lamp.
- (1) 1x4, 1-lamp T12 wall strip. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 5-10 fc. Fixture operates 40 hours/week. Re-lamp with (1) 1, 28W T8 lamp and high-efficiency, electronic ballast.

Trinity Building – 1st Floor – Storage

Energy Saving Opportunity:

- (4) 100W exposed incandescent. Average foot candle reading for these fixtures is 2-3 fc. Fixtures operate 1 hour/year. Re-lamp with (4) 26W compact fluorescent, screw type lamps.

Trinity Building – 2nd Floor – Hall

Energy Saving Opportunity:

- (1) 2-lamp, 40W recessed incandescent square. Average foot candle reading for this fixture is 3-5 fc. Fixture operates 1 hour/year. Re-lamp with (2) 9W compact fluorescent, screw type lamp.



Trinity Building – 2nd Floor – Storage

Energy Saving Opportunity:

- (18) 60W exposed incandescent. Average foot candle reading for these fixtures is 2-3 fc. Fixtures operate 1 hour/year. Re-lamp with (18) 13W compact fluorescent, screw type lamps.

Trinity Building – 2nd Floor – Stairs

Energy Saving Opportunity:

- (2) 2-lamp T12 surface wrap. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 1-2 fc. Fixtures operate 20 hours/week. Re-lamp with (2) 2, 28W T8 lamps and high-efficiency, electronic ballasts.
- (1) 4-lamp T12 surface wrap. Fixture utilizes standard magnetic ballast. Average foot candle reading for this fixture is 1-2 fc. Fixture operates 20 hours/week. Re-lamp with (1) 4, 25W T8 lamps and high-efficiency, electronic ballast.

Trinity Building – 2nd Floor – Storage

Energy Saving Opportunity:

- (1) Incandescent Exit Sign. Fixture operates 168 hours/week. Replace with new (1) LED Exit Sign.
- (39) 34W exposed incandescent. Average foot candle reading for this fixture is 3-5 fc. Fixture operates 1 hour/year. Re-lamp with (39) 9W compact fluorescent, screw type lamp.
- (5) 2-lamp T12 surface wrap. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 10-15 fc. Fixtures operate 20 hours/week. Re-lamp with (5) 2, 28W T8 lamps and high-efficiency, electronic ballasts.

Trinity Building – 2nd Floor – Old Library

Energy Saving Opportunity:

- (9) 4-lamp T12 surface wrap. Fixtures utilize standard magnetic ballasts. Average foot candle reading for these fixtures is 5-10 fc. Fixtures operate 60 hours/year. Re-lamp with (9) 4, 25W T8 lamps and high-efficiency, electronic ballasts.
- (2) Incandescent Exit Sign. Fixtures operate 168 hours/week. Replace with new (2) LED Exit Sign.



Trinity Building – 2nd Floor – Stairs

Energy Saving Opportunity:

- (2) 5-lamp, Decorative Incandescent Candleabra. Average foot candle reading for these fixtures is 2-3 fc. Fixtures operate 1 hour/month. There are no recommendations, fixtures are to remain.

Trinity Building – 2nd Floor – Entry

Energy Saving Opportunity:

- (1) 2-lamp, 40W decorative incandescent surface mount. Average foot candle reading for this fixture is 3-5 fc. Fixture operates 1 hour/month. Re-lamp with (2) 13W compact fluorescent, screw type lamp.

Trinity Building – 3rd Floor – Storage

Energy Saving Opportunity:

- (19) 34W exposed incandescent. Average foot candle reading for this fixture is 3-5 fc. Fixture operates 1 hour/year. Re-lamp with (19) 9W compact fluorescent, screw type lamp.



2.0 ENERGY MANAGEMENT SYSTEM / CONTROL IMPROVEMENTS

ECM-2.1: Install Programmable Tstats & Locking Covers - Central Garage (Assumes ECM-4.3 Implemented)

The Central Garage offices are conditioned by two split systems as described in the HVAC description. These units are controlled by standard thermostats. The set points for these spaces can be modified to reduce energy use.

This ECM recommends the installation of new programmable thermostats with locking covers to control the unit. See Table 25 Office Set Point Schedule - Central Garage below for space temperature setpoints.

| Existing Space Temp. Set Points | | | Recommended Space Temp. Set Points | | |
|---------------------------------|-----------|------------|------------------------------------|-----------|------------|
| Mode | Occupied | Unoccupied | Mode | Occupied | Unoccupied |
| Hours | 0630-1700 | 1700-0630 | Hours | 0630-1700 | 1700-0630 |
| Cooling | 72°F | 72°F | Cooling | 74°F | 80°F |
| Heating | 72°F | 72°F | Heating | 70°F | 60°F |

Table 25 Office Set Point Schedule - Central Garage

Savings Summary

| Energy Consumption Savings | | | | | Energy Cost Savings | | | | Total Energy Savings | Avoided Maint. Savings | Capital Cost | SPB |
|----------------------------|----|--------|------------|------------|---------------------|-----|-------|-------|----------------------|------------------------|--------------|-----|
| KWh | KW | Months | Steam klbs | Water kgal | KWh | KW | Steam | Water | | | | |
| 27,671 | 3 | 12 | - | 0 | \$1,895 | \$0 | \$0 | \$0 | \$1,895 | \$0 | \$227 | 0.1 |

Table 26 Savings Summary - ECM-2.1 Office Setpoint Schedule (Central Garage)

Physical Changes

To the occupant, there will be virtually no visible changes.

Interface with Agency Equipment

Contractor will provide all labor and material to inspect, test, and adjust the mechanical and control systems affecting the given spaces to ensure the HVAC systems are performing in a manner to adequately condition the spaces served.

Utility Interruptions and Site Coordination

There will be no significant utility interruptions. There will be some time when the space temperatures may fluctuate as the system operation is tested.. These will be coordinated with the facility administration.



Environmental Impacts

The environmental impact from this project will only be positive. By reducing electrical consumption, pollution from power generating plants will also be reduced. Please see Table 3 Greenhouse Gases and Other Pollutants.

Salvage and Disposal

There is no equipment that will be removed.



ECM-2.2: Install Plug Load Occupancy Sensors - City Hall

The City Hall has workstations using various office appliances. These spaces have a total of approximately fifty-five (55) computers that can be retrofitted with a plug load occupancy sensor. The plug load sensor will turn off accessory plug loads (not the computer itself) which includes the associated monitor, personal printers, and task lighting that are used approximately 12 hours a day, however most remain on the majority of the day.

This ECM recommends the installation of a plug load occupancy sensor power strip that will reduce energy consumption by turning plug loads on and off based on occupancy.

Savings Summary

| Energy Consumption Savings | | | | | Energy Cost Savings | | | | Total Energy Savings | Avoided Maint. Savings | Capital Cost | SPB |
|----------------------------|----|--------|------------|------------|---------------------|-----|-------|-------|----------------------|------------------------|--------------|-----|
| KWh | KW | Months | Steam klbs | Water kgal | KWh | KW | Steam | Water | | | | |
| 16,527 | - | - | - | 0 | \$1,132 | \$0 | \$0 | \$0 | \$1,132 | \$0 | \$8,081 | 7.6 |

Table 27 Savings Summary - ECM-2.2 Install Plug Load Occupancy Sensors (City Hall)

Physical Changes

To the occupant, there will be virtually no visible changes. The worker will have to be educated on how the plug load occupancy sensor works in order to understand how it may affect them during the workday. For instance, if the worker leaves for lunch and the occupancy sensor will shut off outlets that are connected after the present time delay expires. When the worker returns they will notice that as they approach their desk, the equipment connected to the power strip will turn on.

Interface with Agency Equipment

The facility manager should coordinate which workstations will be allowed to have the plug load occupancy sensor power strip installed on.

Utility Interruptions and Site Coordination

There will be no significant utility interruptions. There will be minimal downtime associated with each plug load occupancy sensor power strip installation. These will be coordinated with the facility administration.

Environmental Impacts

The environmental impact from this project will only be positive. By reducing electrical consumption, pollution from power generating plants will also be reduced. By reducing the plug loads associated with unoccupied workstation energy will be conserved. Please see Table 3 Greenhouse Gases and Other Pollutants.

Salvage and Disposal

There is no equipment that will be removed.



ECM-2.3: Install Plug Load Occupancy Sensors - Annex

The Annex has workstations using various office appliances. These spaces have a total of approximately seventy-five (75) computers that can be retrofitted with a plug load occupancy sensor. The plug load sensor will turn off accessory plug loads (not the computer itself) which includes the associated monitor, personal printers, and task lighting that are used approximately 12 hours a day, however most remain on the majority of the day.

This ECM recommends the installation of a plug load occupancy sensor power strip that will reduce energy consumption by turning plug loads on and off based on occupancy.

Savings Summary

| Energy Consumption Savings | | | | | Energy Cost Savings | | | | Total Energy Savings | Avoided Maint. Savings | Capital Cost | SPB |
|----------------------------|----|--------|------------|------------|---------------------|-----|-------|-------|----------------------|------------------------|--------------|-----|
| KWh | KW | Months | Steam klbs | Water kgal | KWh | KW | Steam | Water | | | | |
| 19,016 | - | - | - | - | \$1,303 | \$0 | \$0 | \$0 | \$1,303 | \$0 | \$11,019 | 9.7 |

Table 28 Savings Summary - ECM-2.3 Install Plug Load Occupancy Sensors (Annex)

Physical Changes

To the occupant, there will be virtually no visible changes. The worker will have to be educated on how the plug load occupancy sensor works in order to understand how it may affect them during the workday. For instance, if the worker leaves for lunch and the occupancy sensor will shut off outlets that are connected after the present time delay expires. When the worker returns they will notice that as they approach their desk, the equipment connected to the power strip will turn on.

Interface with Agency Equipment

The facility manager should coordinate which workstations will be allowed to have the plug load occupancy sensor power strip installed on.

Utility Interruptions and Site Coordination

There will be no significant utility interruptions. There will be minimal downtime associated with each plug load occupancy sensor power strip installation. These will be coordinated with the facility administration.

Environmental Impacts

The environmental impact from this project will only be positive. By reducing electrical consumption, pollution from power generating plants will also be reduced. By reducing the plug loads associated with unoccupied workstation energy will be conserved. Please see Table 3 Greenhouse Gases and Other Pollutants.



Salvage and Disposal

There is no equipment that will be removed.



4.0 HEATING, VENTILATING, & AIR CONDITIONING IMPROVEMENTS

ECM-4.1: Unit Replacement – Annex

The Annex is conditioned by multiple systems as was previously detailed in the HVAC description. There are several pieces of equipment that are nearing the end of their useful life and consume higher quantities of energy than newer equipment. Also the water source units consume large quantities of domestic water.

This ECM recommends replacing the condensing unit, cooling coil, and refrigerant lines for the existing split systems. The existing gas furnace or steam coils for these units would remain. This ECM also recommends replacing the water source units with new split systems. The units serving the server and telephone room would not require heat while the unit serving the basement cells shall be a heat pump unit. The new split system units shall have a higher cooling efficiency EER rating ranging from 12.0 and a higher heating efficiency COP of 3.5. The new heat pump unit will still have supplemental auxiliary electric heat; but this would only occur when the heat pump could not maintain set temperature. New equipment shall be installed in the same location as existing equipment. See Table 29 Existing HVAC Recommended Replacement Schedule - Annex. It should be noted that cooling would not be possible below 0°F ambient for the computer room and telephone room. Design temperature for this area is 2°F, however there can be times when ambient temperatures are below this. Also, the cost estimate does not include any code issues that may arise.

| Existing HVAC Recommended Replacement Schedule | | | | | | |
|--|---------------------|----------|--------|------|----------|----------|
| Area Served | Unit Type | Quantity | SA cfm | Tons | Clg type | Htg Type |
| Detectives | DX/Gas RTU | 1 | 2,000 | 5.0 | DX | Gas |
| Office | DX/Gas Split | 1 | 1,200 | 3.0 | DX | Gas |
| Fire Chief/Kitchen | DX/Steam Split | 1 | 1,200 | 3.0 | DX | Steam |
| Server Rm | Vert. Water Source | 1 | 1,200 | 3.0 | WS | WSHP |
| Telephone Rm | Horiz. Water Source | 1 | 1,200 | 3.0 | WS | WSHP |
| Basement Cells | Vert. Water Source | 1 | 1,200 | 3.0 | WS | WSHP |

Table 29 Existing HVAC Recommended Replacement Schedule - Annex

Savings Summary

| Energy Consumption Savings | | | | | Energy Cost Savings | | | | Total Energy Savings | Avoided Maint. Savings | Capital Cost | SPB |
|----------------------------|----|--------|------------|------------|---------------------|-----|-------|---------|----------------------|------------------------|--------------|-----|
| KWh | KW | Months | Steam klbs | Water kgal | KWh | KW | Steam | Water | | | | |
| 55,706 | 11 | 12 | - | 2,173 | \$3,816 | \$0 | \$0 | \$7,040 | \$10,856 | \$0 | \$101,983 | 9.5 |

Table 30 Savings Summary - ECM-4.1 Unit Replacement Annex

Physical Changes

To the occupant, there will be virtually no visible changes. In many locations where the system has not been operating effectively, building occupants will now have a more comfortable working environment.



Interface with Agency Equipment

Contractor will provide all labor and material to inspect, test, and adjust the mechanical and control systems affecting the given spaces to ensure the HVAC systems are performing in a manner to adequately condition the spaces served.

Utility Interruptions and Site Coordination

There will be no significant utility interruptions. There will be some downtime associated with each unit replacement. Any electricity curtailment will be limited to an individual breaker serving an air handler or other HVAC equipment. In some instances, a sub panel may be momentarily interrupted. These will be coordinated with the facility manager.

Environmental Impacts

The environmental impact from this project will only be positive. By reducing electrical consumption, pollution from power generating plants will also be reduced. By increasing the efficiency of the equipment, cooling and heating energy will be conserved. Please see Table 3 Greenhouse Gases and Other Pollutants.

Salvage and Disposal

Existing equipment is not believed to hold any salvage value. It will be removed and disposed of properly.



ECM-4.2: Pump Motor Replacement – Heman Park Pool

There are two pumps located in a mechanical room at Heman Park Pool to serve the main filtration system. Each of these pumps has a 40 hp motor. One has been replaced recently while the other is an older less efficient model.

This ECM recommends replacing the older pump motor with a new 40 hp motor The new motor with a minimum efficiency of 93%.

Savings Summary

| Energy Consumption Savings | | | | | Energy Cost Savings | | | | Total Energy Savings | Avoided Maint. Savings | Capital Cost | SPB |
|----------------------------|----|--------|------------|------------|---------------------|-----|-------|-------|----------------------|------------------------|--------------|-----|
| KWh | KW | Months | Steam klbs | Water kgal | KWh | KW | Steam | Water | | | | |
| 15,709 | 5 | 4 | - | - | \$1,076 | \$0 | \$0 | \$0 | \$1,076 | \$0 | \$5,845 | 5.4 |

Table 31 Savings Summary - ECM-4.2 Pump Motor Replacement (Heman Park Pool)

Physical Changes

To the occupant, there will be virtually no visible changes. The equipment will operate at the same level of performance.

Interface with Agency Equipment

Contractor will provide all labor and material to inspect, test, and adjust the mechanical and control systems affecting the given pumps to ensure the systems are performing as near to the original design as possible.

Utility Interruptions and Site Coordination

There will be no significant utility interruptions. There will be some downtime associated with each motor replacement. Any electricity curtailment will be limited to an individual breaker serving the HVAC equipment. In some instances, a sub panel may be momentarily interrupted. These will be coordinated with the facility manager.

Environmental Impacts

The environmental impact from this project will only be positive. By reducing electrical consumption, pollution from power generating plants will also be reduced. By increasing the efficiency of the equipment fan energy will be conserved. See Table 3 Greenhouse Gases and Other Pollutants.

Salvage and Disposal

Existing equipment is not believed to hold any salvage value. It will be removed and disposed of properly.



ECM-4.3: Unit Replacement – Central Garage (Assumes ECM-2.1 Implemented)

The central Garage has two office areas that are conditioned by split systems. The condensing unit and indoor unit for the office in the shop is older and can be replaced with a newer unit. The indoor unit serving the front office has been replaced while the condensing unit is original. This system is not functioning properly and needs to be replaced. This would allow the window units to be removed.

This ECM recommends replacing these units with heat pumps and units of the same configuration. The new split system units with capacities of 5-tons or lesser shall have a higher cooling efficiency EER rating ranging from 13.5 and a higher heating efficiency COP of 4.0. The new heat pump will still have supplemental auxiliary electric heat; however, the electric heat would only be used when the heat pump could not maintain set temperature. New equipment shall be in the same location as existing equipment. See Table 32 Existing HVAC Recommended Replacement Schedule - Central Garage.

| Existing HVAC Recommended Replacement Schedule | | | | | | |
|--|---------------|----------|--------|------|----------|----------|
| Area Served | Unit Type | Quantity | SA cfm | Tons | Clg type | Htg Type |
| Front Office | DX/Elec Split | 1 | 1,000 | 2.5 | DX | Elec |
| Shop Office | DX/Elec Split | 1 | 1,200 | 3.0 | DX | Elec |

Table 32 Existing HVAC Recommended Replacement Schedule - Central Garage

Savings Summary

| Energy Consumption Savings | | | | | Energy Cost Savings | | | | Total Energy Savings | Avoided Maint. Savings | Capital Cost | SPB |
|----------------------------|----|--------|------------|------------|---------------------|-----|-------|-------|----------------------|------------------------|--------------|-----|
| KWh | KW | Months | Steam klbs | Water kgal | KWh | KW | Steam | Water | | | | |
| 23,643 | 8 | 12 | - | - | \$1,620 | \$0 | \$0 | \$0 | \$1,620 | \$903 | \$19,718 | 7.8 |

Table 33 Savings Summary - ECM-4.3 Existing HVAC Replacement - Central Garage

Physical Changes

To the occupant, there will be virtually no visible changes. The equipment will operate at the same level of performance.

Interface with Agency Equipment

Contractor will provide all labor and material to inspect, test, and adjust the mechanical and control systems affecting the given spaces to ensure the HVAC systems are performing in a manner to adequately condition the spaces served.



Utility Interruptions and Site Coordination

There will be no significant utility interruptions. There will be some downtime associated with each motor replacement. Any electricity curtailment will be limited to an individual breaker serving the HVAC equipment. In some instances, a sub panel may be momentarily interrupted. These will be coordinated with the facility manager.

Environmental Impacts

The environmental impact from this project will only be positive. By reducing electrical consumption, pollution from power generating plants will also be reduced. By increasing the efficiency of the equipment fan energy will be conserved. Please see Table 3 Greenhouse Gases and Other Pollutants.

Salvage and Disposal

Existing equipment is not believed to hold any salvage value. It will be removed and disposed of properly.



Appendix A

Lighting Improvements Calculations (Annex) – ECM-1.1



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals:

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|--|---------------|------------------------------|----------------------------|-----------------------|---|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Police Station - Basement - Corridor | 1x4, 2L T12 recessed cove strip w/standard ballast | 15 | 73 | 1095 | 3416.4 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 15 | 51 | 765 | 330 | 3120 | 1,029.60 | 61.64 | 37 | 45 | 2 | 1,260 | 20.44 |
| Police Station - Basement - Break Room | 2x4, 4L T12 recessed troffer w/standard ballast | 5 | 144 | 720 | 2246.4 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 5 | 86 | 430 | 290 | 3120 | 904.80 | 54.17 | 42 | 50 | 2 | 470 | 8.68 |
| Police Station - Basement - Break Room | 2x2, 2 U-lamp T12 recessed troffer w/standard ballast | 1 | 73 | 73 | 227.76 | Re-lamp w/2 31W T8 U- lamps w/high-efficiency, electronic ballast | 1 | 60 | 60 | 13 | 3120 | 40.56 | 2.43 | 37 | 45 | 2 | 84 | 34.59 |
| Police Station - Basement - Break Room | 2-lamp 60W Incandescent Surface Round | 1 | 120 | 120 | 6.24 | Re-lamp w/2 13W compact fluorescent screw-type lamps | 1 | 26 | 26 | 94 | 52 | 4.89 | 0.29 | 5 | 15 | 1 | 21 | 71.76 |
| Police Station - Basement - Fire Chief's Office | 2x4, 4L T12 recessed troffer w/standard ballast | 10 | 144 | 1440 | 4492.8 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 10 | 86 | 860 | 580 | 3120 | 1,809.60 | 108.34 | 42 | 50 | 2 | 940 | 8.68 |
| Police Station - Basement - Corridor | 26W TTT CFL Recessed Can | 10 | 26 | 260 | 811.2 | Do Nothing - Fixture To Remain | 10 | 26 | 260 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| Police Station - Basement - Corridor | Incandescent Exit Sign | 3 | 20 | 60 | 525.6 | Replace with LED Exit Sign | 3 | 3 | 9 | 51 | 8760 | 446.76 | 26.75 | 55 | 65 | 5 | 375 | 14.02 |
| Police Station - Basement - E.O.C. Room | 26W TTT CFL Recessed Can | 1 | 26 | 26 | 13.52 | Do Nothing - Fixture To Remain | 1 | 26 | 26 | 0 | 520 | 0.00 | 0.00 | | | | | |
| Police Station - Basement - E.O.C. Room | 1x2, 2L T12 wall mount w/standard ballast | 1 | 48 | 48 | 24.96 | Re-lamp w/2 17W T8 lamps w/high-efficiency, electronic ballast | 1 | 34 | 34 | 14 | 520 | 7.28 | 0.44 | 37 | 45 | 2 | 84 | 192.73 |
| Police Station - Basement - E.O.C. Room | 1x4, 2L T12 surface wrap w/standard ballast | 27 | 73 | 1971 | 1024.92 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 27 | 51 | 1377 | 594 | 520 | 308.88 | 18.49 | 37 | 45 | 2 | 2,268 | 122.64 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|--|---------------|------------------------------|----------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Police Station - Basement - E.O.C. Room | 1x4, 2L T12 surface wrap w/standard ballast | 2 | 73 | 146 | 1278.96 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 2 | 51 | 102 | 44 | 8760 | 385.44 | 23.08 | 37 | 45 | 2 | 168 | 7.28 |
| Police Station - Basement - E.O.C. Kitchen | 2L T12 strip w/standard ballast | 1 | 73 | 73 | 18.98 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 22 | 260 | 5.72 | 0.34 | 37 | 45 | 2 | 84 | 245.29 |
| Police Station - Basement - E.O.C. Mechanical Room | 2L T12 strip w/standard ballast | 2 | 73 | 146 | 7.592 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 2 | 51 | 102 | 44 | 52 | 2.29 | 0.14 | 37 | 45 | 2 | 168 | 1226.43 |
| Police Station - Basement - E.O.C. Mechanical Room | 52W Exposed Incandescent | 2 | 52 | 104 | 5.408 | Re-lamp w/13W compact fluorescent screw-type lamps | 2 | 13 | 26 | 78 | 52 | 4.06 | 0.24 | 5 | 15 | 1 | 42 | 172.96 |
| Police Station - Basement - E.O.C. | Incandescent Exit Sign | 2 | 20 | 40 | 350.4 | Replace with LED Exit Sign | 2 | 3 | 6 | 34 | 8760 | 297.84 | 17.83 | 55 | 65 | 5 | 250 | 14.02 |
| Police Station - Basement - E.O.C.Communication s Room | 2L T12 strip w/standard ballast | 3 | 73 | 219 | 11.388 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 3 | 51 | 153 | 66 | 52 | 3.43 | 0.21 | 37 | 45 | 2 | 252 | 1226.43 |
| Police Station - Basement - E.O.C.Storeroom | 2L T12 surface wrap w/standard ballast | 5 | 73 | 365 | 18.98 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 5 | 51 | 255 | 110 | 52 | 5.72 | 0.34 | 37 | 45 | 2 | 420 | 1226.43 |
| Police Station - Basement - E.O.C.Restroom | 2L T12 surface wrap w/standard ballast | 2 | 73 | 146 | 7.592 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 2 | 51 | 102 | 44 | 52 | 2.29 | 0.14 | 37 | 45 | 2 | 168 | 1226.43 |
| Police Station - Basement - Shooting Range | PAR 38 Halogen Flood | 6 | 75 | 450 | 117 | Do Nothing - Fixture To Remain | 6 | 75 | 450 | 0 | 260 | 0.00 | 0.00 | | | | | |
| Police Station - Basement - Shooting Range | 52W Exposed Incandescent | 5 | 52 | 260 | 67.6 | Re-lamp w/13W compact fluorescent screw-type lamps | 5 | 13 | 65 | 195 | 260 | 50.70 | 3.04 | 5 | 15 | 1 | 105 | 34.59 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|---|---------------|------------------------------|----------------------------|-----------------------|---|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Police Station - Basement - Shooting Range File Room | 2L T12 strip w/standard ballast | 4 | 73 | 292 | 15.184 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 4 | 51 | 204 | 88 | 52 | 4.58 | 0.27 | 37 | 45 | 2 | 336 | 1226.43 |
| Police Station - Basement - Files | 1x8, 2L 75W T12 strip w/standard ballast | 2 | 158 | 316 | 16.432 | Re-lamp w/2 59W T8 8' lamps w/high-efficiency, electronic ballast | 2 | 112 | 224 | 92 | 52 | 4.78 | 0.29 | 37 | 45 | 2 | 168 | 586.56 |
| Police Station - Basement - Corridor | 2L T12 strip w/standard ballast | 2 | 73 | 146 | 15.184 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 2 | 51 | 102 | 44 | 104 | 4.58 | 0.27 | 37 | 45 | 2 | 168 | 613.22 |
| Police Station - Basement - Closet | 52W Exposed Incandescent | 1 | 52 | 52 | 2.704 | Re-lamp w/13W compact fluorescent screw-type lamps | 1 | 13 | 13 | 39 | 52 | 2.03 | 0.12 | 5 | 15 | 1 | 21 | 172.96 |
| Police Station - Basement - Weapons Storage | 2L T12 strip w/standard ballast | 4 | 73 | 292 | 75.92 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 4 | 51 | 204 | 88 | 260 | 22.88 | 1.37 | 37 | 45 | 2 | 336 | 245.29 |
| Police Station - Basement - Bike Storage | 100W Exposed Incandescent | 14 | 100 | 1400 | 72.8 | Re-lamp w/26W compact fluorescent screw-type lamps | 14 | 26 | 364 | 1036 | 52 | 53.87 | 3.23 | 5 | 15 | 1 | 294 | 91.15 |
| Police Station - Basement - Stairs | 2-lamp 60W Incandescent Surface | 2 | 120 | 240 | 62.4 | Re-lamp w/2 13W compact fluorescent screw-type lamps | 2 | 26 | 52 | 188 | 260 | 48.88 | 2.93 | 10 | 25 | 1 | 72 | 24.60 |
| Police Station - 1st Floor - Print Shop | 2x4, 4L T12 recessed troffer w/standard ballast | 6 | 144 | 864 | 1797.12 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 6 | 86 | 516 | 348 | 2080 | 723.84 | 43.34 | 42 | 50 | 2 | 564 | 13.01 |
| Police Station - 1st Floor - Police Dispatch | 2x4, 4L T12 recessed volumetric w/standard ballast | 21 | 144 | 3024 | 9434.88 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 21 | 86 | 1806 | 1218 | 3120 | 3,800.16 | 227.52 | 42 | 50 | 2 | 1,974 | 8.68 |
| Police Station - 1st Floor - Police Dispatch | 2x4, 4L T12 recessed volumetric w/standard ballast | 10 | 144 | 1440 | 12614.4 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 10 | 86 | 860 | 580 | 8760 | 5,080.80 | 304.19 | 42 | 50 | 2 | 940 | 3.09 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|--|---------------|------------------------------|----------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Police Station - 1st Floor - Entry Corridor | 1x4, 1L T12 wall strip w/standard ballast | 8 | 42 | 336 | 1048.32 | Re-lamp w/1 28W T8 lamp w/high-efficiency, electronic ballast | 8 | 26 | 208 | 128 | 3120 | 399.36 | 23.91 | 37 | 45 | 2 | 672 | 28.11 |
| Police Station - Basement - Men's Cells | 2L 3', T12 strip w/standard ballast | 1 | 65 | 65 | 284.7 | Re-lamp w/2 3', 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 45 | 45 | 20 | 4380 | 87.60 | 5.24 | 37 | 45 | 2 | 84 | 16.02 |
| Police Station - Basement - Men's Cells | 1x4, 2L T12 strip w/standard ballast | 2 | 73 | 146 | 639.48 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 2 | 51 | 102 | 44 | 4380 | 192.72 | 11.54 | 37 | 45 | 2 | 168 | 14.56 |
| Police Station - Basement - Men's Cells | PAR 38 Halogen Flood | 2 | 75 | 150 | 657 | Do Nothing - Fixture To Remain | 2 | 75 | 150 | 0 | 4380 | 0.00 | 0.00 | | | | | |
| Police Station - Basement - Men's Cells | 1x4, 2L T12 wall-mounted strip w/standard ballast | 1 | 73 | 73 | 319.74 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 22 | 4380 | 96.36 | 5.77 | 37 | 45 | 2 | 84 | 14.56 |
| Police Station - Basement - Stairs | 1x1, 60W Incandescent Surface | 1 | 60 | 60 | 262.8 | Re-lamp w/1 13W compact fluorescent screw-type lamps | 1 | 13 | 13 | 47 | 4380 | 205.86 | 12.32 | 5 | 15 | 1 | 21 | 1.70 |
| Police Station - 1st Floor - Private Offices | 2x4, 4L T12 recessed volumetric w/standard ballast | 12 | 144 | 1728 | 5391.36 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 12 | 86 | 1032 | 696 | 3120 | 2,171.52 | 130.01 | 42 | 50 | 2 | 1,128 | 8.68 |
| Police Station - 1st Floor - Conference Room | 2x4, 2L T12 recessed troffer w/standard ballast | 4 | 73 | 292 | 911.04 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 4 | 51 | 204 | 88 | 3120 | 274.56 | 16.44 | 37 | 45 | 2 | 336 | 20.44 |
| Police Station - 1st Floor - Men's Locker Room | 2x4, 4L T12 recessed troffer w/standard ballast | 6 | 144 | 864 | 2695.68 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 6 | 86 | 516 | 348 | 3120 | 1,085.76 | 65.00 | 42 | 50 | 2 | 564 | 8.68 |
| Police Station - 1st Floor - Women's Locker Room | 2x4, 4L T12 recessed troffer w/standard ballast | 4 | 144 | 576 | 1797.12 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 4 | 86 | 344 | 232 | 3120 | 723.84 | 43.34 | 42 | 50 | 2 | 376 | 8.68 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|---|---------------|------------------------------|----------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Police Station - 1st Floor - Mechanical Storage | 100W Exposed Incandescent | 3 | 100 | 300 | 15.6 | Re-lamp w/26W compact fluorescent screw-type lamps | 3 | 26 | 78 | 222 | 52 | 11.54 | 0.69 | 5 | 15 | 1 | 63 | 91.15 |
| Police Station - 1st Floor - Offices | 1x4, 2L T12 recessed troffer w/standard ballast | 9 | 73 | 657 | 2049.84 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 9 | 51 | 459 | 198 | 3120 | 617.76 | 36.99 | 37 | 45 | 2 | 756 | 20.44 |
| Police Station - 1st Floor - Cell Entry | 2x4, 2L T12 recessed troffer w/standard ballast | 6 | 73 | 438 | 1366.56 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 6 | 51 | 306 | 132 | 3120 | 411.84 | 24.66 | 37 | 45 | 2 | 504 | 20.44 |
| Police Station - 1st Floor - Cell Entry | 40W Recessed Incandescent Can | 2 | 40 | 80 | 249.6 | Re-lamp w/9W compact fluorescent screw-type lamps | 2 | 9 | 18 | 62 | 3120 | 193.44 | 11.58 | 5 | 15 | 1 | 42 | 3.63 |
| Police Station - 1st Floor - Hall | 1x1, 2-lamp 60W Recessed Incandescent Square | 1 | 120 | 120 | 1051.2 | Re-lamp w/2 13W compact fluorescent screw-type lamps | 1 | 26 | 26 | 94 | 8760 | 823.44 | 49.30 | 10 | 25 | 1 | 36 | 0.73 |
| Police Station - 1st Floor - Hall | PAR 38 Halogen Flood | 1 | 75 | 75 | 657 | Do Nothing - Fixture To Remain | 1 | 75 | 75 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| Police Station - 1st Floor - Men's Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | 4 | 144 | 576 | 1797.12 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 4 | 86 | 344 | 232 | 3120 | 723.84 | 43.34 | 42 | 50 | 2 | 376 | 8.68 |
| Police Station - 1st Floor - Women's Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | 4 | 144 | 576 | 1797.12 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 4 | 86 | 344 | 232 | 3120 | 723.84 | 43.34 | 42 | 50 | 2 | 376 | 8.68 |
| Police Station - 1st Floor - Women's Restroom | 2-lamp 60W Incandescent Vanity | 1 | 120 | 120 | 374.4 | Re-lamp w/2 13W compact fluorescent screw-type lamps | 1 | 26 | 26 | 94 | 3120 | 293.28 | 17.56 | 10 | 25 | 1 | 36 | 2.05 |
| Police Station - 1st Floor - Entry | PAR 38 Halogen Flood Cans | 9 | 75 | 675 | 2106 | Do Nothing - Fixture To Remain | 9 | 75 | 675 | 0 | 3120 | 0.00 | 0.00 | | | | | |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|---|---------------|------------------------------|----------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Police Station - 1st Floor - Entry | 2x4, 4L T12 recessed volumetric w/standard ballast | 1 | 144 | 144 | 449.28 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 58 | 3120 | 180.96 | 10.83 | 42 | 50 | 2 | 94 | 8.68 |
| Police Station - 1st Floor - Field Ops | 2x4, 4L T12 recessed volumetric w/standard ballast | 2 | 144 | 288 | 898.56 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 2 | 86 | 172 | 116 | 3120 | 361.92 | 21.67 | 42 | 50 | 2 | 188 | 8.68 |
| Police Station - 1st Floor - Field Ops | 2x4, 4L T12 recessed troffer w/standard ballast | 1 | 144 | 144 | 449.28 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 58 | 3120 | 180.96 | 10.83 | 42 | 50 | 2 | 94 | 8.68 |
| Police Station - 1st Floor - Field Ops | 2x2, 2 U-lamp T12 recessed troffer w/standard ballast | 1 | 73 | 73 | 227.76 | Re-lamp w/2 31W T8 U-lamps w/high-efficiency, electronic ballast | 1 | 60 | 60 | 13 | 3120 | 40.56 | 2.43 | 37 | 45 | 2 | 84 | 34.59 |
| Police Station - 1st Floor - Traffic | 2x4, 4L T12 recessed troffer w/standard ballast | 3 | 144 | 432 | 1347.84 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 3 | 86 | 258 | 174 | 3120 | 542.88 | 32.50 | 42 | 50 | 2 | 282 | 8.68 |
| Police Station - 1st Floor - Traffic | 1x4, 2L T12 recessed troffer w/standard ballast | 4 | 73 | 292 | 911.04 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 4 | 51 | 204 | 88 | 3120 | 274.56 | 16.44 | 37 | 45 | 2 | 336 | 20.44 |
| Police Station - 2nd Floor - Offices | 2x4, 4L T12 recessed volumetric w/standard ballast | 17 | 144 | 2448 | 7637.76 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 17 | 86 | 1462 | 986 | 3120 | 3,076.32 | 184.18 | 42 | 50 | 2 | 1,598 | 8.68 |
| Police Station - 2nd Floor - Offices | 2x4, 4L T12 recessed volumetric w/standard ballast | 5 | 144 | 720 | 187.2 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 5 | 86 | 430 | 290 | 260 | 75.40 | 4.51 | 42 | 50 | 2 | 470 | 104.12 |
| Police Station - 2nd Floor - Hall | 2L T12 strip w/standard ballast | 1 | 73 | 73 | 227.76 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 22 | 3120 | 68.64 | 4.11 | 37 | 45 | 2 | 84 | 20.44 |
| Police Station - 2nd Floor - Interrogation Room | 2x4, 4L T12 recessed troffer w/standard ballast | 6 | 144 | 864 | 449.28 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 6 | 86 | 516 | 348 | 520 | 180.96 | 10.83 | 42 | 50 | 2 | 564 | 52.06 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|---|---------------|------------------------------|----------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Police Station - 2nd Floor - Men's Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | 1 | 144 | 144 | 449.28 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 58 | 3120 | 180.96 | 10.83 | 42 | 50 | 2 | 94 | 8.68 |
| Police Station - 2nd Floor - Women's Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | 1 | 144 | 144 | 449.28 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 58 | 3120 | 180.96 | 10.83 | 42 | 50 | 2 | 94 | 8.68 |
| Police Station - 2nd Floor - Entry | 2L T12 strip w/standard ballast | 6 | 73 | 438 | 3836.88 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 6 | 51 | 306 | 132 | 8760 | 1,156.32 | 69.23 | 37 | 45 | 2 | 504 | 7.28 |
| Police Station - 2nd Floor - Narcotics Evidence Room | 2L T12 strip w/standard ballast | 8 | 73 | 584 | 303.68 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 8 | 51 | 408 | 176 | 520 | 91.52 | 5.48 | 37 | 45 | 2 | 672 | 122.64 |
| Police Station - 2nd Floor - Entry | Incandescent Exit Sign | 2 | 20 | 40 | 350.4 | Replace with LED Exit Sign | 2 | 3 | 6 | 34 | 8760 | 297.84 | 17.83 | 55 | 65 | 5 | 250 | 14.02 |
| Police Station - 2nd Floor - Homicide Evidence Room | 2x4, 4L T12 recessed volumetric w/standard ballast | 4 | 144 | 576 | 299.52 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 4 | 86 | 344 | 232 | 520 | 120.64 | 7.22 | 42 | 50 | 2 | 376 | 52.06 |
| Police Station - 2nd Floor - Lobby | 1x2, 2L T12 pendant strip w/standard ballast | 5 | 48 | 240 | 748.8 | Re-lamp w/2 17W T8 lamps w/high-efficiency, electronic ballast | 5 | 34 | 170 | 70 | 3120 | 218.40 | 13.08 | 37 | 45 | 2 | 420 | 32.12 |
| Police Station - 3rd Floor - Offices | 2x4, 4L T12 recessed volumetric w/standard ballast | 17 | 144 | 2448 | 7637.76 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 17 | 86 | 1462 | 986 | 3120 | 3,076.32 | 184.18 | 42 | 50 | 2 | 1,598 | 8.68 |
| Police Station - 3rd Floor - Mechanical Room | 2x4, 2L T12 parabolic strip w/standard ballast | 4 | 73 | 292 | 30.368 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 4 | 51 | 204 | 88 | 104 | 9.15 | 0.55 | 37 | 45 | 2 | 336 | 613.22 |
| Police Station - 3rd Floor - Offices | Incandescent Exit Sign | 2 | 20 | 40 | 350.4 | Replace with LED Exit Sign | 2 | 3 | 6 | 34 | 8760 | 297.84 | 17.83 | 55 | 65 | 5 | 250 | 14.02 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|---|---------------|------------------------------|----------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Police Station - 3rd Floor - Stairs | 1x4, 2L T12 surface wrap w/standard ballast | 2 | 73 | 146 | 455.52 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 2 | 0 | 0 | 146 | 3120 | 455.52 | 27.27 | 37 | 45 | 2 | 168 | 6.16 |
| Police Station - 3rd Floor - Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | 1 | 144 | 144 | 449.28 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 58 | 3120 | 180.96 | 10.83 | 42 | 50 | 2 | 94 | 8.68 |
| Police Station - 3rd Floor - Elevator Lobby | 2x2, 2 U-lamp T12 recessed troffer w/standard ballast | 1 | 73 | 73 | 227.76 | Re-lamp w/2 31W T8 U-lamps w/high-efficiency, electronic ballast | 1 | 60 | 60 | 13 | 3120 | 40.56 | 2.43 | 37 | 45 | 2 | 84 | 34.59 |
| Police Station - Exterior Entry | 1x1, 60W Incandescent Surface Square | 2 | 60 | 120 | 525.6 | Re-lamp w/ 13W compact fluorescent screw-type lamps | 2 | 13 | 26 | 94 | 4380 | 411.72 | 24.65 | 5 | 15 | 1 | 42 | 1.70 |
| Fire Station - 1st Floor Apparatus Bay | 400W, High-Pressure Sodium Low Bay w/standard ballast | 6 | 460 | 2760 | 12088.8 | T5HO High Bay w/electronic ballast and integral occupancy sensor | 7 | 258 | 1806 | 954 | 4380 | 4,178.52 | 250.17 | 313 | 73 | 25 | 2,877 | 11.50 |
| Fire Station - 1st Floor Apparatus Bay | 250W, Mercury Vapor Wall Mount w/standard ballast | 1 | 295 | 295 | 1292.1 | Fixture to be Removed | 1 | 0 | 0 | 295 | 4380 | 1,292.10 | 77.36 | 0 | 25 | 25 | 50 | 0.65 |
| Fire Station - 1st Floor Apparatus Bay | 2L T8 strip w/electronic ballast | 3 | 59 | 177 | 552.24 | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| Fire Station - 1st Floor Office | 1x4, 2L T12 recessed troffer w/standard ballast | 4 | 73 | 292 | 911.04 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 4 | 51 | 204 | 88 | 3120 | 274.56 | 16.44 | 37 | 45 | 2 | 336 | 20.44 |
| Fire Station - 1st Floor Stairs | 100W Incandescent Pendant | 1 | 100 | 100 | 5.2 | Re-lamp w/26W compact fluorescent screw-type lamps | 1 | 26 | 26 | 74 | 52 | 3.85 | 0.23 | 5 | 15 | 1 | 21 | 91.15 |
| Fire Station - 1st Floor Mechanical Room | 100W Exposed Incandescent | 2 | 100 | 200 | 10.4 | Re-lamp w/26W compact fluorescent screw-type lamps | 2 | 26 | 52 | 148 | 52 | 7.70 | 0.46 | 5 | 15 | 1 | 42 | 91.15 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|--|---------------|------------------------------|----------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Fire Station - 1st Floor Corridor | 2-lamp 60W Incandescent Surface Square | 1 | 120 | 120 | 6.24 | Re-lamp w/2 13W compact fluorescent screw-type lamps | 1 | 26 | 26 | 94 | 52 | 4.89 | 0.29 | 10 | 25 | 1 | 36 | 123.02 |
| Fire Station - 1st Floor - Store Room | 100W Exposed Incandescent | 4 | 100 | 400 | 20.8 | Re-lamp w/26W compact fluorescent screw-type lamps | 4 | 26 | 104 | 296 | 52 | 15.39 | 0.92 | 5 | 15 | 1 | 84 | 91.15 |
| Fire Station - 1st Floor - Kitchen | 2L T12 strip w/standard ballast | 2 | 73 | 146 | 455.52 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 2 | 51 | 102 | 44 | 3120 | 137.28 | 8.22 | 37 | 45 | 2 | 168 | 20.44 |
| Fire Station - 1st Floor - Kitchen | 1L 3' T8 strip w/electronic ballast | 1 | 24 | 24 | 74.88 | Do Nothing - Fixture To Remain | 1 | 24 | 24 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| Fire Station - 1st Floor - Break Room | 4-lamp 13W CFL Ceiling Fan | 2 | 52 | 104 | 324.48 | Do Nothing - Fixture To Remain | 2 | 52 | 104 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| Fire Station - 2nd Floor Restroom | 1x1, 60W Incandescent Recessed Square | 2 | 60 | 120 | 124.8 | Re-lamp w/ 13W compact fluorescent screw-type lamps | 2 | 13 | 26 | 94 | 1040 | 97.76 | 5.85 | 5 | 15 | 1 | 42 | 7.18 |
| Fire Station - 2nd Floor Showers | 60W Incandescent Recessed Can | 2 | 60 | 120 | 124.8 | Re-lamp w/ 13W compact fluorescent screw-type lamps | 2 | 13 | 26 | 94 | 1040 | 97.76 | 5.85 | 5 | 15 | 1 | 42 | 7.18 |
| Fire Station - 2nd Floor Sleep Area | 1x2, 2L T12 surface wrap w/standard ballast | 9 | 42 | 378 | 1572.48 | Re-lamp w/2 17W, 2' T8 lamps w/high-efficiency, electronic ballast | 9 | 26 | 234 | 144 | 4160 | 599.04 | 35.86 | 37 | 45 | 2 | 756 | 21.08 |
| Fire Station - 2nd Floor Weight Room | 1x4, 2L T12 surface wrap w/standard ballast | 8 | 73 | 584 | 607.36 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 8 | 51 | 408 | 176 | 1040 | 183.04 | 10.96 | 37 | 45 | 2 | 672 | 61.32 |
| Fire Station - 2nd Floor Media Room | 1x4, 2L T12 surface wrap w/standard ballast | 4 | 73 | 292 | 151.84 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 4 | 51 | 204 | 88 | 520 | 45.76 | 2.74 | 37 | 45 | 2 | 336 | 122.64 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|-------------------------------------|---|---------------|------------------------------|----------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Fire Station - 2nd Floor Restroom | 1x4, 2L T12 surface vanity w/standard ballast | 2 | 73 | 146 | 607.36 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 2 | 51 | 102 | 44 | 4160 | 183.04 | 10.96 | 37 | 45 | 2 | 168 | 15.33 |
| Fire Station - 2nd Floor Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | 1 | 144 | 144 | 599.04 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 58 | 4160 | 241.28 | 14.45 | 42 | 50 | 2 | 94 | 6.51 |
| Fire Station - 2nd Floor Storage | 90W Exposed Incandescent | 1 | 90 | 90 | 4.68 | Re-lamp w/26W compact fluorescent screw-type lamps | 1 | 26 | 26 | 64 | 52 | 3.33 | 0.20 | 5 | 20 | 1 | 26 | 130.49 |
| Fire Station - 2nd Floor Sleep Room | 4-lamp 52W Incandescent Ceiling Fan | 1 | 208 | 208 | 54.08 | Re-lamp w/4 13W compact fluorescent screw-type lamps | 1 | 52 | 52 | 156 | 260 | 40.56 | 2.43 | 20 | 25 | 4 | 49 | 20.18 |
| Fire Station - 2nd Floor Stairs | Incandescent Exit Sign | 2 | 20 | 40 | 350.4 | Replace with LED Exit Sign | 2 | 3 | 6 | 34 | 8760 | 297.84 | 17.83 | 55 | 65 | 5 | 250 | 14.02 |
| Fire Station - 2nd Floor Stairs | 2L T12 wall strip w/standard ballast | 2 | 42 | 84 | 43.68 | Re-lamp w/2 28 T8 lamps w/high-efficiency, electronic ballast | 2 | 26 | 52 | 32 | 520 | 16.64 | 1.00 | 37 | 45 | 2 | 168 | 168.63 |
| Fire Station - 2nd Floor Stairs | 1L T12 wall strip w/standard ballast | 1 | 42 | 42 | 174.72 | Re-lamp w/1 28W T8 lamp w/high-efficiency, electronic ballast | 1 | 26 | 26 | 16 | 4160 | 66.56 | 3.98 | 37 | 45 | 2 | 84 | 21.08 |



Fixture ECM Totals (Continued):

| | Lighting Retrofit: | Controls Totals: | Total |
|--|--------------------|------------------|----------|
| Total Annual Demand Savings (kW): | 17 | - | 17 |
| Total Energy Consumption Savings (kWh/yr) | 43,582 | 15,353 | 58,934 |
| Total Energy Savings / Year (\$) | \$2,609 | \$919 | \$3,528 |
| Total Cost of Material and Labor (\$) | \$32,731 | \$11,154 | \$43,885 |
| St. Louis Price Adjustment (\$) | \$33,582 | \$11,444 | \$45,026 |
| Total Tax, Overhead & Profit, and Contingency (\$) | \$11,754 | \$4,005 | \$15,759 |
| Total Installed Cost (\$) | \$45,336 | \$15,449 | \$60,785 |
| Total Simple Payback (Years) | 17.38 | 16.81 | 17.23 |



Detailed Energy Study University City Municipal Buildings

Controls Totals:

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts Saved / Fixture (W) | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|---|--|---------------|---------------------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| Police Station - Basement - Corridor | 1x4, 2L T12 recessed cove strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 15 | 51 | 765 | 4 | 780 | 596.70 | 35.72 | 90 | 53 | 572 | 16.01 |
| Police Station - Basement - Break Room | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 5 | 86 | 430 | 1 | 780 | 335.40 | 20.08 | 90 | 53 | 143 | 7.12 |
| Police Station - Basement - Break Room | 2x2, 2 U-lamp T12 recessed troffer w/standard ballast | Re-lamp w/2 31W T8 U-lamps w/high-efficiency, electronic ballast | 1 | 60 | 60 | 1 | 780 | 46.80 | 2.80 | 90 | 53 | 143 | 51.04 |
| Police Station - Basement - Fire Chief's Office | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 10 | 86 | 860 | 4 | 780 | 670.80 | 40.16 | 90 | 53 | 572 | 14.24 |
| Police Station - Basement - E.O.C. Room | 1x2, 2L T12 wall mount w/standard ballast | Re-lamp w/2 17W T8 lamps w/high-efficiency, electronic ballast | 1 | 34 | 34 | 1 | 130 | 4.42 | 0.26 | 90 | 53 | 143 | 540.39 |
| Police Station - Basement - E.O.C. Room | 1x4, 2L T12 surface wrap w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 27 | 51 | 1377 | 2 | 130 | 179.01 | 10.72 | 90 | 53 | 286 | 26.69 |
| Police Station - Basement - E.O.C. Room | 1x4, 2L T12 surface wrap w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 2 | 51 | 102 | 1 | 2190 | 223.38 | 13.37 | 90 | 53 | 143 | 10.69 |
| Police Station - Basement - E.O.C. Kitchen | 2L T12 strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 1 | 65 | 3.32 | 0.20 | 90 | 53 | 143 | 720.52 |
| Police Station - Basement - Weapons Storage | 2L T12 strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 4 | 51 | 204 | 1 | 65 | 13.26 | 0.79 | 90 | 53 | 143 | 180.13 |
| Police Station - 1st Floor - Print Shop | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 6 | 86 | 516 | 1 | 520 | 268.32 | 16.06 | 90 | 53 | 143 | 8.90 |



Detailed Energy Study University City Municipal Buildings

Controls Totals (Continued):

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts Saved / Fixture (W) | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|--|--|---------------|---------------------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| Police Station - 1st Floor - Police Dispatch | 2x4, 4L T12 recessed volumetric w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 21 | 86 | 1806 | 3 | 780 | 1408.68 | 84.34 | 90 | 53 | 429 | 5.09 |
| Police Station - 1st Floor - Police Dispatch | 2x4, 4L T12 recessed volumetric w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 10 | 86 | 860 | 2 | 2190 | 1883.40 | 112.76 | 90 | 53 | 286 | 2.54 |
| Police Station - 1st Floor - Entry Corridor | 1x4, 1L T12 wall strip w/standard ballast | Re-lamp w/1 28W T8 lamp w/high-efficiency, electronic ballast | 8 | 26 | 208 | 2 | 780 | 162.24 | 9.71 | 90 | 53 | 286 | 29.44 |
| Police Station - 1st Floor - Private Offices | 2x4, 4L T12 recessed volumetric w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 12 | 86 | 1032 | 3 | 780 | 804.96 | 48.19 | 90 | 53 | 429 | 8.90 |
| Police Station - 1st Floor - Conference Room | 2x4, 2L T12 recessed troffer w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 4 | 51 | 204 | 1 | 780 | 159.12 | 9.53 | 90 | 53 | 143 | 15.01 |
| Police Station - 1st Floor - Men's Locker Room | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 6 | 86 | 516 | 2 | 780 | 402.48 | 24.10 | 90 | 53 | 286 | 11.87 |
| Police Station - 1st Floor - Women's Locker Room | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 4 | 86 | 344 | 1 | 780 | 268.32 | 16.06 | 90 | 53 | 143 | 8.90 |
| Police Station - 1st Floor - Offices | 1x4, 2L T12 recessed troffer w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 9 | 51 | 459 | 3 | 780 | 358.02 | 21.43 | 90 | 53 | 429 | 20.01 |
| Police Station - 1st Floor - Men's Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 4 | 86 | 344 | 1 | 780 | 268.32 | 16.06 | 90 | 53 | 143 | 8.90 |
| Police Station - 1st Floor - Women's Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 4 | 86 | 344 | 1 | 780 | 268.32 | 16.06 | 90 | 53 | 143 | 8.90 |



Detailed Energy Study University City Municipal Buildings

Controls Totals (Continued):

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts Saved / Fixture (W) | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|---|--|---------------|---------------------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| Police Station - 1st Floor - Entry | 2x4, 4L T12 recessed volumetric w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 1 | 780 | 67.08 | 4.02 | 90 | 53 | 143 | 35.61 |
| Police Station - 1st Floor - Field Ops | 2x4, 4L T12 recessed volumetric w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 2 | 86 | 172 | 1 | 780 | 134.16 | 8.03 | 90 | 53 | 143 | 17.80 |
| Police Station - 1st Floor - Field Ops | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 1 | 780 | 67.08 | 4.02 | 90 | 53 | 143 | 35.61 |
| Police Station - 1st Floor - Field Ops | 2x2, 2 U-lamp T12 recessed troffer w/standard ballast | Re-lamp w/2 31W T8 U-lamps w/high-efficiency, electronic ballast | 1 | 60 | 60 | 1 | 780 | 46.80 | 2.80 | 90 | 53 | 143 | 51.04 |
| Police Station - 1st Floor - Traffic | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 3 | 86 | 258 | 1 | 780 | 201.24 | 12.05 | 90 | 53 | 143 | 11.87 |
| Police Station - 1st Floor - Traffic | 1x4, 2L T12 recessed troffer w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 4 | 51 | 204 | 1 | 780 | 159.12 | 9.53 | 90 | 53 | 143 | 15.01 |
| Police Station - 2nd Floor - Offices | 2x4, 4L T12 recessed volumetric w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 17 | 86 | 1462 | 5 | 780 | 1140.36 | 68.27 | 90 | 53 | 715 | 10.47 |
| Police Station - 2nd Floor - Offices | 2x4, 4L T12 recessed volumetric w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 5 | 86 | 430 | 2 | 65 | 27.95 | 1.67 | 90 | 53 | 286 | 170.91 |
| Police Station - 2nd Floor - Hall | 2L T12 strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 1 | 780 | 39.78 | 2.38 | 90 | 53 | 143 | 60.04 |
| Police Station - 2nd Floor - Interrogation Room | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 6 | 86 | 516 | 2 | 130 | 67.08 | 4.02 | 90 | 53 | 286 | 71.21 |



Detailed Energy Study University City Municipal Buildings

Controls Totals (Continued):

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts Saved / Fixture (W) | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|---|--|---------------|---------------------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| Police Station - 2nd Floor - Men's Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 1 | 780 | 67.08 | 4.02 | 90 | 53 | 143 | 35.61 |
| Police Station - 2nd Floor - Women's Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 1 | 780 | 67.08 | 4.02 | 90 | 53 | 143 | 35.61 |
| Police Station - 2nd Floor - Entry | 2L T12 strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 6 | 51 | 306 | 2 | 2190 | 670.14 | 40.12 | 90 | 53 | 286 | 7.13 |
| Police Station - 2nd Floor - Narcotics Evidence Room | 2L T12 strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 8 | 51 | 408 | 2 | 130 | 53.04 | 3.18 | 90 | 53 | 286 | 90.06 |
| Police Station - 2nd Floor - Homicide Evidence Room | 2x4, 4L T12 recessed volumetric w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 4 | 86 | 344 | 1 | 130 | 44.72 | 2.68 | 90 | 53 | 143 | 53.41 |
| Police Station - 2nd Floor - Lobby | 1x2, 2L T12 pendant strip w/standard ballast | Re-lamp w/2 17W T8 lamps w/high-efficiency, electronic ballast | 5 | 34 | 170 | 2 | 780 | 132.60 | 7.94 | 90 | 53 | 286 | 36.03 |
| Police Station - 3rd Floor - Offices | 2x4, 4L T12 recessed volumetric w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 17 | 86 | 1462 | 5 | 780 | 1140.36 | 68.27 | 90 | 53 | 715 | 10.47 |
| Police Station - 3rd Floor - Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 1 | 780 | 67.08 | 4.02 | 90 | 53 | 143 | 35.61 |
| Police Station - 3rd Floor - Elevator Lobby | 2x2, 2 U-lamp T12 recessed troffer w/standard ballast | Re-lamp w/2 31W T8 U-lamps w/high-efficiency, electronic ballast | 1 | 60 | 60 | 1 | 780 | 46.80 | 2.80 | 90 | 53 | 143 | 51.04 |
| Fire Station - 1st Floor - Apparatus Bay | 400W, High-Pressure Sodium Low Bay w/standard ballast | Replace with 4-lamp T5HO High Bay w/electronic ballast and integral occupancy sensor | 7 | 258 | 1806 | 7 | 1095 | 1977.57 | 118.40 | 0 | 0 | 0 | 0.00 |



Detailed Energy Study University City Municipal Buildings

Controls Totals (Continued):

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts Saved / Fixture (W) | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|---|--|---------------|---------------------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| Fire Station - 1st Floor - Office | 1x4, 2L T12 recessed troffer w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 4 | 51 | 204 | 1 | 780 | 159.12 | 9.53 | 90 | 53 | 143 | 15.01 |
| Fire Station - 1st Floor - Kitchen | 2L T12 strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 2 | 51 | 102 | 1 | 780 | 79.56 | 4.76 | 90 | 53 | 143 | 30.02 |
| Fire Station - 2nd Floor - Sleep Area | 1x2, 2L T12 surface wrap w/standard ballast | Re-lamp w/2 17W, 2' T8 lamps w/high-efficiency, electronic ballast | 9 | 26 | 234 | 4 | 1040 | 243.36 | 14.57 | 90 | 53 | 572 | 39.26 |
| Fire Station - 2nd Floor - Weight Room | 1x4, 2L T12 surface wrap w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 8 | 51 | 408 | 1 | 260 | 106.08 | 6.35 | 90 | 53 | 143 | 22.52 |
| Fire Station - 2nd Floor - Media Room | 1x4, 2L T12 surface wrap w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 4 | 51 | 204 | 1 | 130 | 26.52 | 1.59 | 90 | 53 | 143 | 90.06 |
| Fire Station - 2nd Floor - Restroom | 1x4, 2L T12 surface vanity w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 2 | 51 | 102 | 1 | 1040 | 106.08 | 6.35 | 90 | 53 | 143 | 22.52 |
| Fire Station - 2nd Floor - Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 1 | 1040 | 89.44 | 5.35 | 90 | 53 | 143 | 26.71 |



Appendix B

Lighting Improvements Calculations (City Hall) – ECM-1.2



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals:

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours/ Year | kWh Savings/ Year (kWh) | Energy Savings/ Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|--|---------------|------------------------------|----------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|------------------------|-------------------------------|---------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| City Hall - Elevator | MR16 20W Halogen Can | 6 | 20 | 120 | 530.4 | Do Nothing - Fixture To Remain | 6 | 20 | 120 | 0 | 4420 | 0.00 | 0.00 | | | | | |
| City Hall - 5th Floor - Courtroom | PAR 38 Halogen Flood | 21 | 75 | 1575 | 655.2 | Do Nothing - Fixture To Remain | 21 | 75 | 1575 | 0 | 416 | 0.00 | 0.00 | | | | | |
| City Hall - 5th Floor - Courtroom | 26W CFL Decorative Wall Torch | 6 | 26 | 156 | 64.896 | Do Nothing - Fixture To Remain | 6 | 26 | 156 | 0 | 416 | 0.00 | 0.00 | | | | | |
| City Hall - 5th Floor - Courtroom | 2L T8 cove strip w/electronic ballast | 16 | 59 | 944 | 392.704 | Do Nothing - Fixture To Remain | 16 | 59 | 944 | 0 | 416 | 0.00 | 0.00 | | | | | |
| City Hall - 5th Floor - Courtroom | Incandescent Exit Sign | 3 | 20 | 60 | 525.6 | Replace with LED Exit Sign | 3 | 3 | 9 | 51 | 8760 | 446.76 | 22.34 | 55 | 65 | 5 | 375 | 16.79 |
| City Hall - 5th Floor - Courtroom Storage | 2L T8 strip w/electronic ballast | 2 | 59 | 118 | 6.136 | Do Nothing - Fixture To Remain | 2 | 59 | 118 | 0 | 52 | 0.00 | 0.00 | | | | | |
| City Hall - 5th Floor - Courtroom | Decorative Chandelier (40W Incandescent Lamps) | 16 | 40 | 640 | 266.24 | Re-lamp w/13W compact fluorescent screw-type lamps | 16 | 13 | 208 | 432 | 416 | 179.71 | 8.99 | 5 | 15 | 1 | 336 | 37.39 |
| City Hall - 5th Floor - Courtroom | Decorative Chandelier (13W Compact Fluorescent Lamps) | 9 | 13 | 117 | 48.672 | Do Nothing - Fixture To Remain | 9 | 13 | 117 | 0 | 416 | 0.00 | 0.00 | | | | | |
| City Hall - 5th Floor - Elevator Lobby | 100W Exposed Incandescent Pendant | 1 | 100 | 100 | 41.6 | Re-lamp w/26W compact fluorescent screw-type lamps | 1 | 26 | 26 | 74 | 416 | 30.78 | 1.54 | 5 | 15 | 1 | 21 | 13.64 |
| City Hall - 5th Floor - Penthouse | 13W Exposed CFL Screw Type Lamp | 8 | 13 | 104 | 5.408 | Do Nothing - Fixture To Remain | 8 | 13 | 104 | 0 | 52 | 0.00 | 0.00 | | | | | |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours/ Year | kWh Savings/ Year (kWh) | Energy Savings/ Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|---|---------------|------------------------------|----------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|------------------------|-------------------------------|---------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| City Hall - 5th Floor - Penthouse | 2L T8 strip w/electronic ballast | 4 | 59 | 236 | 12.272 | Do Nothing - Fixture To Remain | 4 | 59 | 236 | 0 | 52 | 0.00 | 0.00 | | | | | |
| City Hall - 4th Floor - Women's Restroom | 2L T8 vanity strip w/electronic ballast | 3 | 59 | 177 | 782.34 | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 0 | 4420 | 0.00 | 0.00 | | | | | |
| City Hall - 4th Floor - Women's Restroom | 13W CFL Wall Sconce | 1 | 13 | 13 | 57.46 | Do Nothing - Fixture To Remain | 1 | 13 | 13 | 0 | 4420 | 0.00 | 0.00 | | | | | |
| City Hall - 4th Floor - Elevator Lobby | 2-lamp 13W CFL Decorative Wall Sconce | 1 | 26 | 26 | 0 | Do Nothing - Fixture To Remain | 1 | 26 | 26 | 0 | 0 | 0.00 | 0.00 | | | | | |
| City Hall - 4th Floor - Engineering Offices | 2x4, 4L T12 recessed troffer w/standard ballast | 21 | 144 | 3024 | 9434.88 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 21 | 86 | 1806 | 1218 | 3120 | 3,800.16 | 190.01 | 42 | 50 | 2 | 1,974 | 10.39 |
| City Hall - 4th Floor - Engineering Offices | 2x4, 4L T12 recessed troffer w/standard ballast | 9 | 144 | 1296 | 1347.84 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 9 | 86 | 774 | 522 | 1040 | 542.88 | 27.14 | 42 | 50 | 2 | 846 | 31.17 |
| City Hall - 4th Floor - Engineering Offices | 2x4, 4L, 25W T8 recessed troffer w/electronic ballast | 19 | 86 | 1634 | 5098.08 | Do Nothing - Fixture To Remain | 19 | 86 | 1634 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| City Hall - 4th Floor - Engineering Offices | Incandescent Exit Sign | 5 | 20 | 100 | 876 | Replace with LED Exit Sign | 5 | 3 | 15 | 85 | 8760 | 744.6 | 37.23 | 55 | 65 | 5 | 625 | 16.79 |
| City Hall - 4th Floor - Engineering Office Conference Room | 2L T12 above ceiling strip w/standard ballast | 6 | 73 | 438 | 113.88 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 6 | 51 | 306 | 132 | 260 | 34.32 | 1.72 | 37 | 45 | 2 | 504 | 293.71 |
| City Hall - 4th Floor - Engineering Office Conference Room | 4-lamp 13W CFL Ceiling Fan | 1 | 52 | 52 | 13.52 | Do Nothing - Fixture To Remain | 1 | 52 | 52 | 0 | 260 | 0.00 | 0.00 | | | | | |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours/ Year | kWh Savings/ Year (kWh) | Energy Savings/ Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|---|---------------|------------------------------|----------------------------|-----------------------|---|------------------|------------------------------|-------------------------|--------------------------|------------------------|-------------------------------|---------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| City Hall - 4th Floor - Engineering Office File Room | 3L T8 pendant wrap w/electronic ballast | 3 | 87 | 261 | 67.86 | Do Nothing - Fixture To Remain | 3 | 87 | 261 | 0 | 260 | 0.00 | 0.00 | | | | | |
| City Hall - 4th Floor - Engineering Office File Room Corridor | 2L 75W T12 8' parabolic pendant w/standard ballast | 1 | 158 | 158 | 41.08 | Re-lamp w/2 59W T8 8' lamps w/high-efficiency, electronic ballast | 1 | 112 | 112 | 46 | 260 | 11.96 | 0.60 | 37 | 45 | 2 | 84 | 140.47 |
| City Hall - 3rd Floor - Men's Restroom | 2L T8 vanity strip w/electronic ballast | 3 | 59 | 177 | 782.34 | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 0 | 4420 | 0.00 | 0.00 | | | | | |
| City Hall - 3rd Floor - Men's Restroom | 13W CFL Wall Sconce | 1 | 13 | 13 | 57.46 | Do Nothing - Fixture To Remain | 1 | 13 | 13 | 0 | 4420 | 0.00 | 0.00 | | | | | |
| City Hall - 3rd Floor - Elevator Lobby | 2-lamp 13W CFL Decorative Wall Sconce | 1 | 26 | 26 | 114.92 | Do Nothing - Fixture To Remain | 1 | 26 | 26 | 0 | 4420 | 0.00 | 0.00 | | | | | |
| City Hall - 3rd Floor - Elevator Lobby | Incandescent Exit Sign | 1 | 20 | 20 | 175.2 | Replace with LED Exit Sign | 1 | 3 | 3 | 17 | 8760 | 148.92 | 7.45 | 55 | 65 | 5 | 125 | 16.79 |
| City Hall - 3rd Floor - Private Offices | 1x4, 2L T8 D/I pendant w/electronic ballast | 17 | 59 | 1003 | 3129.36 | Do Nothing - Fixture To Remain | 17 | 59 | 1003 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| City Hall - 3rd Floor - Private Offices | 1x4, 2L T8 D/I pendant w/electronic ballast | 19 | 59 | 1121 | 582.92 | Do Nothing - Fixture To Remain | 19 | 59 | 1121 | 0 | 520 | 0.00 | 0.00 | | | | | |
| City Hall - 3rd Floor - Storage Vault | 90W Exposed Incandescent Pendant | 1 | 90 | 90 | 4.68 | Re-lamp w/26W compact fluorescent screw-type lamps | 1 | 26 | 26 | 64 | 52 | 3.33 | 0.17 | 5 | 15 | 1 | 21 | 126.20 |
| City Hall - 3rd Floor - Conference Room | 1x4, 2L T8 D/I pendant w/electronic ballast | 6 | 59 | 354 | 736.32 | Do Nothing - Fixture To Remain | 6 | 59 | 354 | 0 | 2080 | 0.00 | 0.00 | | | | | |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|--|---------------|------------------------------|----------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| City Hall - 3rd Floor - Open Offices | 1x4, 2L T8 D/I pendant w/electronic ballast | 27 | 59 | 1593 | 4970.16 | Do Nothing - Fixture To Remain | 27 | 59 | 1593 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| City Hall - 3rd Floor - Private Offices | 3-lamp 60W Incandescent Ceiling Fan | 1 | 180 | 180 | 561.6 | Re-lamp w/3 13W compact fluorescent screw-type lamps | 1 | 39 | 39 | 141 | 3120 | 439.92 | 22.00 | 15 | 25 | 1 | 41 | 1.86 |
| City Hall - 3rd Floor - Open Offices | LED Exit Sign | 1 | 3 | 3 | 26.28 | Do Nothing - Fixture To Remain | 1 | 3 | 3 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| City Hall - 3rd Floor - Private Offices | 1-lamp 22W Circline Ceiling Fan | 3 | 24 | 72 | 7.488 | Do Nothing - Fixture To Remain | 3 | 24 | 72 | 0 | 104 | 0.00 | 0.00 | | | | | |
| City Hall - 3rd Floor - Private Offices | LED Exit Sign | 2 | 3 | 6 | 52.56 | Do Nothing - Fixture To Remain | 2 | 3 | 6 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| City Hall - 3rd Floor - Private Offices | 2x4, 4L, 32W T8 recessed troffer w/electronic ballast | 10 | 114 | 1140 | 296.4 | Re-lamp w/4 25W T8 lamps | 10 | 86 | 860 | 280 | 260 | 72.80 | 4.65 | 12 | 20 | 2 | 340 | 73.05 |
| City Hall - 2nd Floor - Women's Restroom | 2L T8 vanity strip w/electronic ballast | 3 | 59 | 177 | 782.34 | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 0 | 4420 | 0.00 | 0.00 | | | | | |
| City Hall - 2nd Floor - Women's Restroom | 13W CFL Wall Sconce | 1 | 13 | 13 | 57.46 | Do Nothing - Fixture To Remain | 1 | 13 | 13 | 0 | 4420 | 0.00 | 0.00 | | | | | |
| City Hall - 2nd Floor - Elevator Lobby | 2-lamp 13W CFL Decorative Wall Sconce | 1 | 26 | 26 | 0 | Do Nothing - Fixture To Remain | 1 | 26 | 26 | 0 | 0 | 0.00 | 0.00 | | | | | |
| City Hall - 2nd Floor - Center Rotunda | 9W CFL 4-lamp decorative torches | 8 | 9 | 72 | 318.24 | Do Nothing - Fixture To Remain | 8 | 9 | 72 | 0 | 4420 | 0.00 | 0.00 | | | | | |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|---|---------------|------------------------------|----------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| City Hall - 2nd Floor - Center Rotunda | LED Exit Sign | 2 | 3 | 6 | 52.56 | Do Nothing - Fixture To Remain | 2 | 3 | 6 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| City Hall - 2nd Floor - Center Rotunda | Decorative Chandelier (25W Incandescent Lamps) | 12 | 25 | 300 | 1326 | Do Nothing - Fixture To Remain | 12 | 25 | 300 | 0 | 4420 | 0.00 | 0.00 | | | | | |
| City Hall - 2nd Floor - Center Rotunda | Decorative Chandelier (25W Incandescent Candelabra Lamps) | 14 | 25 | 350 | 1547 | Do Nothing - Fixture To Remain | 14 | 25 | 350 | 0 | 4420 | 0.00 | 0.00 | | | | | |
| City Hall - 2nd Floor - City Clerk | 1x4, 2L T8 D/I pendant w/electronic ballast | 5 | 59 | 295 | 920.4 | Do Nothing - Fixture To Remain | 5 | 59 | 295 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| City Hall - 2nd Floor - City Clerk | 2x4, 4L T12 recessed troffer w/standard ballast | 2 | 144 | 288 | 898.56 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 2 | 86 | 172 | 116 | 3120 | 361.92 | 23.14 | 42 | 50 | 2 | 188 | 8.13 |
| City Hall - 2nd Floor - Mayor | 90W Exposed Incandescent | 2 | 90 | 180 | 9.36 | Re-lamp w/26W compact fluorescent screw-type lamps | 2 | 26 | 52 | 128 | 52 | 6.66 | 0.43 | 5 | 15 | 1 | 42 | 98.70 |
| City Hall - 2nd Floor - Mayor | PAR 38 Halogen Can | 9 | 75 | 675 | 2106 | Do Nothing - Fixture To Remain | 9 | 75 | 675 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| City Hall - 2nd Floor - Mayor | 40W Incandescent Wall Torches | 4 | 40 | 160 | 499.2 | Re-lamp w/9W compact fluorescent screw-type lamps | 4 | 9 | 36 | 124 | 3120 | 386.88 | 24.73 | 5 | 15 | 1 | 84 | 3.40 |
| City Hall - 2nd Floor - Mayor | 2L T5 task light strips w/electronic ballast | 2 | 53 | 106 | 330.72 | Do Nothing - Fixture To Remain | 2 | 53 | 106 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| City Hall - 2nd Floor - Mayor's Restroom | 13W CFL 3-lamp decorative torches | 8 | 26 | 208 | 10.816 | Do Nothing - Fixture To Remain | 8 | 26 | 208 | 0 | 52 | 0.00 | 0.00 | | | | | |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|---|---------------|------------------------------|----------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| City Hall - 2nd Floor - Mayor's Restroom | 52W Exposed Incandescent | 1 | 52 | 52 | 2.704 | Re-lamp w/13W compact fluorescent screw-type lamps | 1 | 13 | 13 | 39 | 52 | 2.03 | 0.13 | 5 | 15 | 1 | 21 | 161.97 |
| City Hall - 2nd Floor Mayor's Fireplace | 4-lamp Decorative 60W Incandescent Surface Mount | 1 | 240 | 240 | 12.48 | Re-lamp w/13W compact fluorescent screw-type lamps | 1 | 52 | 52 | 188 | 52 | 9.78 | 0.62 | 5 | 15 | 1 | 21 | 33.60 |
| City Hall - 2nd Floor - Administrative Office 7 | 1x4, 2L T8 D/I pendant w/electronic ballast | 6 | 59 | 354 | 1104.48 | Do Nothing - Fixture To Remain | 6 | 59 | 354 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| City Hall - 2nd Floor - Administrative Office 8 | 1x4, 2L T8 D/I pendant w/electronic ballast | 6 | 59 | 354 | 1104.48 | Do Nothing - Fixture To Remain | 6 | 59 | 354 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| City Hall - 2nd Floor - Storage Closets | 60W Exposed Incandescent | 3 | 60 | 180 | 9.36 | Re-lamp w/13W compact fluorescent screw-type lamps | 3 | 13 | 39 | 141 | 52 | 7.33 | 0.47 | 5 | 15 | 1 | 63 | 134.40 |
| City Hall - 2nd Floor - Conference Room | 2x4, 4L, 32W T8 recessed troffer w/electronic ballast | 3 | 114 | 342 | 177.84 | Re-lamp w/4 25W T8 lamps | 3 | 86 | 258 | 84 | 520 | 43.68 | 2.79 | 12 | 20 | 2 | 102 | 36.53 |
| City Hall - 2nd Floor - Conference Room | 2L T8 vanity w/electronic ballast | 2 | 59 | 118 | 6.136 | Do Nothing - Fixture To Remain | 2 | 59 | 118 | 0 | 52 | 0.00 | 0.00 | | | | | |
| City Hall - 1st Floor - Men's Restroom | 2L T8 vanity strip w/electronic ballast | 3 | 59 | 177 | 782.34 | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 0 | 4420 | 0.00 | 0.00 | | | | | |
| City Hall - 1st Floor - Men's Restroom | 13W CFL Wall Sconce | 1 | 13 | 13 | 57.46 | Do Nothing - Fixture To Remain | 1 | 13 | 13 | 0 | 4420 | 0.00 | 0.00 | | | | | |
| City Hall - 1st Floor - Elevator Lobby | 2-lamp 60W Decorative Wall Sconce | 1 | 120 | 120 | 6.24 | Re-lamp w/2 13W compact fluorescent screw-type lamps | 1 | 26 | 26 | 94 | 52 | 4.89 | 0.31 | 5 | 15 | 1 | 21 | 67.20 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours/ Year | kWh Savings/ Year (kWh) | Energy Savings/ Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--------------------------------------|--|---------------|------------------------------|----------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|------------------------|-------------------------------|---------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| City Hall - 1st Floor - Lobby | 13W CFL 2-lamp decorative torches | 36 | 26 | 936 | 4137.12 | Do Nothing - Fixture To Remain | 36 | 26 | 936 | 0 | 4420 | 0.00 | 0.00 | | | | | |
| City Hall - 1st Floor - Lobby | LED Exit Sign | 4 | 3 | 12 | 105.12 | Do Nothing - Fixture To Remain | 4 | 3 | 12 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| City Hall - 1st Floor - Lobby | 15W Incandescent Statue Lights | 7 | 15 | 105 | 464.1 | Do Nothing - Fixture To Remain | 7 | 15 | 105 | 0 | 4420 | 0.00 | 0.00 | | | | | |
| City Hall - 1st Floor - Lobby | 5-lamp Decorative Candelabra (25W Incandescent Candelabra Lamps) | 4 | 125 | 500 | 2210 | Do Nothing - Fixture To Remain | 4 | 125 | 500 | 0 | 4420 | 0.00 | 0.00 | | | | | |
| City Hall - 1st Floor - Offices | 1x4, 2L T8 D/I pendant w/electronic ballast | 42 | 59 | 2478 | 7731.36 | Do Nothing - Fixture To Remain | 42 | 59 | 2478 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| City Hall - 1st Floor - Vault Closet | 90W Exposed Incandescent | 3 | 90 | 270 | 14.04 | Re-lamp w/26W compact fluorescent screw-type lamps | 3 | 26 | 78 | 192 | 52 | 9.98 | 0.64 | 5 | 15 | 1 | 63 | 98.70 |
| City Hall - 1st Floor - Vault Closet | 13W CFL Exposed Lamp | 1 | 13 | 13 | 0.676 | Do Nothing - Fixture To Remain | 1 | 13 | 13 | 0 | 52 | 0.00 | 0.00 | | | | | |
| City Hall - 1st Floor - Offices | 1x4, 2L T8 D/I pendant w/electronic ballast | 4 | 59 | 236 | 736.32 | Do Nothing - Fixture To Remain | 4 | 59 | 236 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| City Hall - 1st Floor - Sink Closet | 52W Exposed Incandescent | 3 | 52 | 156 | 8.112 | Re-lamp w/13W compact fluorescent screw-type lamps | 3 | 13 | 39 | 117 | 52 | 6.08 | 0.39 | 5 | 20 | 1 | 78 | 200.54 |
| City Hall - Basement - Stairs | 50W MR16 Track Light | 11 | 50 | 550 | 2431 | Do Nothing - Fixture To Remain | 11 | 50 | 550 | 0 | 4420 | 0.00 | 0.00 | | | | | |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|--|---------------|------------------------------|----------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| City Hall - Basement - Stairs | LED Exit Sign | 2 | 3 | 6 | 52.56 | Do Nothing - Fixture To Remain | 2 | 3 | 6 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| City Hall - Basement - Stairs | Incandescent Exit Sign | 1 | 20 | 20 | 175.2 | Replace with LED Exit Sign | 1 | 3 | 3 | 17 | 8760 | 148.92 | 9.52 | 55 | 65 | 5 | 125 | 13.13 |
| City Hall - Basement - Stairs | 13W CFL Wall Sconce | 8 | 13 | 104 | 911.04 | Do Nothing - Fixture To Remain | 8 | 13 | 104 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| City Hall - Basement - Shops | 2L T8 damp-location pendant w/electronic ballast | 2 | 59 | 118 | 368.16 | Do Nothing - Fixture To Remain | 2 | 59 | 118 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| City Hall - Basement - Shops | LED Exit Sign | 1 | 3 | 3 | 26.28 | Do Nothing - Fixture To Remain | 1 | 3 | 3 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| City Hall - Basement - Mechanical Room | 2L T8 damp-location pendant w/electronic ballast | 2 | 59 | 118 | 12.272 | Do Nothing - Fixture To Remain | 2 | 59 | 118 | 0 | 104 | 0.00 | 0.00 | | | | | |
| City Hall - Basement - Electrical Room | 2L T8 damp-location pendant w/electronic ballast | 2 | 59 | 118 | 12.272 | Do Nothing - Fixture To Remain | 2 | 59 | 118 | 0 | 104 | 0.00 | 0.00 | | | | | |
| City Hall - Basement - Closet | 90W Exposed Incandescent | 9 | 90 | 810 | 42.12 | Re-lamp w/26W compact fluorescent screw-type lamps | 9 | 26 | 234 | 576 | 52 | 29.95 | 1.91 | 5 | 15 | 1 | 189 | 98.70 |
| City Hall - Basement - File Room | 2x4, 4L T12 recessed troffer w/standard ballast | 7 | 144 | 1008 | 104.832 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 7 | 86 | 602 | 406 | 104 | 42.22 | 2.70 | 42 | 50 | 2 | 658 | 243.76 |
| City Hall - Basement - File Room | 2L T12 strip w/standard ballast | 6 | 73 | 438 | 45.552 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 6 | 51 | 306 | 132 | 104 | 13.73 | 0.88 | 37 | 45 | 2 | 504 | 574.27 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|-------------------------------|---|---------------|------------------------------|----------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| City Hall - Basement Shops | 2L T12 surface wrap w/standard ballast | 2 | 73 | 146 | 455.52 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 2 | 51 | 102 | 44 | 3120 | 137.28 | 8.78 | 37 | 45 | 2 | 168 | 19.14 |
| City Hall - Basement Shops | 2L T12 industrial strip w/standard ballast | 8 | 73 | 584 | 1822.08 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 8 | 51 | 408 | 176 | 3120 | 549.12 | 35.11 | 37 | 45 | 2 | 672 | 19.14 |

| | Lighting Retrofit: | Controls Totals: | Total |
|---|--------------------|------------------|----------|
| Total Annual Demand Savings (kW): | 6 | - | 6 |
| Total Energy Consumption Savings (kWh/yr) | 8,217 | 3,864 | 12,081 |
| Total Energy Savings / Year (\$) | \$436 | \$247 | \$683 |
| Total Cost of Material and Labor (\$) | \$8,291 | \$6,435 | \$14,726 |
| St. Louis Price Adjustment (\$) | \$8,507 | \$6,602 | \$15,109 |
| Total Tax, Overhead & Profit, and Contingency (\$) | \$2,977 | \$2,311 | \$5,288 |
| Total Installed Cost (\$) | \$11,484 | \$8,913 | \$20,397 |
| Total Simple Payback (Years) | 26.32 | 36.08 | 29.85 |



Detailed Energy Study University City Municipal Buildings

Controls Totals:

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts | | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|---|--|---------------|---------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| | | | | Saved / Fixture (W) | Proposed Wattage (W) | | | | | | | | |
| City Hall - 4th Floor - Women's Restroom | 2L T8 vanity strip w/electronic ballast | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 1 | 442 | 78.23 | 5.00 | 90 | 53 | 143 | 28.59 |
| City Hall - 4th Floor - Engineering Offices | 2x4, 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 21 | 86 | 1806 | 5 | 312 | 563.47 | 36.02 | 90 | 53 | 715 | 19.85 |
| City Hall - 4th Floor - Engineering Offices | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 9 | 86 | 774 | 2 | 104 | 80.50 | 5.15 | 90 | 53 | 286 | 55.58 |
| City Hall - 4th Floor - Engineering Offices | 2x4, 4L, 25W T8 recessed troffer w/electronic ballast | Do Nothing - Fixture To Remain | 19 | 86 | 1634 | 4 | 312 | 509.81 | 32.59 | 90 | 53 | 572 | 17.55 |
| City Hall - 3rd Floor - Men's Restroom | 2L T8 vanity strip w/electronic ballast | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 1 | 442 | 78.23 | 5.00 | 90 | 53 | 143 | 28.59 |
| City Hall - 3rd Floor - Private Offices | 1x4, 2L T8 D/l pendant w/electronic ballast | Do Nothing - Fixture To Remain | 17 | 59 | 1003 | 4 | 312 | 312.94 | 20.01 | 90 | 53 | 572 | 28.59 |
| City Hall - 3rd Floor - Private Offices | 1x4, 2L T8 D/l pendant w/electronic ballast | Do Nothing - Fixture To Remain | 19 | 59 | 1121 | 4 | 52 | 58.29 | 3.73 | 90 | 53 | 572 | 153.49 |
| City Hall - 3rd Floor - Conference Room | 1x4, 2L T8 D/l pendant w/electronic ballast | Do Nothing - Fixture To Remain | 6 | 59 | 354 | 1 | 208 | 73.63 | 4.71 | 90 | 53 | 143 | 30.38 |
| City Hall - 3rd Floor - Open Offices | 1x4, 2L T8 D/l pendant w/electronic ballast | Do Nothing - Fixture To Remain | 27 | 59 | 1593 | 4 | 312 | 497.02 | 31.77 | 90 | 53 | 572 | 18.00 |
| City Hall - 2nd Floor - Women's Restroom | 2L T8 vanity strip w/electronic ballast | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 1 | 442 | 78.23 | 5.00 | 90 | 53 | 143 | 28.59 |



Detailed Energy Study University City Municipal Buildings

Controls Totals (Continued):

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts Saved / Fixture (W) | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|---|--|---------------|---------------------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| City Hall - 2nd Floor - City Clerk | 1x4, 2L T8 D/I pendant w/electronic ballast | Do Nothing - Fixture To Remain | 5 | 59 | 295 | 1 | 312 | 92.04 | 5.88 | 90 | 53 | 143 | 24.30 |
| City Hall - 2nd Floor - City Clerk | 2x4, 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 2 | 86 | 172 | 1 | 312 | 53.66 | 3.43 | 90 | 53 | 143 | 41.68 |
| City Hall - 2nd Floor - Mayor | 2L T5 task light strips w/electronic ballast | Do Nothing - Fixture To Remain | 2 | 53 | 106 | 1 | 312 | 33.07 | 2.11 | 90 | 53 | 143 | 67.63 |
| City Hall - 2nd Floor - Administrative Office 7 | 1x4, 2L T8 D/I pendant w/electronic ballast | Do Nothing - Fixture To Remain | 6 | 59 | 354 | 1 | 312 | 110.45 | 7.06 | 90 | 53 | 143 | 20.25 |
| City Hall - 2nd Floor - Administrative Office 8 | 1x4, 2L T8 D/I pendant w/electronic ballast | Do Nothing - Fixture To Remain | 6 | 59 | 354 | 1 | 312 | 110.45 | 7.06 | 90 | 53 | 143 | 20.25 |
| City Hall - 2nd Floor - Conference Room | 2x4, 4L, 32W T8 recessed troffer w/electronic ballast | Re-lamp w/4 25W T8 lamps | 3 | 86 | 258 | 1 | 52 | 13.42 | 0.86 | 90 | 53 | 143 | 166.73 |
| City Hall - 1st Floor - Men's Restroom | 2L T8 vanity strip w/electronic ballast | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 1 | 442 | 78.23 | 5.00 | 90 | 53 | 143 | 28.59 |
| City Hall - 1st Floor - Offices | 1x4, 2L T8 D/I pendant w/electronic ballast | Do Nothing - Fixture To Remain | 42 | 59 | 2478 | 6 | 312 | 773.14 | 49.43 | 90 | 53 | 858 | 17.36 |
| City Hall - 1st Floor - Offices | 1x4, 2L T8 D/I pendant w/electronic ballast | Do Nothing - Fixture To Remain | 4 | 59 | 236 | 1 | 312 | 73.63 | 4.71 | 90 | 53 | 143 | 30.38 |
| City Hall - Basement - Shops | 2L T8 damp-location pendant w/electronic ballast | Do Nothing - Fixture To Remain | 2 | 59 | 118 | 1 | 312 | 36.82 | 2.35 | 90 | 53 | 143 | 60.76 |



Detailed Energy Study University City Municipal Buildings

Controls Totals (Continued):

| Location | Existing Fixture | Proposed Fixture | Input Watts | | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|------------------------------|--|--|---------------|---------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| | | | Proposed Qty. | Saved / Fixture (W) | | | | | | | | | |
| City Hall - Basement - Shops | 2L T12 surface wrap w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 2 | 51 | 102 | 1 | 312 | 31.82 | 2.03 | 90 | 53 | 143 | 70.29 |
| City Hall - Basement - Shops | 2L T12 industrial strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 8 | 51 | 408 | 2 | 312 | 127.30 | 8.14 | 90 | 53 | 286 | 35.14 |



Appendix C

Lighting Improvements Calculations (Community Center)– ECM-1.3



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals:

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|---|---------------|------------------------------|-------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Community Center - Conference Room / Stage | 2x4, 4L T8 recessed troffer w/electronic ballast | 4 | 114 | 456 | 474.24 | Do Nothing - Fixture To Remain | 4 | 86 | 344 | 112 | 1040 | 116.48 | 5.82 | | | | | |
| Community Center - Conference Room / Stage | 2x4, 4L T8 recessed troffer w/electronic ballast | 16 | 114 | 1824 | 218.88 | Do Nothing - Fixture To Remain | 16 | 86 | 1376 | 448 | 120 | 53.76 | 2.69 | | | | | |
| Community Center - Conference Room / Stage | PAR 38 Halogen Flood | 16 | 75 | 1200 | 124.8 | Do Nothing - Fixture To Remain | 16 | 75 | 1200 | 0 | 104 | 0.00 | 0.00 | | | | | |
| Community Center - Conference Room / Stage | Incandescent Exit Sign | 2 | 20 | 40 | 350.4 | Replace with LED Exit Sign | 2 | 3 | 6 | 34 | 8760 | 297.84 | 17.83 | 55 | 65 | 5 | 250 | 14.02 |
| Community Center - Store Room | 100W Recessed Incandescent Square | 7 | 100 | 700 | 72.8 | Re-lamp w/26W compact fluorescent screw-type lamps | 7 | 26 | 182 | 518 | 104 | 53.87 | 3.23 | 5 | 15 | 1 | 147 | 45.58 |
| Community Center - Store Room | 200W Exposed Incandescent | 1 | 200 | 200 | 20.8 | Re-lamp w/59W compact fluorescent screw-type lamps | 1 | 59 | 59 | 141 | 104 | 14.66 | 0.88 | 10 | 25 | 1 | 36 | 41.01 |
| Community Center - Kitchen | Incandescent Exit Sign | 3 | 20 | 60 | 525.6 | Replace with LED Exit Sign | 3 | 3 | 9 | 51 | 8760 | 446.76 | 26.75 | 55 | 65 | 5 | 375 | 14.02 |
| Community Center - Kitchen | 2x4, 4L T12 recessed troffer w/standard ballast | 8 | 144 | 1152 | 69.12 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 8 | 86 | 688 | 464 | 60 | 27.84 | 1.67 | 42 | 50 | 2 | 752 | 451.17 |
| Community Center - Hall | 2-lamp 60W Incandescent Surface Round | 2 | 120 | 240 | 249.6 | Re-lamp w/2 13W compact fluorescent screw-type lamps | 2 | 26 | 52 | 188 | 1040 | 195.52 | 11.71 | 5 | 15 | 1 | 42 | 3.59 |
| Community Center - Men's Restroom | 2-lamp 60W Recessed Incandescent Square | 4 | 120 | 480 | 499.2 | Re-lamp w/2 13W compact fluorescent screw-type lamps | 4 | 26 | 104 | 376 | 1040 | 391.04 | 23.41 | 5 | 15 | 1 | 84 | 3.59 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|---|---------------|------------------------------|-------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Community Center - Women's Restroom | 2-lamp 60W Recessed Incandescent Square | 4 | 120 | 480 | 499.2 | Re-lamp w/2 13W compact fluorescent screw-type lamps | 4 | 26 | 104 | 376 | 1040 | 391.04 | 23.41 | 5 | 15 | 1 | 84 | 3.59 |
| Community Center - Janitor's Closet | 1-lamp 100W Exposed Incandescent | 1 | 100 | 100 | 1.2 | Re-lamp w/26W compact fluorescent screw-type lamps | 1 | 26 | 26 | 74 | 12 | 0.89 | 0.05 | 5 | 15 | 1 | 21 | 395.00 |
| Community Center - Dining Hall | 2x4, 4L T8 recessed troffer w/electronic ballast | 20 | 114 | 2280 | 2371.2 | Do Nothing - Fixture To Remain | 20 | 114 | 2280 | 0 | 1040 | 0.00 | 0.00 | | | | | |
| Community Center - Mechanical Room | 200W Exposed Incandescent | 3 | 200 | 600 | 7.2 | Re-lamp w/59W compact fluorescent screw-type lamps | 3 | 59 | 177 | 423 | 12 | 5.08 | 0.30 | 10 | 25 | 1 | 108 | 355.38 |
| Community Center - Office / Storage | 200W Exposed Incandescent | 1 | 200 | 200 | 52 | Re-lamp w/59W compact fluorescent screw-type lamps | 1 | 59 | 59 | 141 | 260 | 36.66 | 2.19 | 10 | 25 | 1 | 36 | 16.40 |
| Community Center - Office / Storage | 2L T12 strip w/standard ballast | 1 | 73 | 73 | 18.98 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 22 | 260 | 5.72 | 0.34 | 37 | 45 | 2 | 84 | 245.29 |
| Community Center - Office / Storage | 2L T8 surface wrap w/electronic ballast | 2 | 59 | 118 | 30.68 | Do Nothing - Fixture To Remain | 2 | 59 | 118 | 0 | 260 | 0.00 | 0.00 | | | | | |
| Community Center - Dining Hall | Incandescent Exit Sign | 2 | 20 | 40 | 350.4 | Replace with LED Exit Sign | 2 | 3 | 6 | 34 | 8760 | 297.84 | 17.83 | 55 | 65 | 5 | 250 | 14.02 |
| Community Center - Dining Hall | PAR38 Halogen Flood | 16 | 75 | 1200 | 14.4 | Do Nothing - Fixture To Remain | 16 | 75 | 1200 | 0 | 12 | 0.00 | 0.00 | | | | | |
| Community Center - Entry | PAR38 23W CFL | 3 | 23 | 69 | 7.176 | Do Nothing - Fixture To Remain | 3 | 23 | 69 | 0 | 104 | 0.00 | 0.00 | | | | | |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) | |
|------------------------------|--|---------------|------------------------------|-------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|--|
| Community Center - Entry | PAR38 Halogen Flood | 1 | 75 | 75 | 7.8 | Do Nothing - Fixture To Remain | 1 | 75 | 75 | 0 | 104 | 0.00 | 0.00 | | | | | | |
| Community Center - Office | 2x4, 4L T12 recessed troffer w/standard ballast | 1 | 144 | 144 | 149.76 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 58 | 1040 | 60.32 | 3.61 | 42 | 50 | 2 | 94 | 26.03 | |
| Community Center - Office | 2x4, 4L T12 recessed troffer w/standard ballast | 1 | 144 | 144 | 37.44 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 58 | 260 | 15.08 | 0.90 | 42 | 50 | 2 | 94 | 104.12 | |

| | Lighting Retrofit: | Controls Totals: | Total: |
|---|--------------------|------------------|---------|
| Total Annual Demand Savings (kW): | 4 | - | 4 |
| Total Energy Consumption Savings (kWh/yr) | 2,410 | 3,091 | 5,502 |
| Total Energy Savings / Year (\$) | \$143 | \$185 | \$328 |
| Total Cost of Material and Labor (\$) | \$2,457 | \$1,716 | \$4,173 |
| St. Louis Price Adjustment (\$) | \$2,521 | \$1,761 | \$4,281 |
| Total Tax, Overhead & Profit, and Contingency (\$) | \$882 | \$616 | \$1,499 |
| Total Installed Cost (\$) | \$3,403 | \$2,377 | \$5,780 |
| Total Simple Payback (Years) | 23.86 | 12.84 | 17.64 |



Detailed Energy Study University City Municipal Buildings

Controls Totals:

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts Saved / Fixture (W) | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|--|--|---------------|---------------------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| Community Center - Conference Room / Stage | 2x4, 4L T8 recessed troffer w/electronic ballast | Do Nothing - Fixture To Remain | 4 | 86 | 344 | 1 | 1040 | 357.76 | 21.42 | 90 | 53 | 143 | 6.68 |
| Community Center - Conference Room / Stage | 2x4, 4L T8 recessed troffer w/electronic ballast | Do Nothing - Fixture To Remain | 16 | 86 | 1376 | 1 | 120 | 165.12 | 9.89 | 90 | 53 | 143 | 14.47 |
| Community Center - Kitchen | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 8 | 86 | 688 | 2 | 60 | 41.28 | 2.47 | 90 | 53 | 286 | 115.72 |
| Community Center - Dining Hall | 2x4, 4L T8 recessed troffer w/electronic ballast | Do Nothing - Fixture To Remain | 20 | 114 | 2280 | 4 | 1040 | 2371.20 | 141.96 | 90 | 53 | 572 | 4.03 |
| Community Center - Office / Storage | 2L T12 strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 1 | 260 | 13.26 | 0.79 | 90 | 53 | 143 | 180.13 |
| Community Center - Office / Storage | 2L T8 surface wrap w/electronic ballast | Do Nothing - Fixture To Remain | 2 | 59 | 118 | 1 | 260 | 30.68 | 1.84 | 90 | 53 | 143 | 77.85 |
| Community Center - Office | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 1 | 1040 | 89.44 | 5.35 | 90 | 53 | 143 | 26.71 |
| Community Center - Office | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 1 | 260 | 22.36 | 1.34 | 90 | 53 | 143 | 106.82 |



Appendix D

Lighting Improvements Calculations (Fire Station #2)– ECM-1.4



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals:

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|--|---------------|------------------------------|-------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Fire Station #2 - 1st Floor- Movie Room | 2x4, 2L T8 surface wrap w/electronic ballast | 4 | 59 | 236 | 61.36 | Do Nothing - Fixture To Remain | 4 | 59 | 236 | 0 | 260 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 1st Floor- Movie Room | 4-lamp 60W Incandescent Ceiling Fan | 2 | 240 | 480 | 24.96 | Re-lamp w/4 13W compact fluorescent screw-type lamps | 2 | 52 | 104 | 376 | 52 | 19.55 | 0.98 | 20 | 25 | 1 | 92 | 94.11 |
| Fire Station #2 - 1st Floor- Corridor | LED Exit Sign | 3 | 3 | 9 | 78.84 | Do Nothing - Fixture To Remain | 3 | 3 | 9 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 1st Floor- Corridor | 1x4, 2L T8 surface wrap w/electronic ballast | 3 | 59 | 177 | 552.24 | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 1st Floor- Kitchen | 2x4, 8L T8 surface wrap w/electronic ballast | 1 | 236 | 236 | 736.32 | Do Nothing - Fixture To Remain | 1 | 236 | 236 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 1st Floor- Kitchen | 2-lamp 13W Quad CFL Recessed Can | 3 | 26 | 78 | 243.36 | Do Nothing - Fixture To Remain | 3 | 26 | 78 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 1st Floor- Office Dispatch | 2x4, 4L T8 recessed troffer w/electronic ballast | 3 | 114 | 342 | 1067.04 | Do Nothing - Fixture To Remain | 3 | 114 | 342 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 1st Floor- Garage | 2L T8 strip w/electronic ballast | 4 | 59 | 236 | 61.36 | Do Nothing - Fixture To Remain | 4 | 59 | 236 | 0 | 260 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 1st Floor- Apparatus Bay | 2L T8 caged strip w/electronic ballast | 15 | 59 | 885 | 7752.6 | Do Nothing - Fixture To Remain | 15 | 59 | 885 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 1st Floor- Apparatus Bay | 2L T8 caged strip w/electronic ballast | 26 | 59 | 1534 | 797.68 | Do Nothing - Fixture To Remain | 26 | 59 | 1534 | 0 | 520 | 0.00 | 0.00 | | | | | |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours/ Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|--|---------------|------------------------------|-------------------------|-----------------------|-----------------------------------|------------------|------------------------------|-------------------------|--------------------------|------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Fire Station #2 - 1st Floor- Electrical Room | 1x4, 2L T8 surface strip w/electronic ballast | 1 | 59 | 59 | 6.136 | Do Nothing - Fixture To Remain | 1 | 59 | 59 | 0 | 104 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 1st Floor- Janitor's Closet | 1x4, 2L T8 surface strip w/electronic ballast | 1 | 59 | 59 | 6.136 | Do Nothing - Fixture To Remain | 1 | 59 | 59 | 0 | 104 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 1st Floor- Janitor's Closet | 1x4, 1L T8 surface strip w/electronic ballast | 1 | 30 | 30 | 3.12 | Do Nothing - Fixture To Remain | 1 | 30 | 30 | 0 | 104 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 1st Floor- Apparatus Bay | LED Exit Sign | 3 | 3 | 9 | 78.84 | Do Nothing - Fixture To Remain | 3 | 3 | 9 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 1st Floor- Apparatus Bay Stairs | 1x4, 2L T8 surface wrap w/electronic ballast | 3 | 59 | 177 | 1550.52 | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 1st Floor- Storage | 1x4, 2L T8 surface strip w/electronic ballast | 2 | 59 | 118 | 12.272 | Do Nothing - Fixture To Remain | 2 | 59 | 118 | 0 | 104 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 1st Floor- Restroom | 1x4, 2L T8 wall strip w/electronic ballast | 1 | 59 | 59 | 15.34 | Do Nothing - Fixture To Remain | 1 | 59 | 59 | 0 | 260 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 1st Floor- Outside | 100W Wall Pack HID | 1 | 129 | 129 | 565.02 | Do Nothing - Fixture To Remain | 1 | 129 | 129 | 0 | 4380 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 2nd Floor- Stairs | 2-lamp 26W CFL Surface Round | 2 | 52 | 104 | 911.04 | Do Nothing - Fixture To Remain | 2 | 52 | 104 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 2nd Floor- Corridors | LED Exit Sign | 5 | 3 | 15 | 131.4 | Do Nothing - Fixture To Remain | 5 | 3 | 15 | 0 | 8760 | 0.00 | 0.00 | | | | | |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours/ Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|--|---------------|------------------------------|-------------------------|-----------------------|-----------------------------------|------------------|------------------------------|-------------------------|--------------------------|------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Fire Station #2 - 2nd Floor- Corridors | 26W CFL Step Lights | 5 | 26 | 130 | 1138.8 | Do Nothing - Fixture To Remain | 5 | 26 | 130 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 2nd Floor- Mechanical Room | 2-lamp 26W CFL Surface Round | 1 | 52 | 52 | 5.408 | Do Nothing - Fixture To Remain | 1 | 52 | 52 | 0 | 104 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 2nd Floor- Corridors | 1x4, 2L T8 surface wrap w/electronic ballast | 11 | 59 | 649 | 337.48 | Do Nothing - Fixture To Remain | 11 | 59 | 649 | 0 | 520 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 2nd Floor- Restroom | 1x4, 2L T8 surface wrap w/electronic ballast | 3 | 59 | 177 | 46.02 | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 0 | 260 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 2nd Floor- Restroom | 1x4, 2L T8 vanity w/electronic ballast | 3 | 59 | 177 | 46.02 | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 0 | 260 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 2nd Floor- Restroom | 26W CFL Surface Round Shower Light | 3 | 26 | 78 | 20.28 | Do Nothing - Fixture To Remain | 3 | 26 | 78 | 0 | 260 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 2nd Floor- Bedrooms | 1x4, 2L T8 surface wrap w/electronic ballast | 14 | 59 | 826 | 214.76 | Do Nothing - Fixture To Remain | 14 | 59 | 826 | 0 | 260 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 2nd Floor- Closet | 1x4, 1L T8 surface strip w/electronic ballast | 2 | 30 | 60 | 3.12 | Do Nothing - Fixture To Remain | 2 | 30 | 60 | 0 | 52 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 2nd Floor- Laundry | 1x4, 2L T8 surface wrap w/electronic ballast | 2 | 59 | 118 | 92.04 | Do Nothing - Fixture To Remain | 2 | 59 | 118 | 0 | 780 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 2nd Floor- Mechanical Room / Janitor's Closet | 1x4, 2L T8 surface wrap w/electronic ballast | 2 | 59 | 118 | 6.136 | Do Nothing - Fixture To Remain | 2 | 59 | 118 | 0 | 52 | 0.00 | 0.00 | | | | | |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) | |
|---|---|---------------|------------------------------|-------------------------|-----------------------|-----------------------------------|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|--|
| Fire Station #2 - 2nd Floor- Conference Briefing Room | 2x4, 4L T8 recessed troffer w/electronic ballast | 11 | 114 | 1254 | 3912.48 | Do Nothing - Fixture To Remain | | 11 | 114 | 1254 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| Fire Station #2 - 2nd Floor- Weight Room | 1x4, 2L T8 surface wrap w/electronic ballast | 3 | 59 | 177 | 9.204 | Do Nothing - Fixture To Remain | | 3 | 59 | 177 | 0 | 52 | 0.00 | 0.00 | | | | | |

| | Lighting Retrofits: | Controls Totals: | Total |
|---|---------------------|------------------|---------|
| Total Annual Demand Savings (kW): | 0 | - | 0 |
| Total Energy Consumption Savings (kWh/yr) | 20 | 5,428 | 5,448 |
| Total Energy Savings / Year (\$) | \$1 | \$347 | \$348 |
| Total Cost of Material and Labor (\$) | \$92 | \$3,575 | \$3,667 |
| St. Louis Price Adjustment (\$) | \$94 | \$3,668 | \$3,762 |
| Total Tax, Overhead & Profit, and Contingency (\$) | \$33 | \$1,284 | \$1,317 |
| Total Installed Cost (\$) | \$127 | \$4,952 | \$5,079 |
| Total Simple Payback (Years) | 130.35 | 14.27 | 14.60 |



Detailed Energy Study University City Municipal Buildings

Controls Totals:

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts Saved / Fixture (W) | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|--|--------------------------------|---------------|---------------------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| Fire Station #2 - 1st Floor- Movie Room | 2x4, 2L T8 surface wrap w/electronic ballast | Do Nothing - Fixture To Remain | 4 | 59 | 236 | 1 | 52 | 12.27 | 0.78 | 90 | 53 | 143 | 182.27 |
| Fire Station #2 - 1st Floor- Corridor | 1x4, 2L T8 surface wrap w/electronic ballast | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 1 | 624 | 110.45 | 7.06 | 90 | 53 | 143 | 20.25 |
| Fire Station #2 - 1st Floor- Kitchen | 2x4, 8L T8 surface wrap w/electronic ballast | Do Nothing - Fixture To Remain | 1 | 236 | 236 | 1 | 624 | 147.26 | 9.41 | 90 | 53 | 143 | 15.19 |
| Fire Station #2 - 1st Floor- Kitchen | 2-lamp 13W Quad CFL Recessed Can | Do Nothing - Fixture To Remain | 3 | 26 | 78 | 1 | 624 | 48.67 | 3.11 | 90 | 53 | 143 | 45.96 |
| Fire Station #2 - 1st Floor- Office Dispatch | 2x4, 4L T8 recessed troffer w/electronic ballast | Do Nothing - Fixture To Remain | 3 | 114 | 342 | 1 | 624 | 213.41 | 13.64 | 90 | 53 | 143 | 10.48 |
| Fire Station #2 - 1st Floor- Apparatus Bay | 2L T8 caged strip w/electronic ballast | Do Nothing - Fixture To Remain | 15 | 59 | 885 | 3 | 4380 | 3876.30 | 247.81 | 90 | 53 | 429 | 1.73 |
| Fire Station #2 - 1st Floor- Apparatus Bay | 2L T8 caged strip w/electronic ballast | Do Nothing - Fixture To Remain | 26 | 59 | 1534 | 4 | 104 | 159.54 | 10.20 | 90 | 53 | 572 | 56.08 |
| Fire Station #2 - 2nd Floor- Restroom | 1x4, 2L T8 surface wrap w/electronic ballast | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 1 | 52 | 9.20 | 0.59 | 90 | 53 | 143 | 243.03 |
| Fire Station #2 - 2nd Floor- Restroom | 1x4, 2L T8 vanity w/electronic ballast | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 1 | 52 | 9.20 | 0.59 | 90 | 53 | 143 | 243.03 |
| Fire Station #2 - 2nd Floor- Restroom | 26W CFL Surface Round Shower Light | Do Nothing - Fixture To Remain | 3 | 26 | 78 | 1 | 52 | 4.06 | 0.26 | 90 | 53 | 143 | 551.48 |



Detailed Energy Study University City Municipal Buildings

Controls Totals (Continued):

| <u>Location</u> | <u>Existing Fixture</u> | <u>Proposed Fixture</u> | <u>Proposed Qty.</u> | <u>Input Watts Saved / Fixture (W)</u> | <u>Proposed Wattage (W)</u> | <u>Proposed Control Qty.</u> | <u>Avg. Hours Saved / Year</u> | <u>kWh Savings / Year (kWh)</u> | <u>Energy Savings / Year (\$)</u> | <u>Unit Material Cost (\$)</u> | <u>Unit Labor Cost (\$)</u> | <u>Total Cost (\$)</u> | <u>Simple Payback (Yr.)</u> |
|---|--|--------------------------------|----------------------|--|-----------------------------|------------------------------|--------------------------------|---------------------------------|-----------------------------------|--------------------------------|-----------------------------|------------------------|-----------------------------|
| Fire Station #2 - 2nd Floor- Bedrooms | 1x4, 2L T8 surface wrap w/electronic ballast | Do Nothing - Fixture To Remain | 14 | 59 | 826 | 7 | 52 | 42.95 | 2.75 | 90 | 53 | 1001 | 364.54 |
| Fire Station #2 - 2nd Floor- Closet | 1x4, 1L T8 surface strip w/electronic ballast | Do Nothing - Fixture To Remain | 2 | 30 | 60 | 1 | 52 | 3.12 | 0.20 | 90 | 53 | 143 | 716.93 |
| Fire Station #2 - 2nd Floor- Conference Briefing Room | 2x4, 4L T8 recessed troffer w/electronic ballast | Do Nothing - Fixture To Remain | 11 | 114 | 1254 | 1 | 624 | 782.50 | 50.02 | 90 | 53 | 143 | 2.86 |
| Fire Station #2 - 2nd Floor- Weight Room | 1x4, 2L T8 surface wrap w/electronic ballast | Do Nothing - Fixture To Remain | 3 | 59 | 177 | 1 | 52 | 9.20 | 0.59 | 90 | 53 | 143 | 243.03 |



Appendix E

Lighting Improvements Calculations (Golf Course)– ECM-1.5



Preliminary Energy Study University City Municipal Buildings

Fixture ECM Totals:

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|---|---------------|------------------------------|-------------------------|--------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Golf Course - Pro Shop | 1x4, 2L T12 wall-mounted strip w/standard ballast | 4 | 73 | 292 | 1594.32 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 4 | 51 | 204 | 88 | 5460 | 480.48 | 37.12 | 37 | 45 | | 336 | 9.05 |
| Golf Course - Pro Shop | R40 Flood Track Light | 8 | 40 | 320 | 1747.2 | Do Nothing - Fixture To Remain | 8 | 40 | 320 | 0 | 5460 | 0.00 | 0.00 | | | | | |
| Golf Course - Pro Shop | 2x4, 4L T8 recessed troffer w/electronic ballast | 8 | 114 | 912 | 4979.52 | Re-lamp w/4 25W T8 lamps | 8 | 86 | 688 | 224 | 5460 | 1,223.04 | 94.49 | 12 | 25 | | 4 | 3.47 |
| Golf Course - Pro Shop | 2x4, 4L T8 surface wrap w/electronic ballast | 1 | 114 | 114 | 622.44 | Re-lamp w/4 25W T8 lamps | 1 | 86 | 86 | 28 | 5460 | 152.88 | 11.81 | 12 | 25 | | 4 | 3.47 |
| Golf Course - Pro Shop - Office | 1x4, 4L T12 surface wrap w/standard ballast | 1 | 114 | 114 | 355.68 | Re-lamp w/4 25W T8 lamps | 1 | 86 | 86 | 28 | 3120 | 87.36 | 6.75 | 12 | 25 | | 4 | 6.07 |
| Golf Course - Pro Shop - Men's Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | 1 | 144 | 144 | 449.28 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 93 | 3120 | 290.16 | 22.42 | 37 | 45 | | 2 | 3.75 |
| Golf Course - Pro Shop - Women's Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | 1 | 144 | 144 | 74.88 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 93 | 520 | 48.36 | 3.74 | 37 | 45 | | 2 | 22.48 |
| Golf Course - Pro Shop - Stairs | 100W Exposed Incandescent | 4 | 100 | 400 | 104 | Re-lamp w/26W compact fluorescent screw-type lamps | 4 | 26 | 104 | 296 | 260 | 76.96 | 5.95 | 5 | 15 | | 1 | 14.13 |
| Golf Course - Pro Shop - Basement | 2L T12 strip w/standard ballast | 1 | 73 | 73 | 18.98 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 22 | 260 | 5.72 | 0.44 | 37 | 45 | | 2 | 190.08 |
| Golf Course - Pro Shop - Kitchen | 2L T12 strip w/standard ballast | 1 | 73 | 73 | 18.98 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 22 | 260 | 5.72 | 0.44 | 37 | 45 | | 2 | 190.08 |



Preliminary Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|----------------------------------|--|---------------|------------------------------|-------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Golf Course - Pro Shop - Kitchen | 100W Incandescent Globe | 1 | 100 | 100 | | Re-lamp w/26W compact fluorescent screw-type lamps | 1 | 26 | 26 | 74 | 260 | 19.24 | 1.49 | 5 | 15 | 1 | 21 | 14.13 |
| Golf Course - Ball Shack | 1x4, 2L T8 surface wrap w/electronic ballast | 1 | 59 | 59 | 61.36 | Do Nothing - Fixture To Remain | 1 | 59 | 59 | 0 | 1040 | 0.00 | 0.00 | | | | | |

| | Lighting Retrofit: | Controls Totals: | Total: |
|--|--------------------|------------------|---------|
| Total Annual Demand Savings (kW): | 1 | - | 1 |
| Total Energy Consumption Savings | 2,390 | 1,448 | 3,838 |
| Total Energy Savings / Year (\$) | \$185 | \$112 | \$297 |
| Total Cost of Material and Labor (\$) | \$1,187 | \$858 | \$2,045 |
| St. Louis Price Adjustment (\$) | \$1,218 | \$880 | \$2,098 |
| Total Tax, Overhead & Profit, and | \$426 | \$308 | \$734 |
| Total Installed Cost (\$) | \$1,644 | \$1,188 | \$2,833 |
| Total Simple Payback (Years) | 8.90 | 10.62 | 9.55 |



Preliminary Energy Study University City Municipal Buildings

Controls Totals:

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts Saved / Fixture (W) | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|---|--|---------------|---------------------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| Golf Course - Pro Shop | 1x4, 2L T12 wall-mounted strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 4 | 51 | 204 | 1 | 1365 | 278.46 | 21.51 | 90 | 53 | 143 | 6.65 |
| Golf Course - Pro Shop | 2x4, 4L T8 recessed troffer w/electronic ballast | Re-lamp w/4 25W T8 lamps | 8 | 86 | 688 | 1 | 1365 | 939.12 | 72.56 | 90 | 53 | 143 | 1.97 |
| Golf Course - Pro Shop | 2x4, 4L T8 surface wrap w/electronic ballast | Re-lamp w/4 25W T8 lamps | 1 | 86 | 86 | 1 | 1365 | 117.39 | 9.07 | 90 | 53 | 143 | 15.77 |
| Golf Course - Pro Shop - Office | 1x4, 4L T12 surface wrap w/standard ballast | Re-lamp w/4 25W T8 lamps | 1 | 86 | 86 | 1 | 780 | 67.08 | 5.18 | 90 | 53 | 143 | 27.59 |
| Golf Course - Pro Shop - Men's Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 1 | 780 | 39.78 | 3.07 | 90 | 53 | 143 | 46.53 |
| Golf Course - Pro Shop - Women's Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 1 | 130 | 6.63 | 0.51 | 90 | 53 | 143 | 279.17 |



Preliminary Energy Study University City Municipal Buildings

Fixture ECM Totals:

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours/ Year | kWh Savings / Year (kWh) | Energy Savings/ Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|---|---------------|------------------------------|-------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|------------------------|-----------------------------|---------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Golf Course - Grounds Maintenance Building - Storage | 100W Exposed Incandescent | 1 | 100 | 100 | 0.2 | Re-lamp w/26W compact fluorescent screw-type lamps | 1 | 26 | 26 | 74 | 2 | 0.15 | 0.01 | 5 | 15 | 1 | 21 | 1698.49 |
| Golf Course - Grounds Maintenance Building - Garage | 60W Exposed Incandescent | 1 | 60 | 60 | 187.2 | Re-lamp w/13W compact fluorescent screw-type lamps | 1 | 13 | 13 | 47 | 3120 | 146.64 | 12.25 | 5 | 15 | 1 | 21 | 1.71 |
| Golf Course - Grounds Maintenance Building - Garage | 60W Exposed Incandescent | 5 | 60 | 300 | 0.6 | Re-lamp w/13W compact fluorescent screw-type lamps | 5 | 13 | 65 | 235 | 2 | 0.47 | 0.04 | 5 | 15 | 1 | 105 | 2674.22 |
| Golf Course - Grounds Maintenance Building - Garage | 13W Exposed CFL Screw Type | 2 | 13 | 26 | 81.12 | Do Nothing - Fixture To Remain | 2 | 13 | 26 | 0 | 3120 | 0.00 | 0.00 | | | | | |
| Golf Course - Grounds Maintenance Building - Garage | 2L T12 strip w/standard ballast | 5 | 73 | 365 | 2277.6 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 5 | 51 | 255 | 110 | 6240 | 686.40 | 57.34 | 37 | 45 | 2 | 420 | 7.32 |
| Golf Course - Grounds Maintenance Building - Garage Office | 2x4, 4L T8 surface wrap w/electronic ballast | 2 | 114 | 228 | 711.36 | Re-lamp w/4 25W T8 lamps | 2 | 86 | 172 | 56 | 3120 | 174.72 | 14.60 | 12 | 25 | 4 | 82 | 5.62 |
| Golf Course - Grounds Maintenance Building - Exterior | PAR38 Flood on motion sensor | 2 | 75 | 150 | 78 | Do Nothing - Fixture To Remain | 2 | 75 | 150 | 0 | 520 | 0.00 | 0.00 | | | | | |

| | Lighting Retrofit: | Controls Totals: | Total: |
|---|--------------------|------------------|---------|
| Total Annual Demand Savings (kW): | 1 | - | 1 |
| Total Energy Consumption Savings (kWh/yr) | 1,008 | 268 | 1,277 |
| Total Energy Savings / Year (\$) | \$84 | \$22 | \$107 |
| Total Cost of Material and Labor (\$) | \$649 | \$143 | \$792 |
| St. Louis Price Adjustment (\$) | \$666 | \$147 | \$813 |
| Total Tax, Overhead & Profit, and Contingency (\$) | \$233 | \$51 | \$284 |
| Total Installed Cost (\$) | \$899 | \$198 | \$1,097 |
| Total Simple Payback (Years) | 10.67 | 8.84 | 10.29 |



Preliminary Energy Study University City Municipal Buildings

Controls Totals:

| <u>Location</u> | <u>Existing Fixture</u> | <u>Proposed Fixture</u> | <u>Proposed Qty.</u> | <u>Input Watts Saved / Fixture (W)</u> | <u>Proposed Wattage (W)</u> | <u>Proposed Control Qty.</u> | <u>Avg. Hours Saved / Year</u> | <u>kWh Savings / Year (kWh)</u> | <u>Energy Savings / Year (\$)</u> | <u>Unit Material Cost (\$)</u> | <u>Unit Labor Cost (\$)</u> | <u>Total Cost (\$)</u> | <u>Simple Payback (Yr.)</u> |
|--|--|--------------------------|----------------------|--|-----------------------------|------------------------------|--------------------------------|---------------------------------|-----------------------------------|--------------------------------|-----------------------------|------------------------|-----------------------------|
| Golf Course - Grounds Maintenance Building - Garage Office | 2x4, 4L T8 surface wrap w/electronic ballast | Re-lamp w/4 25W T8 lamps | 2 | 86 | 172 | 1 | 1560 | 268.32 | 22.42 | 90 | 53 | 143 | 6.38 |



Appendix F

Lighting Improvements Calculations (Public Works)– ECM-1.6



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals:

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|---|---------------|------------------------------|-------------------------|-----------------------|---|------------------|------------------------------|-------------------------|--------------------------|-------------------------|-----------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Central Garage - Vehicle Workshop | 1x8, 2L 75W T12 surface strip w/standard ballast | 41 | 158 | 6478 | 18527.08 | Replace with 4-lamp T8 High Bay w/electronic ballast and integral occupancy sensor | 25 | 114 | 2850 | 3628 | 2860 | 10,376.08 | 711.80 | 278 | 73 | 25 | 9,400 | 13.21 |
| Central Garage - Vehicle Workshop | 1x4, 2L T12 surface strip w/standard ballast | 13 | 73 | 949 | 2714.14 | Replace with 4-lamp T8 High Bay w/electronic ballast and integral occupancy sensor | 7 | 114 | 798 | 151 | 2860 | 431.86 | 29.63 | 278 | 73 | 25 | 2,632 | 88.84 |
| Central Garage - Vehicle Workshop | 1x4, 2L T12 pendant industrial task w/standard ballast | 4 | 73 | 292 | 835.12 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 4 | 51 | 204 | 88 | 2860 | 251.68 | 17.27 | 37 | 45 | 2 | 336 | 19.46 |
| Central Garage - High- Bay Garage | 1x8, 2L 75W T12 industrial strip w/standard ballast | 21 | 158 | 3318 | 9489.48 | Replace with 4-lamp T5HO High Bay w/electronic ballast and integral occupancy sensor | 8 | 258 | 2064 | 1254 | 2860 | 3,586.44 | 246.03 | 313 | 73 | 25 | 3,288 | 13.36 |
| Central Garage - High- Bay Garage | 1x4, 2L T12 industrial strip w/standard ballast | 3 | 73 | 219 | 626.34 | Fixtures to be Demolished | 3 | 0 | 0 | 219 | 2860 | 626.34 | 42.97 | 0 | 25 | 5 | 90 | 2.09 |
| Central Garage - Garage | Incandescent Exit Sign | 1 | 20 | 20 | 175.2 | Replace with LED Exit Sign | 1 | 3 | 3 | 17 | 8760 | 148.92 | 10.22 | 55 | 65 | 5 | 125 | 12.24 |
| Central Garage - Tool/Compressor Room | 1x8, 2L 75W T12 industrial strip w/standard ballast | 1 | 158 | 158 | 451.88 | Re-lamp w/2 59W T8 8' lamps w/high-efficiency, electronic ballast | 1 | 112 | 112 | 46 | 2860 | 131.56 | 9.03 | 37 | 45 | 2 | 84 | 9.31 |
| Central Garage - Parts Supply Room | 1x4, 2L T12 industrial strip w/standard ballast | 5 | 73 | 365 | 1043.9 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 5 | 51 | 255 | 110 | 2860 | 314.60 | 21.58 | 37 | 45 | 2 | 420 | 19.46 |
| Central Garage - Parts Supply Room | 1x4, 1L T12 industrial strip w/standard ballast | 2 | 42 | 84 | 240.24 | Re-lamp w/1 28W T8 lamp w/high-efficiency, electronic ballast | 2 | 26 | 52 | 32 | 2860 | 91.52 | 6.28 | 35 | 42 | 2 | 158 | 25.17 |
| Central Garage - Print Room | 2x4, 4L T12 recessed troffer w/standard ballast | 1 | 144 | 144 | 411.84 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 58 | 2860 | 165.88 | 11.38 | 42 | 50 | 2 | 94 | 8.26 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|--|---------------|------------------------------|-------------------------|--------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|-----------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Central Garage - Offices | 2x4, 4L T12 surface wrap w/standard ballast | 2 | 144 | 288 | 823.68 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 2 | 86 | 172 | 116 | 2860 | 331.76 | 22.76 | 42 | 50 | 2 | 188 | 8.26 |
| Central Garage - Offices | 1x4, 2L T12 surface wrap w/standard ballast | 3 | 73 | 219 | 626.34 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 3 | 51 | 153 | 66 | 2860 | 188.76 | 12.95 | 37 | 45 | 2 | 252 | 19.46 |
| Central Garage - Break Room | 1x4, 2L T12 industrial strip w/standard ballast | 1 | 73 | 73 | 208.78 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 22 | 2860 | 62.92 | 4.32 | 37 | 45 | 2 | 84 | 19.46 |
| Central Garage - Men's Locker & Restroom | 1x4, 2L T12 industrial strip w/standard ballast | 14 | 73 | 1022 | 2922.92 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 14 | 51 | 714 | 308 | 2860 | 880.88 | 60.43 | 37 | 45 | 2 | 1,176 | 19.46 |
| Central Garage - Men's Locker & Restroom | 1x4, 2L T8 industrial strip w/standard ballast | 1 | 69 | 69 | 197.34 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 18 | 2860 | 51.48 | 3.53 | 37 | 45 | 2 | 84 | 23.79 |
| Central Garage - Men's Locker & Restroom | 1x4, 1L T12 vanity strip w/standard ballast | 1 | 42 | 42 | 120.12 | Re-lamp w/1 28W T8 lamp w/high-efficiency, electronic ballast | 1 | 26 | 26 | 16 | 2860 | 45.76 | 3.14 | 35 | 42 | 2 | 79 | 25.17 |
| Central Garage - Men's Locker & Restroom | 1x4, 2L T8 strip w/electronic ballast | 2 | 59 | 118 | 337.48 | Do Nothing - Fixture To Remain | 2 | 59 | 118 | 0 | 2860 | 0.00 | 0.00 | | | | | |
| Central Garage - Offices | 1x4, 2L T12 industrial strip w/standard ballast | 15 | 73 | 1095 | 3131.7 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 15 | 51 | 765 | 330 | 2860 | 943.80 | 64.74 | 37 | 45 | 2 | 1,260 | 19.46 |
| Central Garage - Women's Restroom | 1x4, 2L T12 industrial strip w/standard ballast | 1 | 73 | 73 | 208.78 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 22 | 2860 | 62.92 | 4.32 | 37 | 45 | 2 | 84 | 19.46 |
| Central Garage - Fuel Station | 175W Metal Halide Class 1, surface mount with standard ballast | 4 | 213 | 852 | 3731.76 | Do Nothing - Fixture To Remain | 4 | 213 | 852 | 0 | 4380 | 0.00 | 0.00 | | | | | |



Fixture ECM Totals (Continued):

| | Lighting Retrofit: | Controls Totals: | Total: |
|--|--------------------|------------------|----------|
| Total Annual Demand Savings (kW): | 7 | - | 7 |
| Total Energy Consumption Savings (kWh/yr) | 18,693 | 5,290 | 23,983 |
| Total Energy Savings / Year (\$) | \$1,282 | \$317 | \$1,599 |
| Total Cost of Material and Labor (\$) | \$19,834 | \$2,145 | \$21,979 |
| St. Louis Price Adjustment (\$) | \$20,350 | \$2,201 | \$22,550 |
| Total Tax, Overhead & Profit, and Contingency (\$) | \$7,122 | \$770 | \$7,893 |
| Total Installed Cost (\$) | \$27,472 | \$2,971 | \$30,443 |
| Total Simple Payback (Years) | 21.42 | 9.38 | 19.04 |



Detailed Energy Study University City Municipal Buildings

Controls Totals:

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts Saved / Fixture (W) | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---------------------------------------|---|--|---------------|---------------------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| Central Garage - Vehicle Workshop | 1x8, 2L 75W T12 surface strip w/standard ballast | Replace with 4-lamp T8 High Bay w/electronic ballast and integral occupancy sensor | 25 | 114 | 2850 | 25 | 572 | 1630.20 | 97.60 | 0 | 0 | 0 | 0.00 |
| Central Garage - Vehicle Workshop | 1x4, 2L T12 surface strip w/standard ballast | Replace with 4-lamp T8 High Bay w/electronic ballast and integral occupancy sensor | 7 | 114 | 798 | 7 | 572 | 456.46 | 27.33 | 0 | 0 | 0 | 0.00 |
| Central Garage - High-Bay Garage | 1x8, 2L 75W T12 industrial strip w/standard ballast | Replace with 4-lamp T5HO High Bay w/electronic ballast and integral occupancy sensor | 8 | 258 | 2064 | 8 | 572 | 1180.61 | 70.68 | 0 | 0 | 0 | 0.00 |
| Central Garage - Tool/Compressor Room | 1x8, 2L 75W T12 industrial strip w/standard ballast | Re-lamp w/2 59W T8 8' lamps w/high-efficiency, electronic ballast | 1 | 112 | 112 | 1 | 1430 | 160.16 | 9.59 | 90 | 53 | 143 | 14.91 |
| Central Garage - Parts Supply Room | 1x4, 2L T12 industrial strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 5 | 51 | 255 | 1 | 1144 | 291.72 | 17.47 | 90 | 53 | 143 | 8.19 |
| Central Garage - Parts Supply Room | 1x4, 1L T12 industrial strip w/standard ballast | Re-lamp w/1 28W T8 lamp w/high-efficiency, electronic ballast | 2 | 26 | 52 | 1 | 1144 | 59.49 | 3.56 | 90 | 53 | 143 | 40.15 |
| Central Garage - Print Room | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 1 | 572 | 49.19 | 2.95 | 90 | 53 | 143 | 48.55 |
| Central Garage - Offices | 2x4, 4L T12 surface wrap w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 2 | 86 | 172 | 1 | 572 | 98.38 | 5.89 | 90 | 53 | 143 | 24.28 |
| Central Garage - Offices | 1x4, 2L T12 surface wrap w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 3 | 51 | 153 | 1 | 572 | 87.52 | 5.24 | 90 | 53 | 143 | 27.29 |
| Central Garage - Break Room | 1x4, 2L T12 industrial strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 1 | 572 | 29.17 | 1.75 | 90 | 53 | 143 | 81.88 |



Detailed Energy Study University City Municipal Buildings

Controls Totals (Continued):

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts Saved / Fixture (W) | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|---|--|---------------|---------------------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| Central Garage - Men's Locker & Restroom | 1x4, 2L T12 industrial strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 14 | 51 | 714 | 2 | 858 | 612.61 | 36.68 | 90 | 53 | 286 | 7.80 |
| Central Garage - Men's Locker & Restroom | 1x4, 2L T8 industrial strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 1 | 858 | 43.76 | 2.62 | 90 | 53 | 143 | 54.58 |
| Central Garage - Men's Locker & Restroom | 1x4, 1L T12 vanity strip w/standard ballast | Re-lamp w/1 28W T8 lamp w/high-efficiency, electronic ballast | 1 | 26 | 26 | 1 | 858 | 22.31 | 1.34 | 90 | 53 | 143 | 107.07 |
| Central Garage - Men's Locker & Restroom | 1x4, 2L T8 strip w/electronic ballast | Do Nothing - Fixture To Remain | 2 | 59 | 118 | 0 | 858 | 101.24 | 6.06 | 90 | 53 | 0 | 0.00 |
| Central Garage - Offices | 1x4, 2L T12 industrial strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 15 | 51 | 765 | 3 | 572 | 437.58 | 26.20 | 90 | 53 | 429 | 16.38 |
| Central Garage - Women's Restroom | 1x4, 2L T12 industrial strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 1 | 572 | 29.17 | 1.75 | 90 | 53 | 143 | 81.88 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals:

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|--|---------------|------------------------------|-------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Materials Recycling Facility - Storage | 1x4, 2L T8 surface strip w/electronic ballast | 6 | 59 | 354 | 736.32 | Do Nothing - Fixture To Remain | 6 | 59 | 354 | 0 | 2080 | 0.00 | 0.00 | | | | | |
| Materials Recycling Facility - Storage | 1x4, 2L T12 surface strip w/standard ballast | 10 | 73 | 730 | 1518.4 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 10 | 51 | 510 | 220 | 2080 | 457.60 | 31.39 | 37 | 45 | 2 | 840 | 26.76 |
| Materials Recycling Facility - Break | 2x4, 4L T12 recessed troffer w/standard ballast | 3 | 144 | 432 | 44.928 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 3 | 86 | 258 | 174 | 104 | 18.10 | 1.24 | 42 | 50 | 2 | 282 | 227.17 |
| Materials Recycling Facility - Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | 1 | 144 | 144 | 299.52 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 58 | 2080 | 120.64 | 8.28 | 42 | 50 | 2 | 94 | 11.36 |
| Materials Recycling Facility - Janitor's Closet | 1x4, 2L T8 industrial strip w/standard ballast | 1 | 69 | 69 | 143.52 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 18 | 2080 | 37.44 | 2.57 | 37 | 45 | 2 | 84 | 32.71 |
| Materials Recycling Facility - Storage | Incandescent Exit Sign | 2 | 20 | 40 | 350.4 | Replace with LED Exit Sign | 2 | 3 | 6 | 34 | 8760 | 297.84 | 20.43 | 55 | 65 | 5 | 250 | 12.24 |
| Materials Recycling Facility - Trash Sorting | 100W Metal Halide Wall Flood w/standard ballast | 3 | 125 | 375 | 1642.5 | Do Nothing - Fixture To Remain | 3 | 125 | 375 | 0 | 4380 | 0.00 | 0.00 | | | | | |
| Materials Recycling Facility - Trash Sorting | 150W High-Pressure Sodium Wall Pack w/standard ballast | 2 | 188 | 376 | 3293.76 | Do Nothing - Fixture To Remain | 2 | 188 | 376 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| Materials Recycling Facility - Break Shack | 1x4, 2L T12 surface wrap w/standard ballast | 2 | 73 | 146 | 15.184 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 2 | 51 | 102 | 44 | 104 | 4.58 | 0.31 | 37 | 45 | 2 | 168 | 535.18 |



Fixture ECM Totals:

| | Lighting Retrofit: | Controls Totals: | Total: |
|---|--------------------|------------------|---------|
| Total Annual Demand Savings (kW): | 1 | - | 1 |
| Total Energy Consumption Savings (kWh/yr) | 936 | 422 | 1,358 |
| Total Energy Savings / Year (\$) | \$64 | \$25 | \$89 |
| Total Cost of Material and Labor (\$) | \$1,718 | \$1,001 | \$2,719 |
| St. Louis Price Adjustment (\$) | \$1,763 | \$1,027 | \$2,790 |
| Total Tax, Overhead & Profit, and Contingency | \$617 | \$359 | \$976 |
| Total Installed Cost (\$) | \$2,380 | \$1,386 | \$3,766 |
| Total Simple Payback (Years) | 37.05 | 54.91 | 42.09 |



Detailed Energy Study University City Municipal Buildings

Controls Totals:

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts Saved / Fixture (W) | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|---|--|---------------|---------------------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| Materials Recycling Facility - Storage | 1x4, 2L T8 surface strip w/electronic ballast | Do Nothing - Fixture To Remain | 6 | 59 | 354 | 2 | 416 | 147.26 | 8.82 | 90 | 53 | 286 | 32.44 |
| Materials Recycling Facility - Storage | 1x4, 2L T12 surface strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 10 | 51 | 510 | 2 | 416 | 212.16 | 12.70 | 90 | 53 | 286 | 22.52 |
| Materials Recycling Facility - Break | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 3 | 86 | 258 | 1 | 21 | 5.37 | 0.32 | 90 | 53 | 143 | 445.09 |
| Materials Recycling Facility - Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 1 | 416 | 35.78 | 2.14 | 90 | 53 | 143 | 66.76 |
| Materials Recycling Facility - Janitor's Closet | 1x4, 2L T8 industrial strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 1 | 416 | 21.22 | 1.27 | 90 | 53 | 143 | 112.58 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals:

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---------------------------------------|---|---------------|------------------------------|-------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Park Storage and Shops - Storage | 1x4, 2L T12 pendant strip w/standard ballast | 19 | 73 | 1387 | 12150.12 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 19 | 51 | 969 | 418 | 8760 | 3,661.68 | 251.19 | 37 | 45 | 2 | 1,596 | 6.35 |
| Park Storage and Shops - Storage | 1x4, 4L T12 pendant strip w/standard ballast | 1 | 144 | 144 | 1261.44 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 58 | 8760 | 508.08 | 34.85 | 42 | 50 | 2 | 94 | 2.70 |
| Park Storage and Shops - Break Area | 1x4, 2L T12 pendant strip w/standard ballast | 27 | 73 | 1971 | 17265.96 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 27 | 51 | 1377 | 594 | 8760 | 5,203.44 | 356.96 | 37 | 45 | 2 | 2,268 | 6.35 |
| Park Storage and Shops - Break Area | 2x4, 4L T12 pendant strip w/standard ballast | 1 | 144 | 144 | 1261.44 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 58 | 8760 | 508.08 | 34.85 | 42 | 50 | 2 | 94 | 2.70 |
| Park Storage and Shops - Storage | 26W CFL Pendant Globe | 5 | 26 | 130 | 338 | Do Nothing - Fixture To Remain | 5 | 26 | 130 | 0 | 2600 | 0.00 | 0.00 | | | | | |
| Park Storage and Shops - Back Garage | 1x4, 2L T12 pendant strip w/standard ballast | 6 | 73 | 438 | 3836.88 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 6 | 51 | 306 | 132 | 8760 | 1,156.32 | 79.32 | 37 | 45 | 2 | 504 | 6.35 |
| Park Storage and Shops - Machine Shop | 1x4, 2L T12 pendant strip w/standard ballast | 20 | 73 | 1460 | 12789.6 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 20 | 51 | 1020 | 440 | 8760 | 3,854.40 | 264.41 | 37 | 45 | 2 | 1,680 | 6.35 |
| Park Storage and Shops - Entry Hall | 1x4, 2L T12 surface wrap w/standard ballast | 3 | 73 | 219 | 569.4 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 3 | 51 | 153 | 66 | 2600 | 171.60 | 11.77 | 37 | 45 | 2 | 252 | 21.41 |
| Park Storage and Shops - Locker | 1x4, 2L T12 surface wrap w/standard ballast | 3 | 73 | 219 | 569.4 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 3 | 51 | 153 | 66 | 2600 | 171.60 | 11.77 | 37 | 45 | 2 | 252 | 21.41 |
| Park Storage and Shops - Locker | 1x8, 2L 75W T12 surface wrap w/standard ballast | 2 | 158 | 316 | 821.6 | Re-lamp w/2 59W 8', T8 lamps w/high-efficiency, electronic ballast | 2 | 112 | 224 | 92 | 2600 | 239.20 | 16.41 | 40 | 52 | 2 | 188 | 11.46 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|-----------------------------------|---|---------------|------------------------------|-------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Park Storage and Shops - Restroom | 100W Exposed Incandescent Pendant | 2 | 100 | 200 | 520 | Re-lamp w/26W compact fluorescent screw-type lamps | 2 | 26 | 52 | 148 | 2600 | 384.80 | 19.24 | 5 | 15 | 1 | 42 | 2.18 |
| Park Storage and Shops - Restroom | 2-lamp 60W Incandescent Vanity | 1 | 120 | 120 | 312 | Re-lamp w/2 13W compact fluorescent screw type lamps | 1 | 26 | 26 | 94 | 2600 | 244.40 | 12.22 | 10 | 20 | 1 | 31 | 2.54 |
| Park Storage and Shops - Office | 2x4, 4L T8 recessed troffer w/electronic ballast | 3 | 114 | 342 | 889.2 | Provide new 2-lamp T8 recessed volumetric w/high-efficiency electronic ballast | 3 | 59 | 177 | 165 | 2600 | 429.00 | 29.43 | 125 | 55 | 10 | 570 | 19.37 |
| Park Storage and Shops - Office | 2L T12 strip above lay-in lens w/standard ballast | 3 | 73 | 219 | 569.4 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 3 | 51 | 153 | 66 | 2600 | 171.60 | 11.77 | 37 | 45 | 2 | 252 | 21.41 |

| | Lighting Retrofit: | Controls Totals: | Total: |
|--|--------------------|------------------|----------|
| Total Annual Demand Savings (kW): | 2 | - | 2 |
| Total Energy Consumption Savings (kWh/yr) | 16,704 | 17,284 | 33,988 |
| Total Energy Savings / Year (\$) | \$1,134 | \$1,035 | \$2,169 |
| Total Cost of Material and Labor (\$) | \$7,823 | \$1,573 | \$9,396 |
| St. Louis Price Adjustment (\$) | \$8,026 | \$1,614 | \$9,640 |
| Total Tax, Overhead & Profit, and | \$2,809 | \$565 | \$3,374 |
| Total Installed Cost (\$) | \$10,836 | \$2,179 | \$13,014 |
| Total Simple Payback (Years) | 9.55 | 2.11 | 6.00 |



Detailed Energy Study University City Municipal Buildings

Controls Totals:

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts Saved / Fixture (W) | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---------------------------------------|---|--|---------------|---------------------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| Park Storage and Shops - Storage | 1x4, 2L T12 pendant strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 19 | 51 | 969 | 2 | 4380 | 4244.22 | 254.10 | 90 | 53 | 286 | 1.13 |
| Park Storage and Shops - Storage | 1x4, 4L T12 pendant strip w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 0 | 4380 | 376.68 | 22.55 | 90 | 53 | 0 | 0.00 |
| Park Storage and Shops - Break Area | 1x4, 2L T12 pendant strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 27 | 51 | 1377 | 2 | 4380 | 6031.26 | 361.09 | 90 | 53 | 286 | 0.79 |
| Park Storage and Shops - Break Area | 2x4, 4L T12 pendant strip w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 0 | 4380 | 376.68 | 22.55 | 90 | 53 | 0 | 0.00 |
| Park Storage and Shops - Back Garage | 1x4, 2L T12 pendant strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 6 | 51 | 306 | 1 | 4380 | 1340.28 | 80.24 | 90 | 53 | 143 | 1.78 |
| Park Storage and Shops - Machine Shop | 1x4, 2L T12 pendant strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 20 | 51 | 1020 | 2 | 4380 | 4467.60 | 267.48 | 90 | 53 | 286 | 1.07 |
| Park Storage and Shops - Entry Hall | 1x4, 2L T12 surface wrap w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 3 | 51 | 153 | 1 | 520 | 79.56 | 4.76 | 90 | 53 | 143 | 30.02 |
| Park Storage and Shops - Locker | 1x4, 2L T12 surface wrap w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 3 | 51 | 153 | 1 | 520 | 79.56 | 4.76 | 90 | 53 | 143 | 30.02 |
| Park Storage and Shops - Locker | 1x8, 2L 75W T12 surface wrap w/standard ballast | Re-lamp w/2 59W 8', T8 lamps w/high-efficiency, electronic ballast | 2 | 112 | 224 | 0 | 520 | 116.48 | 6.97 | 90 | 53 | 0 | 0.00 |
| Park Storage and Shops - Office | 2x4, 4L T8 recessed troffer w/electronic ballast | Provide new 2-lamp T8 recessed volumetric w/high-efficiency electronic ballast | 3 | 59 | 177 | 1 | 520 | 92.04 | 5.51 | 90 | 53 | 143 | 25.95 |
| Park Storage and Shops - Office | 2L T12 strip above lay-in lens w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 3 | 51 | 153 | 1 | 520 | 79.56 | 4.76 | 90 | 53 | 143 | 30.02 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals:

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|--|---------------|------------------------------|-------------------------|--------------------------|---|------------------|------------------------------|-------------------------|-----------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|-------------------------|-------------------------------|--------------------|----------------------------|
| Lawn Equipment Storage - Garage | PAR 38 Halogen Flood | 4 | 75 | 300 | 18 | Do Nothing - Fixture To Remain | 4 | 75 | 300 | 0 | 60 | 0.00 | 0.00 | | | | | |
| Lawn Equipment Storage - Garage | 26W Exposed CFL | 1 | 26 | 26 | 1.56 | Do Nothing - Fixture To Remain | 1 | 26 | 26 | 0 | 60 | 0.00 | 0.00 | | | | | |
| Lawn Equipment Storage - Garage | 1x4, 1L T12 surface strip w/standard ballast | 1 | 42 | 42 | 2.52 | 28W T8 lamp w/high- efficiency, electronic | 1 | 26 | 26 | 16 | 60 | 0.96 | 0.07 | 35 | 42 | 2 | 79 | 1199.59 |

| Lighting Retrofit: | |
|----------------------------------|---------|
| Total Annual Demand Savings | 0 |
| Total Energy Consumption | 1 |
| Total Energy Savings / Year (\$) | \$0 |
| Total Cost of Material and | \$79 |
| St. Louis Price Adjustment (\$) | \$81 |
| Total Tax, Overhead & Profit, | \$28 |
| Total Installed Cost (\$) | \$109 |
| Total Simple Payback (Years) | 1661.55 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals:

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|----------------------|---|---------------|------------------------------|-------------------------|-----------------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Sign Shop - Storage | 1x4, 2L T12 surface industrial strip w/standard ballast | 20 | 73 | 1460 | 3416.4 | Replace with 4-lamp T8 High Bay w/electronic ballast and integral occupancy sensor | 8 | 114 | 912 | 548 | 2340 | 1,282.32 | 87.97 | 278 | 73 | 25 | 3,008 | 34.19 |
| Sign Shop - Office | 1x8, 2L 75W T12 industrial strip w/standard ballast | 1 | 158 | 158 | 369.72 | Re-lamp w/2 59W 8' T8 lamps w/high-efficiency, electronic ballast | 1 | 112 | 112 | 46 | 2340 | 107.64 | 7.38 | 40 | 52 | 2 | 94 | 12.73 |
| Sign Shop - Restroom | 1x4, 1L T12 industrial strip w/standard ballast | 1 | 42 | 42 | 98.28 | Re-lamp w/1 28W T8 lamp w/high-efficiency, electronic ballast | 1 | 26 | 26 | 16 | 2340 | 37.44 | 2.57 | 35 | 42 | 2 | 79 | 30.76 |
| Sign Shop - Storage | Incandescent Exit Sign | 1 | 20 | 20 | 175.2 | Replace with LED Exit Sign | 1 | 3 | 3 | 17 | 8760 | 148.92 | 10.22 | 55 | 65 | 5 | 125 | 12.24 |

| | Lighting Retrofit: | Controls Totals: | Total: |
|---|--------------------|------------------|---------|
| Total Annual Demand Savings (kW): | 1 | - | 1 |
| Total Energy Consumption Savings (kWh/yr) | 1,576 | 2,457 | 4,033 |
| Total Energy Savings / Year (\$) | \$108 | \$147 | \$255 |
| Total Cost of Material and Labor (\$) | \$3,306 | \$286 | \$3,592 |
| St. Louis Price Adjustment (\$) | \$3,392 | \$293 | \$3,685 |
| Total Tax, Overhead & Profit, and Contingency (\$) | \$1,187 | \$103 | \$1,290 |
| Total Installed Cost (\$) | \$4,579 | \$396 | \$4,975 |
| Total Simple Payback (Years) | 42.35 | 2.69 | 19.49 |



Detailed Energy Study University City Municipal Buildings

Controls Totals:

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts Saved / Fixture (W) | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|----------------------|---|--|---------------|---------------------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| Sign Shop - Storage | 1x4, 2L T12 surface industrial strip w/standard ballast | Replace with 4-lamp T8 High Bay w/electronic ballast and integral occupancy sensor | 8 | 114 | 912 | 8 | 2340 | 2134.08 | 127.77 | 0 | 0 | 0 | 0.00 |
| Sign Shop - Office | 1x8, 2L 75W T12 industrial strip w/standard ballast | Re-lamp w/2 59W 8', T8 lamps w/high-efficiency, electronic ballast | 1 | 112 | 112 | 1 | 2340 | 262.08 | 15.69 | 90 | 53 | 143 | 9.11 |
| Sign Shop - Restroom | 1x4, 1L T12 industrial strip w/standard ballast | Re-lamp w/1 28W T8 lamp w/high-efficiency, electronic ballast | 1 | 26 | 26 | 1 | 2340 | 60.84 | 3.64 | 90 | 53 | 143 | 39.26 |



Appendix G

Lighting Improvements Calculations (Recreation Center)– ECM-1.7



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals:

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|---|---------------|------------------------------|-------------------------|-----------------------|---|------------------|------------------------------|----------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Recreation Center - Weight Room | 2x4, 4L T8 recessed troffer w/electronic ballast | 22 | 114 | 2508 | 13432.848 | Do Nothing - Fixture To Remain | 22 | 114 | 2508 | 0 | 5356 | 0.00 | 0.00 | | | | | |
| Recreation Center - Weight Room | LED Exit Sign | 2 | 3 | 6 | 52.56 | Do Nothing - Fixture To Remain | 2 | 3 | 6 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| Recreation Center - Weight Room | 23W CFL PAR38 Recessed Can | 8 | 23 | 184 | 985.504 | Do Nothing - Fixture To Remain | 8 | 23 | 184 | 0 | 5356 | 0.00 | 0.00 | | | | | |
| Recreation Center - Restroom Corridor | 2x4, 4L T12 surface wrap w/standard ballast | 2 | 144 | 288 | 1542.528 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 2 | 86 | 172 | 116 | 5356 | 621.30 | 31.06 | 42 | 50 | 2 | 188 | 6.05 |
| Recreation Center - Restroom Corridor | 2x4, 4L T12 recessed troffer w/standard ballast | 1 | 144 | 144 | 771.264 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 58 | 5356 | 310.65 | 15.53 | 42 | 50 | 2 | 94 | 6.05 |
| Recreation Center - Restroom Corridor | 1x4, 2L T12 recessed troffer w/standard ballast | 1 | 73 | 73 | 390.988 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 22 | 5356 | 117.83 | 5.89 | 37 | 45 | 2 | 84 | 14.26 |
| Recreation Center - Men's Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | 3 | 144 | 432 | 2313.792 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 3 | 86 | 258 | 174 | 5356 | 931.94 | 46.60 | 42 | 50 | 2 | 282 | 6.05 |
| Recreation Center - Women's Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | 5 | 144 | 720 | 3856.32 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 5 | 86 | 430 | 290 | 5356 | 1,553.24 | 77.66 | 42 | 50 | 2 | 470 | 6.05 |
| Recreation Center - Rock Wall | 250W, Metal Halide Low Bay w/standard ballast | 4 | 295 | 1180 | 6320.08 | Replace with 4-lamp T5HO High Bay w/electronic ballast, cage and integral occupancy sensor | 4 | 258 | 1032 | 148 | 5356 | 792.69 | 47.46 | 313 | 123 | 25 | 1,844 | 38.86 |
| Recreation Center - Indoor Soccer | 250W, Metal Halide Low Bay w/standard ballast | 11 | 295 | 3245 | 17380.22 | Replace with 4-lamp T5HO High Bay w/electronic ballast, cage and integral occupancy sensor | 21 | 258 | 5418 | -2173 | 5356 | -11,638.59 | -696.80 | 313 | 123 | 25 | 9,681 | -13.89 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals:

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|---|---------------|------------------------------|-------------------------|-----------------------|---|------------------|------------------------------|----------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Recreation Center - Indoor Soccer | 250W, Metal Halide Low Bay w/standard ballast | 32 | 295 | 9440 | 4908.8 | All fixtures shall be removed | 0 | 0 | 0 | 9440 | 520 | 4,908.80 | 293.89 | 0 | 0 | 0 | 0 | 0.00 |
| Recreation Center - Indoor Soccer | LED Exit Sign | 4 | 3 | 12 | 105.12 | Do Nothing - Fixture To Remain | 4 | 3 | 12 | 0 | 8760 | 0.00 | 0.00 | | | | | |
| Recreation Center - Basketball Court | 250W, Metal Halide Indirect Round w/standard ballast | 20 | 295 | 5900 | 31600.4 | Replace with 4-lamp T5HO High Bay w/electronic ballast, cage and integral occupancy sensor | 15 | 258 | 3870 | 2030 | 5356 | 10,872.68 | 650.95 | 313 | 73 | 25 | 6,165 | 9.47 |

| | Lighting Retrofit: | Controls Totals: | Total: |
|---|--------------------|------------------|----------|
| Total Annual Demand Savings (kW): | 10 | - | 10 |
| Total Energy Consumption Savings (kWh/yr) | 8,471 | 11,757 | 20,228 |
| Total Energy Savings / Year (\$) | \$472 | \$752 | \$1,224 |
| Total Cost of Material and Labor (\$) | \$18,808 | \$858 | \$19,666 |
| St. Louis Price Adjustment (\$) | \$19,297 | \$880 | \$20,177 |
| Total Tax, Overhead & Profit, and Contingency (\$) | \$6,754 | \$308 | \$7,062 |
| Total Installed Cost (\$) | \$26,051 | \$1,188 | \$27,239 |
| Total Simple Payback (Years) | 55.16 | 1.58 | 22.26 |



Detailed Energy Study University City Municipal Buildings

Controls Totals:

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts Saved / Fixture (W) | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---------------------------------------|--|--|---------------|---------------------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| Recreation Center - Weight Room | 2x4, 4L, T8 recessed troffer w/electronic ballast | Do Nothing - Fixture To Remain | 22 | 114 | 2508 | 3 | 536 | 1343.28 | 85.88 | 90 | 53 | 429 | 5.00 |
| Recreation Center - Restroom Corridor | 2x4, 4L T12 surface wrap w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 2 | 86 | 172 | 1 | 536 | 92.12 | 5.89 | 90 | 53 | 143 | 24.28 |
| Recreation Center - Restroom Corridor | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 0 | 536 | 46.06 | 2.94 | 90 | 53 | 0 | 0.00 |
| Recreation Center - Restroom Corridor | 1x4, 2L T12 recessed troffer w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 0 | 536 | 27.32 | 1.75 | 90 | 53 | 0 | 0.00 |
| Recreation Center - Men's Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 3 | 86 | 258 | 1 | 536 | 138.18 | 8.83 | 90 | 53 | 143 | 16.19 |
| Recreation Center - Women's Restroom | 2x4, 4L T12 recessed troffer w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 5 | 86 | 430 | 1 | 536 | 230.31 | 14.72 | 90 | 53 | 143 | 9.71 |
| Recreation Center - Rock Wall | 250W, Metal Halide Low Bay w/standard ballast | Replace with 4-lamp T5HO High Bay w/electronic ballast, cage and integral occupancy sensor | 4 | 258 | 1032 | 4 | 536 | 552.74 | 35.34 | 0 | 0 | 0 | 0.00 |
| Recreation Center - Indoor Soccer | 250W, Metal Halide Low Bay w/standard ballast | Replace with 4-lamp T5HO High Bay w/electronic ballast, cage and integral occupancy sensor | 21 | 258 | 5418 | 21 | 1339 | 7254.70 | 463.79 | 0 | 0 | 0 | 0.00 |
| Recreation Center - Basketball Court | 250W, Metal Halide Indirect Round w/standard ballast | Replace with 4-lamp T5HO High Bay w/electronic ballast, cage and integral occupancy sensor | 15 | 258 | 3870 | 15 | 536 | 2072.77 | 132.51 | 0 | 0 | 0 | 0.00 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals:

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|---|---------------|------------------------------|-------------------------|--------------|--|------------------|------------------------------|-------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Recreation Center - Pool Entry | 26W CFL Recessed Can | 10 | 26 | 260 | 27.04 | Do Nothing - Fixture To Remain | 10 | 26 | 260 | 0 | 104 | 0.00 | 0.00 | | | | | |
| Recreation Center - Pool House | Incandescent Exit Sign | 3 | 20 | 60 | 525.6 | Replace with LED Exit Sign | 3 | 3 | 9 | 51 | 8760 | 446.76 | 22.34 | 55 | 65 | 5 | 375 | 16.79 |
| Recreation Center - Pool House | 1L T12 strip w/standard ballast | 59 | 42 | 2478 | 8504.496 | Re-lamp w/1 28W T8 lamp w/high-efficiency, electronic ballast | 59 | 26 | 1534 | 944 | 3432 | 3,239.81 | 161.99 | 37 | 45 | 2 | 4,956 | 30.59 |
| Recreation Center - Pool House | 2L T12 strip w/standard ballast | 17 | 73 | 1241 | 4259.112 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 17 | 51 | 867 | 374 | 3432 | 1,283.57 | 64.18 | 37 | 45 | 2 | 1,428 | 22.25 |
| Recreation Center - Pool House | 2L T12 strip w/standard ballast | 7 | 73 | 511 | 132.86 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 7 | 51 | 357 | 154 | 260 | 40.04 | 2.00 | 37 | 45 | 2 | 588 | 293.71 |
| Recreation Center - Pool House | 2x4, 4L T12 surface wrap w/standard ballast | 4 | 144 | 576 | 1976.832 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 4 | 86 | 344 | 232 | 3432 | 796.22 | 39.81 | 42 | 50 | 2 | 376 | 9.44 |
| Recreation Center - Electrical / Pump Room | 2L T8 damp-location strip w/electronic ballast | 11 | 59 | 649 | 2227.368 | Do Nothing - Fixture To Remain | 11 | 59 | 649 | 0 | 3432 | 0.00 | 0.00 | | | | | |
| Recreation Center - Office | 2x4, 4L T12 surface wrap w/standard ballast | 1 | 144 | 144 | 449.28 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 58 | 3120 | 180.96 | 9.05 | 42 | 50 | 2 | 94 | 10.39 |
| Recreation Center - Storage | 100W Exposed Incandescent Pendant | 1 | 100 | 100 | 5.2 | Re-lamp w/26W compact fluorescent screw-type lamps | 1 | 26 | 26 | 74 | 52 | 3.85 | 0.19 | 5 | 15 | 1 | 21 | 109.15 |



Fixture ECM Totals:

| | Lighting Retrofit: | Controls Totals: | Total: |
|--|--------------------|------------------|----------|
| Total Annual Demand Savings (kW): | 2 | - | 2 |
| Total Energy Consumption Savings (kWh/yr) | 5,991 | 1,677 | 7,669 |
| Total Energy Savings / Year (\$) | \$300 | \$107 | \$407 |
| Total Cost of Material and Labor (\$) | \$7,838 | \$1,430 | \$9,268 |
| St. Louis Price Adjustment (\$) | \$8,042 | \$1,467 | \$9,509 |
| Total Tax, Overhead & Profit, and Contingency (\$) | \$2,815 | \$514 | \$3,328 |
| Total Installed Cost (\$) | \$10,856 | \$1,981 | \$12,837 |
| Total Simple Payback (Years) | 36.24 | 18.47 | 31.56 |



Detailed Energy Study University City Municipal Buildings

Controls Totals:

| Location | Existing Fixture | Proposed Fixture | Proposed Qty. | Input Watts Saved / Fixture (W) | Proposed Wattage (W) | Proposed Control Qty. | Avg. Hours Saved / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|--|--|---------------|---------------------------------|----------------------|-----------------------|-------------------------|--------------------------|----------------------------|-------------------------|----------------------|-----------------|----------------------|
| Recreation Center - Pool House | 1L T12 strip w/standard ballast | Re-lamp w/1 28W T8 lamp w/high-efficiency, electronic ballast | 59 | 26 | 1534 | 4 | 343 | 526.47 | 33.66 | 90 | 53 | 572 | 16.99 |
| Recreation Center - Pool House | 2L T12 strip w/standard ballast | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 17 | 51 | 867 | 2 | 343 | 297.55 | 19.02 | 90 | 53 | 286 | 15.03 |
| Recreation Center - Pool House | 2x4, 4L T12 surface wrap w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 4 | 86 | 344 | 1 | 343 | 118.06 | 7.55 | 90 | 53 | 143 | 18.95 |
| Recreation Center - Electrical / Pump Room | 2L T8 damp-location strip w/electronic ballast | Do Nothing - Fixture To Remain | 11 | 59 | 649 | 2 | 1030 | 668.21 | 42.72 | 90 | 53 | 286 | 6.69 |
| Recreation Center - Office | 2x4, 4L T12 surface wrap w/standard ballast | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 1 | 780 | 67.08 | 4.29 | 90 | 53 | 143 | 33.35 |



Appendix H

Lighting Improvements Calculations (Trinity Building)– ECM-1.8



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals:

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|---|---|---------------|------------------------------|----------------------------|--------------------------|--|------------------|------------------------------|----------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Trinity Building - 1st Floor - Storage | 2x4, 4L T12 surface wrap w/standard ballast | 11 | 144 | 1584 | 31.68 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 11 | 86 | 946 | 638 | 20 | 12.76 | 0.76 | 42 | 50 | 2 | 1,034 | 1353.51 |
| Trinity Building - 1st Floor - Storage | Incandescent Exit Sign | 3 | 20 | 60 | 525.6 | Replace with LED Exit Sign | 3 | 3 | 9 | 51 | 8760 | 446.76 | 26.75 | 55 | 65 | 5 | 375 | 14.02 |
| Trinity Building - 1st Floor - Offices | 2x4, 4L T12 recessed troffer w/standard ballast | 2 | 144 | 288 | 2.88 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 2 | 86 | 172 | 116 | 10 | 1.16 | 0.07 | 42 | 50 | 2 | 188 | 2707.01 |
| Trinity Building - 1st Floor - Kitchen | 2L T12 strip w/standard ballast | 1 | 73 | 73 | 0.73 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 22 | 10 | 0.22 | 0.01 | 37 | 45 | 2 | 84 | 6377.45 |
| Trinity Building - 1st Floor - Stage / Mechanical | 90W Exposed Incandescent | 15 | 90 | 1350 | 6.75 | Re-lamp w/26W compact fluorescent screw-type lamps | 15 | 26 | 390 | 960 | 5 | 4.80 | 0.29 | 5 | 15 | 1 | 315 | 1096.12 |
| Trinity Building - 1st Floor - Stairs | 26W TTT CFL Pendant | 2 | 26 | 52 | 108.16 | Do Nothing - Fixture To Remain | 2 | 26 | 52 | 0 | 2080 | 0.00 | 0.00 | | | | | |
| Trinity Building - 1st Floor - Men's Restroom | 90W Exposed Incandescent | 1 | 90 | 90 | 0.45 | Re-lamp w/26W compact fluorescent screw-type lamps | 1 | 26 | 26 | 64 | 5 | 0.32 | 0.02 | 5 | 15 | 1 | 21 | 1096.12 |
| Trinity Building - 1st Floor - Women's Restroom | 90W Exposed Incandescent | 1 | 90 | 90 | 0.45 | Re-lamp w/26W compact fluorescent screw-type lamps | 1 | 26 | 26 | 64 | 5 | 0.32 | 0.02 | 5 | 15 | 1 | 21 | 1096.12 |
| Trinity Building - 1st Floor - Women's Restroom | 1x4, 1L T12 wall strip w/standard ballast | 1 | 42 | 42 | 87.36 | Re-lamp w/1 28W T8 lamp w/high-efficiency, electronic ballast | 1 | 26 | 26 | 16 | 2080 | 33.28 | 1.99 | 37 | 45 | 2 | 84 | 42.16 |
| Trinity Building - 1st Floor - Storage | 100W Exposed Incandescent | 4 | 100 | 400 | 0.4 | Re-lamp w/26W compact fluorescent screw-type lamps | 4 | 26 | 104 | 296 | 1 | 0.30 | 0.02 | 5 | 15 | 1 | 84 | 4740.00 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|---|---------------|------------------------------|----------------------------|--------------------------|--|------------------|------------------------------|----------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Trinity Building - 1st Floor - Hall | 2-lamp 40W Recessed Incandescent Square | 1 | 80 | 80 | 0.08 | Re-lamp w/2 9W compact fluorescent screw-type lamps | 1 | 18 | 18 | 62 | 1 | 0.06 | 0.00 | 5 | 15 | 1 | 21 | 5657.42 |
| Trinity Building - 1st Floor - Storage | 60W Exposed Incandescent | 18 | 60 | 1080 | 1.08 | Re-lamp w/13W compact fluorescent screw-type lamps | 18 | 13 | 234 | 846 | 1 | 0.85 | 0.05 | 5 | 15 | 1 | 378 | 7462.98 |
| Trinity Building - 2nd Floor - Stairs | 2L T12 wall strip w/standard ballast | 1 | 73 | 73 | 75.92 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 1 | 51 | 51 | 22 | 1040 | 22.88 | 1.37 | 37 | 45 | 2 | 84 | 61.32 |
| Trinity Building - 2nd Floor - Storage | 60W Exposed Incandescent | 18 | 60 | 1080 | 1.08 | Re-lamp w/13W compact fluorescent screw-type lamps | 18 | 13 | 234 | 846 | 1 | 0.85 | 0.05 | 5 | 15 | 1 | 378 | 7462.98 |
| Trinity Building - 2nd Floor - Stairs | 2L T12 surface wrap w/standard ballast | 2 | 73 | 146 | 151.84 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 2 | 51 | 102 | 44 | 1040 | 45.76 | 2.74 | 37 | 45 | 2 | 168 | 61.32 |
| Trinity Building - 2nd Floor - Stairs | 4L T12 surface wrap w/standard ballast | 1 | 144 | 144 | 149.76 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 1 | 86 | 86 | 58 | 1040 | 60.32 | 3.61 | 42 | 50 | 2 | 94 | 26.03 |
| Trinity Building - 2nd Floor - Storage | Incandescent Exit Sign | 1 | 20 | 20 | 175.2 | Replace with LED Exit Sign | 1 | 3 | 3 | 17 | 8760 | 148.92 | 8.92 | 55 | 65 | 5 | 125 | 14.02 |
| Trinity Building - 2nd Floor - Storage | 34W Exposed Incandescent | 39 | 34 | 1326 | 1.326 | Re-lamp w/ 9W compact fluorescent screw-type lamps | 39 | 9 | 351 | 975 | 1 | 0.98 | 0.06 | 5 | 15 | 1 | 819 | 14030.40 |
| Trinity Building - 2nd Floor - Storage | 2L T12 strip w/standard ballast | 5 | 73 | 365 | 379.6 | Re-lamp w/2 28W T8 lamps w/high-efficiency, electronic ballast | 5 | 51 | 255 | 110 | 1040 | 114.40 | 6.85 | 37 | 45 | 2 | 420 | 61.32 |
| Trinity Building - 2nd Floor - Old Library | 4L T12 surface wrap w/standard ballast | 9 | 144 | 1296 | 77.76 | Re-lamp w/4 25W T8 lamps w/high-efficiency, electronic ballast | 9 | 86 | 774 | 522 | 60 | 31.32 | 1.88 | 42 | 50 | 2 | 846 | 451.17 |



Detailed Energy Study University City Municipal Buildings

Fixture ECM Totals (Continued):

| Location | Existing Fixture | Existing Qty. | Input Watts / Fixture (W) | Existing Wattage (W) | kWh Existing (kWh) | Proposed Fixture | Proposed Qty. | Input Watts / Fixture (W) | Proposed Wattage (W) | Energy Savings (W) | Avg. Hours / Year | kWh Savings / Year (kWh) | Energy Savings / Year (\$) | Unit Material Cost (\$) | Unit Labor Cost (\$) | Unit Disposal Cost (\$) | Total Cost (\$) | Simple Payback (Yr.) |
|--|--|---------------|------------------------------|----------------------------|--------------------------|--|------------------|------------------------------|----------------------------|--------------------------|-------------------------|--------------------------------|----------------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|----------------------------|
| Trinity Building - 2nd Floor - Old Library | Incandescent Exit Sign | 2 | 20 | 40 | 350.4 | Replace with LED Exit Sign | 2 | 3 | 6 | 34 | 8760 | 297.84 | 17.83 | 55 | 65 | 5 | 250 | 14.02 |
| Trinity Building - 2nd Floor - Stairs | 5-lamp Decorative Candelabra (25W Incandescent Candelabra Lamps) | 2 | 25 | 100 | 442 | Do Nothing - Fixture To Remain | 2 | 25 | 100 | 0 | 12 | 0.00 | 0.00 | | | | | |
| Trinity Building - 2nd Floor - Entry | 2-lamp 40W Decorative Incandescent Surface Mount | 1 | 120 | 120 | 1.44 | Re-lamp w/2 13W compact fluorescent screw-type lamps | 1 | 26 | 26 | 94 | 12 | 1.13 | 0.07 | 10 | 25 | 1 | 36 | 533.07 |
| Trinity Building - 3rd Floor - Storage | 34W Exposed Incandescent | 19 | 34 | 646 | 0.646 | Re-lamp w/ 9W compact fluorescent screw-type lamps | 19 | 9 | 171 | 475 | 1 | 0.48 | 0.03 | 5 | 15 | 1 | 399 | 14030.40 |

| | Lighting Retrofit: |
|---|--------------------|
| Total Annual Demand Savings (kW): | 6 |
| Total Energy Consumption Savings (kWh/yr) | 1,226 |
| Total Energy Savings / Year (\$) | \$73 |
| Total Cost of Material and Labor (\$) | \$6,224 |
| St. Louis Price Adjustment (\$) | \$6,386 |
| Total Tax, Overhead & Profit, and Contingency (\$) | \$2,235 |
| Total Installed Cost (\$) | \$8,621 |
| Total Simple Payback (Years) | 117.48 |



Appendix I

Energy Management / Control Improvements– ECM-2



ECM-2.2: Install Progrmable Tstats & Locking Covers - Central Garage:

Cooling - Electrical Consumption

Existing Cooling Electrical Consumption:

| | | | | | | | | |
|--|----------|---|----------|---|-------------|---|--------------|---------------|
| Front Office | 2.5 tons | x | 1868 FLH | x | 1.70 kW/ton | = | 7,941 kWh/yr | |
| Shop Office | 3.0 tons | x | 1868 FLH | x | 1.40 kW/ton | = | 7,847 kWh/yr | |
| Total Existing Cooling Electrical Consumption: | | | | | | | = | 15,788 kWh/yr |

Recommended Cooling Electrical Consumption:

| | | | | | | | | |
|---|----------|---|----------|---|-------------|---|------------|---------------|
| Front Office | 2.5 tons | x | 1502 FLH | x | 0.08 kW/ton | = | 300 kWh/yr | |
| Shop Office | 3.0 tons | x | 1502 FLH | x | 0.08 kW/ton | = | 361 kWh/yr | |
| Total Recommended Cooling Electrical Consumption: | | | | | | | = | 661 kWh/yr |
| Total Cooling Electrical Consumption Savings: | | | | | | | = | 15,127 kWh/yr |

Cooling - Electrical Demand Savings

Existing Cooling Electrical Demand:

| | | | | | | | | |
|---|----------|---|--------------------|---|-------------|---|-----------|-----------|
| Front Office | 2.5 tons | x | 70% Dem. Diversity | x | 1.70 kW/ton | = | 3.0 kW/mo | |
| Shop Office | 3.0 tons | x | 70% Dem. Diversity | x | 1.40 kW/ton | = | 2.9 kW/mo | |
| Total Existing Cooling Electrical Demand: | | | | | | | = | 5.9 kW/mo |

Recommended Cooling Electrical Demand:

| | | | | | | | | |
|--|----------|---|--------------------|---|-------------|---|-----------|-----------|
| Front Office | 2.5 tons | x | 70% Dem. Diversity | x | 0.08 kW/ton | = | 0.1 kW/mo | |
| Shop Office | 3.0 tons | x | 70% Dem. Diversity | x | 0.08 kW/ton | = | 0.2 kW/mo | |
| Total Recommended Cooling Electrical Demand: | | | | | | | = | 0.3 kW/mo |
| Total Monthly Cooling Electrical Demand Savings: | | | | | | | = | 5.6 kW/mo |
| Assumes 7 months per year usage: | | | | | | | | |

Heating - Electrical Consumption

Existing Heating Electrical Consumption:

| | | | | | | | | | | |
|--|---------------|---|-------|---|----------------|---|---------------|---|---------------|---------------|
| Front Office | 25,000 Btu/hr | ÷ | 72 °F | x | 146,380 hr- °F | x | 0.292 kW/kBtu | = | 14,841 kWh/yr | |
| Shop Office | 30,000 Btu/hr | ÷ | 72 °F | x | 146,380 hr- °F | x | 0.292 kW/kBtu | = | 17,810 kWh/yr | |
| Total Existing Heating Electrical Consumption: | | | | | | | | | = | 32,651 kWh/yr |

Recommended Heating Electrical Consumption:

| | | | | | | | | | | |
|---|---------------|---|-------|---|----------------|---|---------------|---|--------------|---------------|
| Front Office | 25,000 Btu/hr | ÷ | 72 °F | x | 117,923 hr- °F | ÷ | 0.170 kW/kBtu | = | 6,961 kWh/yr | |
| Shop Office | 30,000 Btu/hr | ÷ | 72 °F | x | 117,923 hr- °F | ÷ | 0.170 kW/kBtu | = | 8,353 kWh/yr | |
| Total Recommended Heating Electrical Consumption: | | | | | | | | | = | 15,314 kWh/yr |
| Total Heating Electrical Consumption Savings: | | | | | | | | | = | 17,337 kWh/yr |

Heating - Electrical Demand

Existing Heating Electrical Demand:

| | | | | | | | | |
|---|---------------|---|---------------|---|---------------|---|-----------|-----------|
| Front Office | 25,000 Btu/hr | x | 80% Dem. Div. | x | 0.292 kW/kBtu | = | 5.8 kW/mo | |
| Shop Office | 30,000 Btu/hr | x | 80% Dem. Div. | x | 0.292 kW/kBtu | = | 7.0 kW/mo | |
| Total Existing Heating Electrical Demand: | | | | | | | = | 5.8 kW/mo |

Recommended Heating Electrical Demand:

| | | | | | | | | |
|--|---------------|---|---------------|---|---------------|---|-----------|-----------|
| Front Office | 25,000 Btu/hr | x | 80% Dem. Div. | ÷ | 0.170 kW/kBtu | = | 3.4 kW/mo | |
| Shop Office | 30,000 Btu/hr | x | 80% Dem. Div. | ÷ | 0.170 kW/kBtu | = | 4.1 kW/mo | |
| Total Recommended Heating Electrical Demand: | | | | | | | = | 3.4 kW/mo |
| Total Heating Electrical Demand Savings: | | | | | | | = | 2.4 kW/mo |
| Assumes 5 months per year usage: | | | | | | | | |



ECM-2.2: Install Progrmable Tstats & Locking Covers - Central Garage (Continued):

Supply Fan Motors - Electrical Consumption

Existing Supply Fan Motor Electrical Consumption:

| | | |
|---|--|----------------|
| Front Office | 0.25 hp x 0.746 kW/bhp x 0.85 bhp/hp ÷ 75% Motor Eff. x 7,586 hrs/yr = | 1,603 kWh/yr |
| Shop Office | 0.33 hp x 0.746 kW/bhp x 0.85 bhp/hp ÷ 75% Motor Eff. x 7,586 hrs/yr = | 2,138 kWh/yr |
| Total Existing Supply Fan Motor Electrical Consumption: | | = 3,741 kWh/yr |

Recommended Supply Fan Motor Electrical Consumption:

| | | |
|--|--|----------------|
| Front Office | 0.25 hp x 0.746 kW/bhp x 0.85 bhp/hp ÷ 93% Motor Eff. x 6,502 hrs/yr = | 1,108 kWh/yr |
| Shop Office | 0.33 hp x 0.746 kW/bhp x 0.85 bhp/hp ÷ 93% Motor Eff. x 6,502 hrs/yr = | 1,478 kWh/yr |
| Total Recommended Supply Fan Motor Electrical Consumption: | | = 2,586 kWh/yr |
| Total Supply Fan Motor Electrical Consumption Savings: | | = 1,155 kWh/yr |

Supply Fan Motors - Electrical Demand

Existing Supply Fan Motor Electrical Demand:

| | | |
|--|---|-------------|
| Front Office | 0.25 hp x 0.746 kW/bhp x 0.85 bhp/hp ÷ 75% Motor Eff. x 80% Dem. Div. = | 0.2 kw/mo |
| Shop Office | 0.33 hp x 0.746 kW/bhp x 0.85 bhp/hp ÷ 75% Motor Eff. x 80% Dem. Div. = | 0.2 kw/mo |
| Total Existing Supply Fan Motor Electrical Demand: | | = 0.4 kW/mo |

Recommended Supply Fan Motor Electrical Demand:

| | | |
|---|---|-------------|
| Front Office | 0.25 hp x 0.746 kW/bhp x 0.85 bhp/hp ÷ 93% Motor Eff. x 80% Dem. Div. = | 0.1 kw/mo |
| Shop Office | 0.33 hp x 0.746 kW/bhp x 0.85 bhp/hp ÷ 93% Motor Eff. x 80% Dem. Div. = | 0.2 kw/mo |
| Total Recommended Supply Fan Motor Electrical Demand: | | = 0.3 kW/mo |
| Total Supply Fan Motor Electrical Demand Savings: | | = 0.1 kW/mo |
| Assumes 12 months per year usage: | | |



ECM-2.2: Install Plug Load Occupancy Sensors - City Hall:

Office Equipment - Electrical Consumption

Existing Electrical Consumption:

| | | | | |
|--|---------------------------------|---|---------------------------------|-----------------|
| Accessories | In-Use (24 hrs/day * 7 days/wk) | 55 Qty. x 40 Accessory Watts/desktop * x 24 hrs/day x 7 days/wk = | 19,282,032 Watts ÷ 1,000 W/kW = | 19,282 kWh/yr |
| Total Existing Electrical Consumption: | | | | = 19,282 kWh/yr |

Recommended Electrical Consumption:

| | | | | |
|---|---------------------------------|--|--------------------------------|----------------|
| Accessories | In-Use (12 hrs/day * 5 days/wk) | 55 Qty. x 40 Accessory Watts/desktop * x 8 hrs/day x 5 days/wk = | 4,590,960 Watts ÷ 1,000 W/kW = | 4,591 kWh/yr |
| Total Recommended Electrical Consumption: | | | | = 4,591 kWh/yr |

| | | | | |
|---------------------------------------|--|--|--|-----------------|
| Total Electrical Consumption Savings: | | | | = 14,691 kWh/yr |
|---------------------------------------|--|--|--|-----------------|

ECM-2.3: Install Plug Load Occupancy Sensors - Annex:

Office Equipment - Electrical Consumption

Existing Electrical Consumption:

| | | | | |
|--|---------------------------------|---|---------------------------------|-----------------|
| Accessories | In-Use (24 hrs/day * 7 days/wk) | 75 Qty. x 40 Accessory Watts/desktop * x 24 hrs/day x 7 days/wk = | 26,293,680 Watts ÷ 1,000 W/kW = | 26,294 kWh/yr |
| Total Existing Electrical Consumption: | | | | = 26,294 kWh/yr |

Recommended Electrical Consumption:

| | | | | |
|---|---------------------------------|---|--------------------------------|----------------|
| Accessories | In-Use (12 hrs/day * 5 days/wk) | 75 Qty. x 40 Accessory Watts/desktop * x 12 hrs/day x 5 days/wk = | 9,390,600 Watts ÷ 1,000 W/kW = | 9,391 kWh/yr |
| Total Recommended Electrical Consumption: | | | | = 9,391 kWh/yr |

| | | | | |
|---------------------------------------|--|--|--|-----------------|
| Total Electrical Consumption Savings: | | | | = 16,903 kWh/yr |
|---------------------------------------|--|--|--|-----------------|



Appendix J

Heating, Ventilation, & Air Conditioning Improvements – ECM-4



ECM-4.1: Unit Replacement - Annex:

Cooling - Electrical Consumption

Existing Cooling Electrical Consumption:

| | | | | | | | | |
|--|-----|------|---|----------|---|-------------|---|-----------------|
| Detectives | 5.0 | tons | x | 2012 FLH | x | 1.40 kW/ton | = | 14,083 kWh/yr |
| Office | 3.0 | tons | x | 2012 FLH | x | 1.40 kW/ton | = | 8,450 kWh/yr |
| Fire Chief/Kitchen | 3.0 | tons | x | 2012 FLH | x | 1.40 kW/ton | = | 8,450 kWh/yr |
| Server Rm | 3.0 | tons | x | 2012 FLH | x | 1.40 kW/ton | = | 8,450 kWh/yr |
| Telephone Rm | 3.0 | tons | x | 2012 FLH | x | 1.40 kW/ton | = | 8,450 kWh/yr |
| Basement Cells | 3.0 | tons | x | 2012 FLH | x | 1.40 kW/ton | = | 8,450 kWh/yr |
| Total Existing Cooling Electrical Consumption: | | | | | | | | = 56,332 kWh/yr |

Recommended Cooling Electrical Consumption:

| | | | | | | | | |
|---|-----|------|---|----------|---|-------------|---|-----------------|
| Detectives | 5.0 | tons | x | 2012 FLH | x | 0.08 kW/ton | = | 805 kWh/yr |
| Office | 3.0 | tons | x | 2012 FLH | x | 0.08 kW/ton | = | 483 kWh/yr |
| Fire Chief/Kitchen | 3.0 | tons | x | 2012 FLH | x | 0.08 kW/ton | = | 483 kWh/yr |
| Server Rm | 3.0 | tons | x | 2012 FLH | x | 0.08 kW/ton | = | 483 kWh/yr |
| Telephone Rm | 3.0 | tons | x | 2012 FLH | x | 0.08 kW/ton | = | 483 kWh/yr |
| Basement Cells | 3.0 | tons | x | 2012 FLH | x | 0.08 kW/ton | = | 483 kWh/yr |
| Total Recommended Cooling Electrical Consumption: | | | | | | | | = 3,219 kWh/yr |
| Total Cooling Electrical Consumption Savings: | | | | | | | | = 53,113 kWh/yr |

Cooling - Electrical Demand Savings

Existing Cooling Electrical Demand:

| | | | | | | | | |
|---|-----|------|---|--------------------|---|-------------|---|--------------|
| Detectives | 5.0 | tons | x | 70% Dem. Diversity | x | 1.40 kW/ton | = | 4.9 kW/mo |
| Office | 3.0 | tons | x | 70% Dem. Diversity | x | 1.40 kW/ton | = | 2.9 kW/mo |
| Fire Chief/Kitchen | 3.0 | tons | x | 70% Dem. Diversity | x | 1.40 kW/ton | = | 2.9 kW/mo |
| Server Rm | 3.0 | tons | x | 70% Dem. Diversity | x | 1.40 kW/ton | = | 2.9 kW/mo |
| Telephone Rm | 3.0 | tons | x | 70% Dem. Diversity | x | 1.40 kW/ton | = | 2.9 kW/mo |
| Basement Cells | 3.0 | tons | x | 70% Dem. Diversity | x | 1.40 kW/ton | = | 2.9 kW/mo |
| Total Existing Cooling Electrical Demand: | | | | | | | | = 19.6 kW/mo |

Recommended Cooling Electrical Demand:

| | | | | | | | | |
|--|-----|------|---|--------------------|---|-------------|---|--------------|
| Detectives | 5.0 | tons | x | 70% Dem. Diversity | x | 0.08 kW/ton | = | 0.3 kW/mo |
| Office | 3.0 | tons | x | 70% Dem. Diversity | x | 0.08 kW/ton | = | 0.2 kW/mo |
| Fire Chief/Kitchen | 3.0 | tons | x | 70% Dem. Diversity | x | 0.08 kW/ton | = | 0.2 kW/mo |
| Server Rm | 3.0 | tons | x | 70% Dem. Diversity | x | 0.08 kW/ton | = | 0.2 kW/mo |
| Telephone Rm | 3.0 | tons | x | 70% Dem. Diversity | x | 0.08 kW/ton | = | 0.2 kW/mo |
| Basement Cells | 3.0 | tons | x | 70% Dem. Diversity | x | 0.08 kW/ton | = | 0.2 kW/mo |
| Total Recommended Cooling Electrical Demand: | | | | | | | | = 1.1 kW/mo |
| Total Monthly Cooling Electrical Demand Savings: | | | | | | | | = 18.5 kW/mo |

Heating - Electrical Consumption

Existing Heating Electrical Consumption:

| | | |
|--|--|-----------------|
| Basement Cells | 30,000 Btu/hr ÷ 72 °F x 146,380 hr- °F x 0.213 kW/kBtu | = 12,961 kWh/yr |
| Total Existing Heating Electrical Consumption: | | = 12,961 kWh/yr |

Recommended Heating Electrical Consumption:

| | | |
|---|--|-----------------|
| Detectives | 30,000 Btu/hr ÷ 72 °F x 146,380 hr- °F ÷ 0.170 kW/kBtu | = 10,369 kWh/yr |
| Total Recommended Heating Electrical Consumption: | | = 10,369 kWh/yr |



ECM-4.1: Unit Replacement - Annex (Continued):

Heating - Electrical Demand

Existing Heating Electrical Demand:

| | | |
|---|---|-------------|
| Basement Cells | 30,000 Btu/hr x 80% Dem. Div. x 0.213 kW/kBtu = | 5.1 kW/mo |
| Total Existing Heating Electrical Demand: | | = 5.1 kW/mo |

Recommended Heating Electrical Demand:

| | | |
|--|---|-------------|
| Detectives | 30,000 Btu/hr x 80% Dem. Div. ÷ 0.170 kW/kBtu = | 4.1 kW/mo |
| Total Recommended Heating Electrical Demand: | | = 4.1 kW/mo |
| Total Heating Electrical Demand Savings: | | = 1.0 kW/mo |

Water-Source Heat Pump Water Consumption

Existing WSHP Consumption:

| | | |
|--|--|---------------|
| Server Rm | 3 tons x 12,000 Btu/ton = 36,000 Btu ÷ 500 ÷ 12 °F _Δ T = 6 GPM = 360 GPH x 2012 FLH = | 724.27 kgal |
| Telephone Rm | 3 tons x 12,000 Btu/ton = 36,000 Btu ÷ 500 ÷ 12 °F _Δ T = 6 GPM = 360 GPH x 2012 FLH = | 724.27 kgal |
| Basement Cells | 3 tons x 12,000 Btu/ton = 36,000 Btu ÷ 500 ÷ 12 °F _Δ T = 6 GPM = 360 GPH x 2012 FLH = | 724.27 kgal |
| Total Existing WSHP Water Consumption Savings: | | 2,172.82 kgal |

Avoided Maintenance Costs

Assume HVAC System Replacement is avoided maintenance.
 Assume replacement happens in 1 years.
 Assume estimated life of new equipment is 15 years.
 Future Value of: \$10,675 (F/P 4.00% 1) = \$11,102
 Annual Value of: \$11,102 (A/P 4.00% 15) = \$999



ECM-4.2: Pump Motor Replacement - Heman Park Pool:

Pump Motors - Electrical Consumption

Existing Pump Motor Electrical Consumption:

| | | | | | | |
|---|---------|----------------|---------------|------------------|----------------|-----------------|
| Main Pool Filtration | 40 hp x | 0.746 kW/bhp x | 0.85 bhp/hp ÷ | 75% Motor Eff. x | 2,400 hrs/yr = | 81,165 kWh/yr |
| Total Existing Pump Motor Electrical Consumption: | | | | | | = 81,165 kWh/yr |

Recommended Pump Motor Electrical Consumption:

| | | | | | | |
|--|---------|----------------|---------------|------------------|----------------|-----------------|
| Main Pool Filtration | 40 hp x | 0.746 kW/bhp x | 0.85 bhp/hp ÷ | 93% Motor Eff. x | 2,400 hrs/yr = | 65,455 kWh/yr |
| Total Recommended Pump Motor Electrical Consumption: | | | | | | = 65,455 kWh/yr |
| Total Pump Motor Electrical Consumption Savings: | | | | | | = 15,709 kWh/yr |

Pump Motors - Electrical Demand

Existing Pump Motor Electrical Demand:

| | | | | | | |
|--|---------|----------------|---------------|------------------|-----------------|--------------|
| Main Pool Filtration | 40 hp x | 0.746 kW/bhp x | 0.85 bhp/hp ÷ | 75% Motor Eff. x | 80% Dem. Div. = | 27.1 kw/mo |
| Total Existing Pump Motor Electrical Demand: | | | | | | = 27.1 kW/mo |

Recommended Pump Motor Electrical Demand:

| | | | | | | |
|---|---------|----------------|---------------|------------------|-----------------|--------------|
| Main Pool Filtration | 40 hp x | 0.746 kW/bhp x | 0.85 bhp/hp ÷ | 93% Motor Eff. x | 80% Dem. Div. = | 21.8 kw/mo |
| Total Recommended Pump Motor Electrical Demand: | | | | | | = 21.8 kW/mo |
| Total Pump Motor Electrical Demand Savings: | | | | | | = 5.2 kW/mo |

Avoided Maintenance Costs

Assume HVAC System Replacement is avoided maintenance.

Assume replacement happens in 5 years.

Assume estimated life of new equipment is 15 years.

Future Value of: \$6,550 (F/P 4.00% 5) = \$7,969

Annual Value of: \$7,969 (A/P 4.00% 15) = \$717



ECM-4.3: Unit Replacement - Central Garage:

Cooling - Electrical Consumption

Existing Cooling Electrical Consumption:

| | | | | | | | | |
|--|----------|---|----------|---|-------------|---|--------------|---------------|
| Front Office | 2.5 tons | x | 1868 FLH | x | 1.70 kW/ton | = | 7,941 kWh/yr | |
| Shop Office | 3.0 tons | x | 1868 FLH | x | 1.40 kW/ton | = | 7,847 kWh/yr | |
| Total Existing Cooling Electrical Consumption: | | | | | | | = | 15,788 kWh/yr |

Recommended Cooling Electrical Consumption:

| | | | | | | | | |
|---|----------|---|----------|---|-------------|---|------------|---------------|
| Front Office | 2.5 tons | x | 1868 FLH | x | 0.08 kW/ton | = | 374 kWh/yr | |
| Shop Office | 3.0 tons | x | 1868 FLH | x | 0.08 kW/ton | = | 448 kWh/yr | |
| Total Recommended Cooling Electrical Consumption: | | | | | | | = | 822 kWh/yr |
| Total Cooling Electrical Consumption Savings: | | | | | | | = | 14,966 kWh/yr |

Cooling - Electrical Demand Savings

Existing Cooling Electrical Demand:

| | | | | | | | | |
|---|----------|---|--------------------|---|-------------|---|-----------|-----------|
| Front Office | 2.5 tons | x | 70% Dem. Diversity | x | 1.70 kW/ton | = | 3.0 kW/mo | |
| Shop Office | 3.0 tons | x | 70% Dem. Diversity | x | 1.40 kW/ton | = | 2.9 kW/mo | |
| Total Existing Cooling Electrical Demand: | | | | | | | = | 5.9 kW/mo |

Recommended Cooling Electrical Demand:

| | | | | | | | | |
|--|----------|---|--------------------|---|-------------|---|-----------|-----------|
| Front Office | 2.5 tons | x | 70% Dem. Diversity | x | 0.08 kW/ton | = | 0.1 kW/mo | |
| Shop Office | 3.0 tons | x | 70% Dem. Diversity | x | 0.08 kW/ton | = | 0.2 kW/mo | |
| Total Recommended Cooling Electrical Demand: | | | | | | | = | 0.3 kW/mo |
| Total Monthly Cooling Electrical Demand Savings: | | | | | | | = | 5.6 kW/mo |

Heating - Electrical Consumption

Existing Heating Electrical Consumption:

| | | | | | | | | | | |
|--|---------------|---|-------|---|---------------|---|---------------|---|---------------|---------------|
| Front Office | 25,000 Btu/hr | ÷ | 72 °F | x | 146,380 hr-°F | x | 0.292 kW/kBtu | = | 14,841 kWh/yr | |
| Shop Office | 30,000 Btu/hr | ÷ | 72 °F | x | 146,380 hr-°F | x | 0.292 kW/kBtu | = | 17,810 kWh/yr | |
| Total Existing Heating Electrical Consumption: | | | | | | | | | = | 32,651 kWh/yr |

Recommended Heating Electrical Consumption:

| | | | | | | | | | | |
|---|---------------|---|-------|---|---------------|---|---------------|---|---------------|---------------|
| Front Office | 25,000 Btu/hr | ÷ | 72 °F | x | 146,380 hr-°F | ÷ | 0.170 kW/kBtu | = | 8,640 kWh/yr | |
| Shop Office | 30,000 Btu/hr | ÷ | 72 °F | x | 146,380 hr-°F | ÷ | 0.170 kW/kBtu | = | 10,369 kWh/yr | |
| Total Recommended Heating Electrical Consumption: | | | | | | | | | = | 19,009 kWh/yr |
| Total Heating Electrical Consumption Savings: | | | | | | | | | = | 13,642 kWh/yr |

Heating - Electrical Demand

Existing Heating Electrical Demand:

| | | | | | | | | |
|---|---------------|---|---------------|---|---------------|---|-----------|-----------|
| Front Office | 25,000 Btu/hr | x | 80% Dem. Div. | x | 0.292 kW/kBtu | = | 5.8 kW/mo | |
| Shop Office | 30,000 Btu/hr | x | 80% Dem. Div. | x | 0.292 kW/kBtu | = | 7.0 kW/mo | |
| Total Existing Heating Electrical Demand: | | | | | | | = | 5.8 kW/mo |

Recommended Heating Electrical Demand:

| | | | | | | | | |
|--|---------------|---|---------------|---|---------------|---|-----------|-----------|
| Front Office | 25,000 Btu/hr | x | 80% Dem. Div. | ÷ | 0.170 kW/kBtu | = | 3.4 kW/mo | |
| Shop Office | 30,000 Btu/hr | x | 80% Dem. Div. | ÷ | 0.170 kW/kBtu | = | 4.1 kW/mo | |
| Total Recommended Heating Electrical Demand: | | | | | | | = | 3.4 kW/mo |
| Total Heating Electrical Demand Savings: | | | | | | | = | 2.4 kW/mo |



ECM-4.3: Unit Replacement - Central Garage (Continued):

Supply Fan Motors - Electrical Consumption

Existing Supply Fan Motor Electrical Consumption:

| | | |
|---|---|----------------|
| Front Office | $0.25 \text{ hp} \times 0.746 \text{ kW/bhp} \times 0.85 \text{ bhp/hp} \div 75\% \text{ Motor Eff.} \times 2,400 \text{ hrs/yr} =$ | 507 kWh/yr |
| Shop Office | $0.33 \text{ hp} \times 0.746 \text{ kW/bhp} \times 0.85 \text{ bhp/hp} \div 75\% \text{ Motor Eff.} \times 2,400 \text{ hrs/yr} =$ | 676 kWh/yr |
| Total Existing Supply Fan Motor Electrical Consumption: | | = 1,184 kWh/yr |

Recommended Supply Fan Motor Electrical Consumption:

| | | |
|--|---|--------------|
| Front Office | $0.25 \text{ hp} \times 0.746 \text{ kW/bhp} \times 0.85 \text{ bhp/hp} \div 93\% \text{ Motor Eff.} \times 2,400 \text{ hrs/yr} =$ | 409 kWh/yr |
| Shop Office | $0.33 \text{ hp} \times 0.746 \text{ kW/bhp} \times 0.85 \text{ bhp/hp} \div 93\% \text{ Motor Eff.} \times 2,400 \text{ hrs/yr} =$ | 545 kWh/yr |
| Total Recommended Supply Fan Motor Electrical Consumption: | | = 955 kWh/yr |
| Total Supply Fan Motor Electrical Consumption Savings: | | = 229 kWh/yr |

Supply Fan Motors - Electrical Demand

Existing Supply Fan Motor Electrical Demand:

| | | |
|--|---|-------------|
| Front Office | $0.25 \text{ hp} \times 0.746 \text{ kW/bhp} \times 0.85 \text{ bhp/hp} \div 75\% \text{ Motor Eff.} \times 80\% \text{ Dem. Div.} =$ | 0.2 kw/mo |
| Shop Office | $0.33 \text{ hp} \times 0.746 \text{ kW/bhp} \times 0.85 \text{ bhp/hp} \div 75\% \text{ Motor Eff.} \times 80\% \text{ Dem. Div.} =$ | 0.2 kw/mo |
| Total Existing Supply Fan Motor Electrical Demand: | | = 0.4 kW/mo |

Recommended Supply Fan Motor Electrical Demand:

| | | |
|---|---|-------------|
| Front Office | $0.25 \text{ hp} \times 0.746 \text{ kW/bhp} \times 0.85 \text{ bhp/hp} \div 93\% \text{ Motor Eff.} \times 80\% \text{ Dem. Div.} =$ | 0.1 kw/mo |
| Shop Office | $0.33 \text{ hp} \times 0.746 \text{ kW/bhp} \times 0.85 \text{ bhp/hp} \div 93\% \text{ Motor Eff.} \times 80\% \text{ Dem. Div.} =$ | 0.2 kw/mo |
| Total Recommended Supply Fan Motor Electrical Demand: | | = 0.3 kW/mo |
| Total Supply Fan Motor Electrical Demand Savings: | | = 0.1 kW/mo |

Avoided Maintenance Costs

Assume HVAC System Replacement is avoided maintenance.
 Assume replacement happens in 1 years.
 Assume estimated life of new equipment is 15 years.
 Future Value of: \$10,675 (F/P 4.00% 1) = \$11,102
 Annual Value of: \$11,102 (A/P 4.00% 15) = \$999



Appendix K

Mechanical Inventory



Detailed Energy Study University City Municipal Buildings

| Mechanical Equipment Inventory | | | | | | | | | | | | | | | |
|--------------------------------|-----------|-----------------------|--------------------------------|---------------|-----------------------|-------------------|-------------------|------------|--------|------|----------|--------|------------|----------------------|--|
| Elevator: | Quantity: | Area Served: | Type: | Manufacturer: | Model # | Serial #: | Capacity: | Fan HP: | RLA: | FLA: | Voltage: | Phase: | Condition: | Date of Manufacture: | Notes: |
| Annex | | | | | | | | | | | | | | | |
| 3rd / Roof | 1 | Office | DX/Gas Split | Carrier | 38TKB036 | 0600E09480 | 3-tons | - | 15.3 | - | 208 | 3 | Fair | 2000 | |
| Roof | 1 | Detectives | DX/Gas RTU | York | D4CG060 | NHBM060332 | 5-tons | 1 | 16.7 | 2.6 | 208 | 3 | Poor | 1989 | |
| Roof | 1 | Fire Bunks | DX/Gas RTU | Carrier | 58TDJ016 | 5004F1973 | 15-tons | 4 | 2@25.6 | 10.5 | 208 | 3 | Good | 2004 | Has Economizer |
| 3rd / Roof | 1 | Office | DX/Gas Split | Carrier | 38VE004 | B954678 | 3-tons | - | 17.8 | - | 208 | 3 | Poor | 1986 | |
| 1st | 1 | Fire Truck Bay | Steam Unit | | | | | | | | | | | | |
| Basement/Grade | 1 | Fire Chief/Kitchen | DX/Steam Split | Carrier | 38CKB036 | 2096E06509 | 3-tons | - | 15.7 | - | 208 | 1 | Poor | 1996 | |
| Grade | 1 | Police Offices | CU | Carrier | 24ABB360 | 080E0964 | 5-tons | - | 26.4 | - | 208 | 1 | Good | 2009 | |
| Grade | 1 | Police Offices | CU | Carrier | 24ABR360 | 0206E19627 | 5-tons | - | 25.3 | - | 208 | 1 | Good | 2006 | |
| Grade | 1 | Fire Office/EOC | CU | Carrier | 38AUZ16A065A | 0910U03949 | 13-tons | 1 | 2@25 | - | 208 | 1 | Good | 2008 | |
| 1st | 1 | Fire Office/EOC | AHU (DX/Steam) | Carrier | 40RM-016 | 3806U24297 | 13-tons | 4 | - | 10.6 | 208 | 3 | Good | 2006 | Has Economizer |
| 1st | 1 | Semer Rm | Vert. Water Source CRU | Kold-wave | | | | | | | | | | | Uses domestic water in a single pass-through |
| 1st | 1 | Telephone Rm | Horiz. Water Source CRU | Carrier | 50HQ033511 | 3200781 | 3-tons | - | 13.8 | 2.5 | 208 | 3 | Fair | - | Uses domestic water in a single pass-through |
| Basement | 1 | Firing Range | Gas Heat Herz. AHU | Applied Air | DFS-15 hrs | 76-DFS-229 F01321 | 378.00 BTUH | 1 | - | - | 208 | 3 | Good | - | Heating Only |
| Basement | 1 | Cells | Vert. Water Source CRU | Kold-wave | 3RC31D12 | | 3-tons | 1/2 | 18 | 2.86 | 208 | 3 | Poor | - | Uses domestic water in a single pass-through |
| 1st | 1 | Police Offices | AHU (DX/Gas) | Carrier | 40RM012 | 3806U24391 | 10-tons | 3 | - | 5.8 | 208 | 3 | Good | 2006 | |
| 1st | 1 | Locker Rooms | Split System (DX/Gas) | Carrier | 38BRC030 | 2100E21912 | 2.5-tons | - | 15 | - | 208 | 3 | Fair | 2000 | |
| 2nd | 1 | Service Support | Split System (DX/Gas) | Comfort Maker | AA1BJ036 | 4994E05577 | 3-tons | - | 16.1 | - | 208 | 3 | Poor | 2000 | |
| Roof | 1 | Police Dispatch | RTU (DX/Elec) | Carrier | 50TFF006 | 1407G10298 | 5-tons | - | 16 | 5.2 | 208 | 3 | Good | 2007 | |
| City Hall | | | | | | | | | | | | | | | |
| Basement | 1 | Condensate | Duplex condensate pump | B&G | 23CBE22-20 | OE1672-SA0590904 | 22 gpm | 1/2 | - | 19.2 | 115 | 1 | Good | 2005 | |
| Basement | 2 | Cooling Tower | End Suction Pump | B&G | 1510 3AC BF 6.5 | | 311 gpm @ 31 ft | 5 | - | - | 208 | 3 | Good | 2005 | |
| Basement | 2 | Bldg. Condenser Water | End Suction Pump | B&G | 1510 3BC BF 8.125 | | 311 @ 60 ft | 10 | - | - | 208 | 3 | Good | 2005 | |
| Grade | 1 | Condenser Water | Cooling Tower | Evapco | ICT 4-612 | | | - | - | - | - | - | Good | 2005 | Induced Draft Counter Flow with VFD |
| Basement | 1 | Condenser Water | Plate & Frame Heat Exchanger | ITT - B&G | BY5409 | 953899-03 | | - | - | - | - | - | Good | 2005 | |
| Basement | 1 | Condenser Water | Shell & Tube Heat Exchanger | B&G | BOSU10 2+2 | | 296 GPM | - | - | - | - | - | Good | 2005 | |
| Various | 40 | Conditioned Space | Water Source Heat Pumps | Trane | GEH/GEC | | 100 tons total | - | - | - | 115 | 1 | Good | 2005 | |
| Herman Park Pool | | | | | | | | | | | | | | | |
| 1st | 1 | Pool Office | WAC | Zenith | | | 1-ton | - | - | - | - | - | Fair | - | |
| 1st | 1 | Main Pool | Pump Motor | Emerson | T661 | | | 40 | - | - | 460 | 3 | Good | - | 93% Eff. |
| 1st | 1 | Main Pool | Pump Motor | | | | | 40 | - | - | 460 | 3 | Poor | - | Near the end of its useful life |
| 1st | 1 | Kid Pool | Pump Motor | Marathon Elec | | | | 7 1/2 | - | - | - | - | Good | New | 87.50% |
| 1st | 1 | Kid Pool | Pump Motor | Magnetek | H492 | | | 3/4 | - | - | - | - | Fair | - | 3450 RPM |
| 1st | 1 | Domestic Hot Water | Natural Gas Fired Water Heater | A. O. Smith | BTR 154 104 | ML990886210 | 154 MBH | - | - | - | - | - | Good | - | 149 Gal/hr recovery |
| Centennial Commons | | | | | | | | | | | | | | | |
| 1st | 2 | Domestic Hot Water | Electric Water Heater | State | CSB12027SFEB | J05M007606 | 119 Gal / 27 kW | - | - | - | 460 | 3 | Good | 2005 | |
| 1st | 3 | Indoor Soccer Field | Gas Fired Forced Air Furnace | Reznor | | | | - | - | - | - | - | - | - | |
| Roof | 1 | Exercise Area | RTU Cooling Only (RTU-1) | Trane | TCD600 | | 50-tons | - | - | - | 460 | 3 | Good | 2005 | |
| 1st | 1 | RTU-1 | Energy Recovery Ventilator | SEMCO | FB-7500TS | | 5600 CFM | - | - | - | 460 | 3 | Good | 2005 | |
| Roof | 1 | Gymnasium | RTU (DX/Gas) | Trane | YCD480 | | 40-ton | - | - | - | 460 | 3 | Good | 2005 | |
| Roof | 9 | Varies | Exhaust Fan | Cook | | | | Fractional | - | - | Varies | - | Good | 2005 | |
| Fire House #2 | | | | | | | | | | | | | | | |
| 1st | 1 | Domestic Hot Water | Gas Water Heater | A.O.Smith | BTH 199 970 | MD040013130 | 100 Gal / 200 MBH | - | - | - | 120 | 1 | Good | 2004 | |
| 1st | 2 | Truck Bays | Gas Unit Heater | Reznor | | | | - | - | - | - | - | - | - | |
| 2nd | 1 | Workout Room | PTAC | Carrier | | | 1-ton | - | - | - | - | - | Good | 2005 | |
| Roof | 6 | - | Exhaust Fans | - | - | - | - | - | - | - | - | - | - | - | |
| Roof | 1 | Training Room | Split DX / Elec | Lennox | XC21-060-230-02 | 5806C09081 | 5-ton | - | 25.7 | - | 208 | 1 | Good | 2006 | Humidifier |
| Roof | 1 | South Bedrooms | Split DX / Elec | Lennox | XC21-060-230-02 | 5806B44235 | 5-ton | - | 25.7 | - | 208 | 1 | Good | 2006 | Humidifier |
| Roof | 1 | North Bedrooms | Split DX / Elec | Lennox | XC21-060-230-02 | 5806C09077 | 5-ton | - | 25.7 | - | 208 | 1 | Good | 2006 | Humidifier |
| Roof | 1 | - | Exhaust Fan | Cook | 012012 GI 12X12GI AL | 180S884444 | | - | - | - | - | - | Good | 2006 | |
| Roof | 1 | - | Exhaust Fan | Cook | 024024 GR 24x24 GI AL | 180S884444 | | - | - | - | - | - | Good | 2006 | |
| Grade | 1 | 1st Floor | Split DX / Elec | Lennox | XC21-036-130-02 | 5806A47736 | 3-ton | - | 16.7 | - | 208 | 1 | Good | 2006 | |
| Grade | 1 | 1st Floor | Split DX / Elec | Lennox | XC21-060-230-02 | 5806C09070 | 5-ton | - | 25.7 | - | 208 | 1 | Good | 2006 | |



Detailed Energy Study University City Municipal Buildings

| Mechanical Equipment Inventory | | | | | | | | | | | | | | | | |
|--------------------------------|----------|--------------------|---------------------------------|---------------|---------------|--------------|-------------------|--------|-----------|------|---------|-------|-----------|---------------------|--|------------|
| Elevation | Quantity | Area Served | Type | Manufacturer | Model # | Serial # | Capacity | Fan HP | RLA | FLA | Voltage | Phase | Condition | Date of Manufacture | Notes | |
| Herman Park C. C. | | | | | | | | | | | | | | | | |
| 1st | 1 | Storage | Electric Unit Heater | Qmark | MUH-03-2 | 07-88-322 | 2-2/3 kW | - | - | - | 208 | 1 | Good | - | | |
| 1st | 1 | Domestic Hot Water | Gas Water Heater | A. O. Smith | FS3 75 | GM96-3403752 | 230 gal / 75 MBH | - | - | - | - | - | Good | - | | |
| Grade | 1 | Conditioned Space | PKU (DX/Gas) | Carrier | 48LJD24 | - | 20-tons | 5 | - | - | - | - | Fair | - | 242 MBH | |
| Grade | 1 | Conditioned Space | PKU (DX/Gas) | American Std. | YCH181 | 928100451D | 15-ton | 3 | 29.5/17.6 | 10.6 | 308 | 3 | Good | 2009 | High Efficiency | |
| Grade | 1 | Conditioned Space | Split | Carrier | 38EN036320 | - | 3-ton | - | 21 | - | 208 | 3 | Poor | 1987 | | |
| Central Garage | | | | | | | | | | | | | | | | |
| Basement | 1 | Front Office | Vertical Fan Coil Unit (DX) | Bryant | FA4ANF030 | 0697A12546 | 2.5-ton | 1/4 | - | 1.8 | 208/230 | 1 | Poor | 2006 | Maintenance Issue, Offices have window units | |
| Roof | 1 | Front Office | CU | Carrier | 38CKC030 | 2497E07006 | 2.5-ton | - | 14.8 | - | 208/230 | 1 | Poor | 1997 | Maintenance Issue, Offices have window units | |
| Mezzanine | 1 | Shop Office | Horizontal Fan Coil Unit (DX) | Bryant | FA4NF036 | 1497A10931 | 3-ton | 1/3 | - | 2.4 | 208/230 | 1 | Poor | 1997 | | |
| Roof | 1 | Shop Office | CU | Carrier | 38CKC036 | 1697F11812 | 3-ton | - | 15 | - | 208/230 | 1 | Poor | 1997 | | |
| 1st | 10 | Shop | Infrared Heater | Re-verber-ray | DTH S ___-100 | - | 100 MBH | - | - | - | - | - | Good | - | | |
| 1st | 2 | Shop | Gas Unit Heater | Reznor | - | - | - | - | - | - | - | - | Fair | - | | |
| 1st | 1 | Shop | Gas Unit Heater | Sterling | - | - | - | - | - | - | - | - | Fair | - | | |
| 1st | 3 | Front Office | Window Air Conditioner | Various | - | - | 3-ton total | - | - | - | - | - | Fair | - | | |
| Transfer Station | | | | | | | | | | | | | | | | |
| 1st | 1 | Office | PTAC | - | - | - | 1-ton | - | - | - | - | - | Poor | - | Inoperable | |
| 1st | 1 | Building Heat | Direct Fired MAU | Absolut/Aire | AA-3U | 14261 | 8000 CFM/ 900 MBH | 7 | 1/2 | - | 23 | 230 | 3 | Fair | - | 99.7% eff. |
| 2nd | 1 | MRF Shack | WAC | - | - | - | 1-ton | - | - | - | - | - | Fair | - | | |
| 2nd | 1 | MRF Shack | Elec. Wall Heater | - | - | - | 1.5 kW | - | - | - | - | - | Fair | - | | |
| Sign Shop | | | | | | | | | | | | | | | | |
| 1st | 1 | Sign Shop | Gas Unit Heater | Reznor | - | - | - | - | - | - | - | - | Fair | - | | |
| 1st | 1 | Sign Shop | Gas Unit Heater | Bryant | - | - | - | - | - | - | - | - | Fair | - | | |
| Golf Course | | | | | | | | | | | | | | | | |
| 1st | 1 | Club House | Vertical Fan Coil Unit | Carrier | FX4CNF030 | 3606A69849 | 2.5-ton | 1/3 | - | 2.8 | 208/230 | 1 | Good | 2006 | | |
| Basement | 1 | Snack Bar | Vertical Fan Coil Unit (DX/Gas) | Carrier | CNPVP8024A | 3806K25447 | 5-ton | - | - | - | 208/230 | 1 | Good | 2006 | | |
| Grade | 1 | Snack Bar | CU | Carrier | 24ACA360A300 | 0407E23612 | 5-ton | - | 26.4 | - | 208/230 | 1 | Good | 2007 | | |
| Roof | 1 | Club House | CU | Carrier | 24ACA330A300 | 1306E36180 | 2.5-ton | - | 12.8 | - | 208/230 | 1 | Good | 2006 | | |
| Golf Maintenance | | | | | | | | | | | | | | | | |
| 1st | 2 | Shop | Gas Unit Heater | Dayton | 3E228A | C8842301 | 65 MBH | - | - | - | 120 | 1 | Good | 1988 | | |
| 1st | 1 | Office | Window Air Conditioner | LG | - | - | 1-ton | - | - | - | 120 | 1 | Good | - | | |
| Trinity | | | | | | | | | | | | | | | | |
| Basement | 2 | Steam System | Steam Boiler | Aldrich | HF-2650 | 04F-1620 | 2650 lbs/hr | 2 | - | 6.4 | 208 | 3 | Good | 2004 | | |
| 1st Floor | 5 | Building | Window Air Conditioner | - | - | - | 1-ton | - | - | - | - | - | Fair | - | | |
| Park Maintenance | | | | | | | | | | | | | | | | |
| 1st | 1 | Shop | Gas Unit Heater | Reznor | F50 | - | 50 MBH Input | - | - | - | 115 | 1 | Good | 1989 | | |
| 1st | 1 | Shop | Gas Unit Heater | Dayton | 3E243D | - | 150 MBH Input | - | - | - | 115 | 1 | Good | 2008 | | |
| 1st | 1 | Shop | Horiz. Gas Furnace | Lennox | GS6-130 | - | 130 MBH Input | - | - | - | - | - | Good | - | 80% eff. | |
| 1st | 1 | Office | Window Air Conditioner | - | - | - | 1-ton | - | - | - | 115 | 1 | Fair | - | | |
| 1st | 1 | Shop | Gas Unit Heater | - | - | - | 50 MBH Input | - | - | - | 115 | 1 | Good | - | | |
| 1st | 1 | Shop | Gas Unit Heater | - | - | - | 100 MBH | - | - | - | 115 | 1 | Good | - | | |



Appendix L

Cost Estimate

ESTIMATE OF PROBABLE COST

| | | |
|--|--|------------------------------------|
| Project Name University City Municipal Buildings DES | Status of Design | Date 2/21/2012 |
| Building Annex | Estimated by ALLEN & HOSHALL | Last Modified: 2/21/2012 |
| Project Number ECM-1.1: Lighting Retrofit | | |

| Item Description | Quantity | | Material/Equip. Cost | | Labor Cost | | Engineering Est | |
|-------------------------|----------|------|----------------------|------------|------------|------------|-----------------|------------|
| | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| DEMOLITION | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL DEMOLITION | | | | \$0 | | \$0 | | \$0 |

| Lighting | | | | | | | | |
|-----------------------|--------|------|-----------|-----------------|-----------|------------|------------|-----------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| Lighting Retrofit | 1 | LS | 60785.11 | \$60,785 | 0.00 | \$0 | 1.00 | \$60,785 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL Lighting | | | | \$60,785 | | \$0 | | \$60,785 |

| ELECTRICAL | | | | | | | | |
|-------------------------|--------|------|-----------|------------|-----------|------------|------------|------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL ELECTRICAL | | | | \$0 | | \$0 | | \$0 |

| | | | | | | | | |
|-------------------------|--|--|--|--|--|--|--|-----------------|
| Sub-total | | | | | | | | |
| Tax (Material @ 9.5%) | | | | | | | | |
| Overhead & Profit (20%) | | | | | | | | |
| Contingency (5%) | | | | | | | | |
| TOTAL | | | | | | | | \$60,785 |

ESTIMATE OF PROBABLE COST

| | | |
|--|--|------------------------------------|
| Project Name University City Municipal Buildings DES | Status of Design | Date 2/21/2012 |
| Building City Hall | Estimated by ALLEN & HOSHALL | Last Modified: 2/21/2012 |
| Project Number ECM-1.2: Lighting Retrofit | | |

| Item Description | Quantity | | Material/Equip. Cost | | Labor Cost | | Engineering Est | |
|-------------------------|----------|------|----------------------|------------|------------|------------|-----------------|------------|
| | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| DEMOLITION | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL DEMOLITION | | | | \$0 | | \$0 | | \$0 |

| Lighting | | | | | | | | |
|-----------------------|--------|------|-----------|-----------------|-----------|------------|------------|-----------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| Lighting Retrofit | 1 | LS | 20396.98 | \$20,397 | 0.00 | \$0 | 1.00 | \$20,397 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | 1.25 | |
| TOTAL Lighting | | | | \$20,397 | | \$0 | | \$20,397 |

| ELECTRICAL | | | | | | | | |
|-------------------------|--------|------|-----------|------------|-----------|------------|------------|------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL ELECTRICAL | | | | \$0 | | \$0 | | \$0 |

| | | | | | | | | |
|-------------------------|--|--|--|--|--|--|--|-----------------|
| Sub-total | | | | | | | | |
| Tax (Material @ 9.5%) | | | | | | | | |
| Overhead & Profit (20%) | | | | | | | | |
| Contingency (5%) | | | | | | | | |
| TOTAL | | | | | | | | \$20,397 |

ESTIMATE OF PROBABLE COST

| | | |
|--|--|------------------------------------|
| Project Name University City Municipal Buildings DES | Status of Design | Date 2/21/2012 |
| Building Community Center | Estimated by ALLEN & HOSHALL | Last Modified: 2/21/2012 |
| Project Number ECM-1.3: Lighting Retrofit | | |

| Item Description | Quantity | | Material/Equip. Cost | | Labor Cost | | Engineering Est | |
|-------------------------|----------|------|----------------------|------------|------------|------------|-----------------|------------|
| | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| DEMOLITION | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL DEMOLITION | | | | \$0 | | \$0 | | \$0 |

| Lighting | | | | | | | | |
|-----------------------|--------|------|-----------|----------------|-----------|------------|------------|----------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| Lighting Retrofit | 1 | LS | 5780.02 | \$5,780 | 0.00 | \$0 | 1.00 | \$5,780 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL Lighting | | | | \$5,780 | | \$0 | | \$5,780 |

| ELECTRICAL | | | | | | | | |
|-------------------------|--------|------|-----------|------------|-----------|------------|------------|------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL ELECTRICAL | | | | \$0 | | \$0 | | \$0 |

| | | | | | | | | |
|-------------------------|--|--|--|--|--|--|--|----------------|
| Sub-total | | | | | | | | |
| Tax (Material @ 9.5%) | | | | | | | | |
| Overhead & Profit (20%) | | | | | | | | |
| Contingency (5%) | | | | | | | | |
| TOTAL | | | | | | | | \$5,780 |

ESTIMATE OF PROBABLE COST

| | | |
|--|--|------------------------------------|
| Project Name University City Municipal Buildings DES | Status of Design | Date 2/21/2012 |
| Building Fire Station #2 | Estimated by ALLEN & HOSHALL | Last Modified: 2/21/2012 |
| Project Number ECM-1.4: Lighting Retrofit | | |

| Item Description | Quantity | | Material/Equip. Cost | | Labor Cost | | Engineering Est | |
|-------------------------|----------|------|----------------------|------------|------------|------------|-----------------|------------|
| | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| DEMOLITION | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL DEMOLITION | | | | \$0 | | \$0 | | \$0 |

| Lighting | | | | | | | | |
|-------------------------|--------|------|-----------|----------------|-----------|-------------|------------|----------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| Lighting Retrofit | 1 | EA | 5079.16 | \$5,079 | 12.50 | \$13 | 1.00 | \$5,092 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL Electrical | | | | \$5,079 | | \$13 | | \$5,092 |

| ELECTRICAL | | | | | | | | |
|-------------------------|--------|------|-----------|------------|-----------|------------|------------|------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL ELECTRICAL | | | | \$0 | | \$0 | | \$0 |

| | | | | | | | | |
|-------------------------|--|--|--|--|--|--|--|----------------|
| Sub-total | | | | | | | | |
| Tax (Material @ 9.5%) | | | | | | | | |
| Overhead & Profit (20%) | | | | | | | | |
| Contingency (15%) | | | | | | | | |
| TOTAL | | | | | | | | \$5,092 |

ESTIMATE OF PROBABLE COST

| | | |
|--|--|------------------------------------|
| Project Name University City Municipal Buildings DES | Status of Design | Date 2/21/2012 |
| Building Golf Course | Estimated by ALLEN & HOSHALL | Last Modified: 2/21/2012 |
| Project Number ECM-1.5 Lighting Retrofit | | |

| Item Description | Quantity | | Material/Equip. Cost | | Labor Cost | | Engineering Est | |
|-------------------------|----------|------|----------------------|------------|------------|------------|-----------------|------------|
| | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| DEMOLITION | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL DEMOLITION | | | | \$0 | | \$0 | | \$0 |

| Lighting | | | | | | | | |
|-------------------------|--------|------|-----------|----------------|-----------|-------------|------------|----------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| Lighting Retrofit | 1 | EA | 1097.00 | \$1,097 | 12.50 | \$13 | 1.00 | \$1,109 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL Electrical | | | | \$1,097 | | \$13 | | \$1,109 |

| ELECTRICAL | | | | | | | | |
|-------------------------|--------|------|-----------|------------|-----------|------------|------------|------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL ELECTRICAL | | | | \$0 | | \$0 | | \$0 |

| | | | | | | | | |
|-------------------------|--|--|--|--|--|--|--|----------------|
| Sub-total | | | | | | | | |
| Tax (Material @ 9.5%) | | | | | | | | |
| Overhead & Profit (20%) | | | | | | | | |
| Contingency (15%) | | | | | | | | |
| TOTAL | | | | | | | | \$1,109 |

ESTIMATE OF PROBABLE COST

| | | |
|--|--|------------------------------------|
| Project Name University City Municipal Buildings DES | Status of Design | Date 2/21/2012 |
| Building Public Works | Estimated by ALLEN & HOSHALL | Last Modified: 2/21/2012 |
| Project Number ECM-1.6 Lighting Retrofit | | |

| Item Description | Quantity | | Material/Equip. Cost | | Labor Cost | | Engineering Est | |
|-------------------------|----------|------|----------------------|------------|------------|------------|-----------------|------------|
| | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| DEMOLITION | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL DEMOLITION | | | | \$0 | | \$0 | | \$0 |

| Lighting | | | | | | | | |
|-------------------------|--------|------|-----------|-----------------|-----------|-------------|------------|-----------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| Lighting Retrofit | 1 | EA | 29757.85 | \$29,758 | 12.50 | \$13 | 1.00 | \$29,770 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL Electrical | | | | \$29,758 | | \$13 | | \$29,770 |

| ELECTRICAL | | | | | | | | |
|-------------------------|--------|------|-----------|------------|-----------|------------|------------|------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL ELECTRICAL | | | | \$0 | | \$0 | | \$0 |

| | | | | | | | | |
|-------------------------|--|--|--|--|--|--|--|-----------------|
| Sub-total | | | | | | | | |
| Tax (Material @ 9.5%) | | | | | | | | |
| Overhead & Profit (20%) | | | | | | | | |
| Contingency (15%) | | | | | | | | |
| TOTAL | | | | | | | | \$29,770 |

ESTIMATE OF PROBABLE COST

| | | |
|--|--|------------------------------------|
| Project Name University City Municipal Buildings DES | Status of Design | Date 2/21/2012 |
| Building Recreation Center | Estimated by ALLEN & HOSHALL | Last Modified: 2/21/2012 |
| Project Number ECM-1.7 Lighting Retrofit | | |

| Item Description | Quantity | | Material/Equip. Cost | | Labor Cost | | Engineering Est | |
|-------------------------|----------|------|----------------------|------------|------------|------------|-----------------|------------|
| | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| DEMOLITION | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL DEMOLITION | | | | \$0 | | \$0 | | \$0 |

| Lighting | | | | | | | | |
|-------------------------|--------|------|-----------|-----------------|-----------|-------------|------------|-----------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| Lighting Retrofit | 1 | EA | 40076.48 | \$40,076 | 12.50 | \$13 | 1.00 | \$40,089 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL Electrical | | | | \$40,076 | | \$13 | | \$40,089 |

| ELECTRICAL | | | | | | | | |
|-------------------------|--------|------|-----------|------------|-----------|------------|------------|------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL ELECTRICAL | | | | \$0 | | \$0 | | \$0 |

| | | | | | | | | |
|-------------------------|--|--|--|--|--|--|--|-----------------|
| Sub-total | | | | | | | | |
| Tax (Material @ 9.5%) | | | | | | | | |
| Overhead & Profit (20%) | | | | | | | | |
| Contingency (15%) | | | | | | | | |
| TOTAL | | | | | | | | \$40,089 |

ESTIMATE OF PROBABLE COST

| | | |
|--|--|------------------------------------|
| Project Name University City Municipal Buildings DES | Status of Design | Date 2/21/2012 |
| Building Trinity Building | Estimated by ALLEN & HOSHALL | Last Modified: 2/21/2012 |
| Project Number ECM-1.8 Lighting Retrofit | | |

| Item Description | Quantity | | Material/Equip. Cost | | Labor Cost | | Engineering Est | |
|-------------------------|----------|------|----------------------|------------|------------|------------|-----------------|------------|
| | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| DEMOLITION | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL DEMOLITION | | | | \$0 | | \$0 | | \$0 |

| Lighting | | | | | | | | |
|-------------------------|--------|------|-----------|----------------|-----------|-------------|------------|----------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| Lighting Retrofit | 1 | EA | 8620.86 | \$8,621 | 12.50 | \$13 | 1.00 | \$8,633 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL Electrical | | | | \$8,621 | | \$13 | | \$8,633 |

| ELECTRICAL | | | | | | | | |
|-------------------------|--------|------|-----------|------------|-----------|------------|------------|------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL ELECTRICAL | | | | \$0 | | \$0 | | \$0 |

| | | | | | | | | |
|-------------------------|--|--|--|--|--|--|--|----------------|
| Sub-total | | | | | | | | |
| Tax (Material @ 9.5%) | | | | | | | | |
| Overhead & Profit (20%) | | | | | | | | |
| Contingency (15%) | | | | | | | | |
| TOTAL | | | | | | | | \$8,633 |

ESTIMATE OF PROBABLE COST

| | | |
|---|--|------------------------------------|
| Project Name University City Municipal Buildings DES | Status of Design | Date 2/21/2012 |
| Building Central Garage | Estimated by ALLEN & HOSHALL | Last Modified: 2/21/2012 |
| Project Number ECM-2.1: Install Programable T-stats & Locking Cover | | |

| Item Description | Quantity | | Material/Equip. Cost | | Labor Cost | | Engineering Est | |
|-------------------------|----------|------|----------------------|------------|------------|------------|-----------------|------------|
| | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| DEMOLITION | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL DEMOLITION | | | | \$0 | | \$0 | | \$0 |

| | | | | | | | | |
|--|---|----|--------|--------------|-------|-------------|------|--------------|
| MECHANICAL | | | | | | | | |
| Install Programable T-stat & Locking Cover | 1 | EA | 120.00 | \$120 | 40.00 | \$40 | 1.00 | \$160 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL MECHANICAL | | | | \$120 | | \$40 | | \$160 |

| | | | | | | | | |
|-------------------------|--|--|--|------------|--|------------|--|------------|
| ELECTRICAL | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL ELECTRICAL | | | | \$0 | | \$0 | | \$0 |

| | | | | | | | | |
|-------------------------|--|--|--|--|--|--|--|--------------|
| Sub-total | | | | | | | | \$160 |
| Tax (Material @ 9.5%) | | | | | | | | \$11 |
| Overhead & Profit (20%) | | | | | | | | \$32 |
| Contingency (15%) | | | | | | | | \$24 |
| TOTAL | | | | | | | | \$227 |

ESTIMATE OF PROBABLE COST

| | | |
|---|--|------------------------------------|
| Project Name University City Municipal Buildings DES | Status of Design | Date 2/21/2012 |
| Building City Hall | Estimated by ALLEN & HOSHALL | Last Modified: 2/21/2012 |
| Project Number ECM-2.2: Install Plug Load Occupancy Sensors | | |

| Item Description | Quantity | | Material/Equip. Cost | | Labor Cost | | Engineering Est | |
|-------------------------|----------|------|----------------------|------------|------------|------------|-----------------|------------|
| | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| DEMOLITION | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL DEMOLITION | | | | \$0 | | \$0 | | \$0 |

| MECHANICAL | | | | | | | | |
|--|-----------|-----------|--------------|----------------|--------------|--------------|-------------|----------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| Install Plug Load Occupancy Sensors | 55 | EA | 90.00 | \$4,950 | 12.50 | \$688 | 1.00 | \$5,638 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL MECHANICAL | | | | \$4,950 | | \$688 | | \$5,638 |

| ELECTRICAL | | | | | | | | |
|-------------------------|--------|------|-----------|------------|-----------|------------|------------|------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL ELECTRICAL | | | | \$0 | | \$0 | | \$0 |

| | | | | | | | | |
|------------------------------------|--|--|--|--|--|--|--|----------------|
| Sub-total | | | | | | | | \$5,638 |
| Tax (Material @ 9.5%) | | | | | | | | \$470 |
| Overhead & Profit (20%) | | | | | | | | \$1,128 |
| Contingency (15%) | | | | | | | | \$846 |
| TOTAL | | | | | | | | \$8,081 |

ESTIMATE OF PROBABLE COST

| | | |
|---|--|-----------------------------|
| Project Name University City Municipal Buildings DES | Status of Design | Date 2/21/2012 |
| Building Annex | Estimated by ALLEN & HOSHALL | Last Modified: 2/21/2012 |
| Project Number ECM-2.3: Install Plug Load Occupancy Sensors | | |

| Item Description | Quantity | | Material/Equip. Cost | | Labor Cost | | Engineering Est | |
|-------------------------|----------|------|----------------------|------------|------------|------------|-----------------|------------|
| | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| DEMOLITION | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL DEMOLITION | | | | \$0 | | \$0 | | \$0 |

| MECHANICAL | | | | | | | | |
|-------------------------------------|--------|------|-----------|----------------|-----------|--------------|------------|----------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| Install Plug Load Occupancy Sensors | 75 | EA | 90.00 | \$6,750 | 12.50 | \$938 | 1.00 | \$7,688 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL MECHANICAL | | | | \$6,750 | | \$938 | | \$7,688 |

| ELECTRICAL | | | | | | | | |
|-------------------------|--------|------|-----------|------------|-----------|------------|------------|------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL ELECTRICAL | | | | \$0 | | \$0 | | \$0 |

| | | | | | | | | |
|------------------------------------|--|--|--|--|--|--|--|-----------------|
| Sub-total | | | | | | | | \$7,688 |
| Tax (Material @ 9.5%) | | | | | | | | \$641 |
| Overhead & Profit (20%) | | | | | | | | \$1,538 |
| Contingency (15%) | | | | | | | | \$1,153 |
| TOTAL | | | | | | | | \$11,019 |

ESTIMATE OF PROBABLE COST

| | | |
|--|--|-----------------------------|
| Project Name University City Municipal Buildings DES | Status of Design | Date 2/21/2012 |
| Building Annex | Estimated by ALLEN & HOSHALL | Last Modified: 2/21/2012 |
| Project Number ECM-4.1: Unit Replacement | | |

| Item Description | Quantity | | Material/Equip. Cost | | Labor Cost | | Engineering Est | |
|--|----------|------|----------------------|------------|------------|----------------|-----------------|----------------|
| | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| DEMOLITION | | | | | | | | |
| Demo 5-ton Condensing Unit and Evaporator Coil | 1 | EA | 0.00 | \$0 | 700.00 | \$700 | 1.25 | \$875 |
| Demo 3-ton Condensing Unit and Evaporator Coil | 2 | EA | 0.00 | \$0 | 700.00 | \$1,400 | 1.25 | \$1,750 |
| Demo 3-ton WSHP | 3 | EA | 0.00 | \$0 | 830.00 | \$2,490 | 1.25 | \$3,113 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL DEMOLITION | | | | \$0 | | \$4,590 | | \$5,738 |

| MECHANICAL | | | | | | | | |
|--|---|----|----------|-----------------|---------|----------------|------|-----------------|
| Install 5-ton Condensing Unit & Evaporator Coil | 1 | EA | 3450.00 | \$3,450 | 1499.00 | \$1,499 | 1.25 | \$6,186 |
| Install 3-ton Condensing Unit & Evaporator Coil | 2 | EA | 2310.00 | \$4,620 | 772.00 | \$1,544 | 1.25 | \$7,705 |
| Install 3-ton Computer Room Unit with remote Condenser | 2 | EA | 16100.00 | \$32,200 | 1500.00 | \$3,000 | 1.25 | \$44,000 |
| Install 3-ton Split System HP | 1 | EA | 3635.00 | \$3,635 | 822.00 | \$822 | 1.25 | \$5,571 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL MECHANICAL | | | | \$43,905 | | \$6,865 | | \$63,463 |

| ELECTRICAL | | | | | | | | |
|-------------------------|--|--|--|------------|--|------------|--|------------|
| Electrical Connection | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL ELECTRICAL | | | | \$0 | | \$0 | | \$0 |

| | | | | | | | | |
|-------------------------|--|--|--|--|--|--|--|-----------------|
| Sub-total | | | | | | | | \$69,200 |
| Tax (Material @ 9.5%) | | | | | | | | \$4,171 |
| Overhead & Profit (20%) | | | | | | | | \$13,840 |
| Contingency (15%) | | | | | | | | \$10,380 |
| TOTAL | | | | | | | | \$97,591 |

ESTIMATE OF PROBABLE COST

| | | |
|--|--|------------------------------------|
| Project Name University City Municipal Buildings DES | Status of Design | Date 2/21/2012 |
| Building Heman Park Pool | Estimated by ALLEN & HOSHALL | Last Modified: 2/21/2012 |
| Project Number ECM-4.2: Pump Motor Replacement | | |

| Item Description | Quantity | | Material/Equip. Cost | | Labor Cost | | Engineering Est | |
|-------------------------|----------|------|----------------------|------------|------------|--------------|-----------------|--------------|
| | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| DEMOLITION | | | | | | | | |
| Remove Pump Motor | 1 | EA | 0.00 | \$0 | 150.00 | \$150 | 1.25 | \$188 |
| | | | | | | | | |
| TOTAL DEMOLITION | | | | \$0 | | \$150 | | \$188 |

| MECHANICAL | | | | | | | | |
|--------------------------|----------|------|-----------|----------------|-----------|--------------|------------|----------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| Install 40 hp pump motor | 1 | EA | 2400.00 | \$2,400 | 201.00 | \$201 | 1.25 | \$3,251 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL MECHANICAL | 1 | | | \$2,400 | | \$201 | | \$3,251 |

| ELECTRICAL | | | | | | | | |
|-------------------------|--------|------|-----------|------------|-----------|------------|------------|------------|
| Item Description | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL ELECTRICAL | | | | \$0 | | \$0 | | \$0 |

| | | | | | | | | |
|-------------------------|--|--|--|--|--|--|--|----------------|
| Sub-total | | | | | | | | \$3,439 |
| Tax (Material @ 9.5%) | | | | | | | | \$228 |
| Overhead & Profit (20%) | | | | | | | | \$688 |
| Contingency (15%) | | | | | | | | \$516 |
| TOTAL | | | | | | | | \$4,870 |

ESTIMATE OF PROBABLE COST

| | | |
|--|--|-----------------------------|
| Project Name University City Municipal Buildings DES | Status of Design | Date 2/21/2012 |
| Building Central Garage | Estimated by ALLEN & HOSHALL | Last Modified: 2/21/2012 |
| Project Number ECM-4.3: Unit Replacement | | |

| Item Description | Quantity | | Material/Equip. Cost | | Labor Cost | | Engineering Est | |
|-----------------------------|----------|------|----------------------|------------|------------|------------|-----------------|------------|
| | Number | Unit | Unit Cost | Total | Unit Cost | Total | Escalation | Total |
| DEMOLITION | | | | | | | | |
| Remove 2.5-ton Split System | 1 | EA | 0.00 | \$0 | | \$0 | 1.25 | \$0 |
| Remove 3-ton Split System | 1 | EA | 0.00 | \$0 | | \$0 | 1.25 | \$0 |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL DEMOLITION | | | | \$0 | | \$0 | | \$0 |

| | | | | | | | | |
|---------------------------------|---|----|---------|----------------|--------|----------------|------|-----------------|
| MECHANICAL | | | | | | | | |
| Install 2.5-ton HP Split System | 1 | EA | 3875.00 | \$3,875 | 81.00 | \$614 | 1.25 | \$5,611 |
| Install 3-ton HP Split System | 1 | EA | 4375.00 | \$4,375 | 520.00 | \$812 | 1.25 | \$6,484 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| TOTAL MECHANICAL | | | | \$8,250 | | \$1,426 | | \$12,095 |

| | | | | | | | | |
|-------------------------|--|--|--|------------|--|------------|--|------------|
| ELECTRICAL | | | | | | | | |
| Electrical Connection | | | | | | | | |
| | | | | | | | | |
| TOTAL ELECTRICAL | | | | \$0 | | \$0 | | \$0 |

| | | | | | | | | |
|-------------------------|--|--|--|--|--|--|--|-----------------|
| Sub-total | | | | | | | | \$12,095 |
| Tax (Material @ 9.5%) | | | | | | | | \$784 |
| Overhead & Profit (20%) | | | | | | | | \$2,419 |
| Contingency (20%) | | | | | | | | \$2,419 |
| TOTAL | | | | | | | | \$17,717 |